

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8806140251 DOC.DATE: 88/06/06 NOTARIZED: NO DOCKET.#
 FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH.NAME AUTHOR AFFILIATION
 CONWAY,W.F. Florida Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Special rept:breached fire barriers & other fire protection
 sys impairments.

DISTRIBUTION CODE: IE22D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 4
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL	
	PD2-2 LA		1	1		PD2-2 PD		1	1	
	EDISON,G		1	1						
INTERNAL:	ACRS MICHELSON		1	1		ACRS MOELLER		2	2	
	AEOD/DOA		1	1		AEOD/DSP/NAS		1	1	
	AEOD/DSP/ROAB		2	2		AEOD/DSP/TPAB		1	1	
	ARM/DCTS/DAB		1	1		DEDRO		1	1	
	NRR/DEST/ADS 7E		1	0		NRR/DEST/CEB 8H		1	1	
	NRR/DEST/ESB 8D		1	1		NRR/DEST/ICSB 7		1	1	
	NRR/DEST/MEB 9H		1	1		NRR/DEST/MTB 9H		1	1	
	NRR/DEST/PSB 8D		1	1		NRR/DEST/RSB 8E		1	1	
	NRR/DEST/SGB 8D		1	1		NRR/DLPQ/HFB 10		1	1	
	NRR/DLPQ/QAB 10		1	1		NRR/DOEA/EAB 11		1	1	
	NRR/DREP/RAB 10		1	1		NRR/DREP/RPB 10		2	2	
	NRR/DRIS/SIB 9A		1	1		NUDOCS-ABSTRACT		1	1	
	REG FILE 02		1	1		RES TELFORD,J		1	1	
	RES/DE/EIB		1	1		RES/DRPS DEPY		1	1	
	RGN2 FILE 01		1	1						
EXTERNAL:	EG&G WILLIAMS,S		4	4		FORD BLDG HOY,A		1	1	
	H ST LOBBY WARD		1	1		LPDR		1	1	
	NRC PDR		1	1		NSIC HARRIS,J		1	1	
	NSIC MAYS,G		1	1						

TOTAL NUMBER OF COPIES REQUIRED: LTTR 45 ENCL 44



JUNE 6 1988

L-88-251

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555


Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Special Report - Breached Fire Barriers and
Other Fire Protection System Impairments

In accordance with Technical Specification 6.9.3 the attached
Special Report is provided for your information.

Should there be any questions on this information, please
contact us.

Very truly yours,


W. F. Conway
Sr. Vice President-Nuclear

WFC/PP/gp

Attachment

cc: Dr. J. Nelson Grace, Regional Administrator,
Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

SDF/009.BFB

IER2
11

8806140251 880606
PDR ADCK 05000250
S DCD

an FPL Group company

SPECIAL REPORT

JUNE 6, 1988

FIRE PROTECTION SYSTEM IMPAIRMENTS REQUIRING NRC NOTIFICATION

Purpose:

Technical Specification (TS) 3.14.5.b requires the submission of a report to the NRC if a non-functional fire barrier penetration is not returned to functional status within 7 days. TS 3.14 also states that certain other conditions require NRC notification. In accordance with the above requirements, this special report is being generated in order to notify the NRC. This report is being updated on a 30 day basis.

Event:

Turkey Point has been and is continuing to implement plant modifications. Fire Protection System (FPS) impairments are, at times, incurred during the performance of these modifications. Occasionally, certain FPS features fail due to random component failure.

Cause and Corrective Actions:

The primary cause of the impairments is the number of modifications being performed. Many of these modifications require the impairment of certain FPS features for their completion. The secondary cause for the impairments is FPS equipment malfunction. Because Turkey Point incurs a variable number of impairments, the plant is reporting the impairments in a monthly report, rather than on a case-by-case basis. The impairments reported this month may be either open or closed at the present time, however they were open in excess of the Technical Specification permitted time limit.

This report includes impairments not reported previously which were:

- 1) opened prior to June and
- 2) stayed open for longer than the time permitted by the Technical Specifications, and
- 3) are either still open or were closed prior to June. The closed impairments have been reported at the time opened, unless noted otherwise.

The plant continues to implement the compensatory measures as applicable.

FIRE PROTECTION SYSTEM IMPAIRMENTS OPENED SINCE 04-31-88 REPORT
WHICH HAVE BEEN OPEN FOR LONGER THAN TECH SPEC LIMITS

Page No.
06/02/88

1

FPI#	DESCRIPTION	OPEN	CLOSED
1521	BARRIER-MH421	05/18/88	/ /
1573	BARRIER 033F	05/18/88	/ /
1583	PENETRATION 106E-E006	05/18/88	/ /
1620	DOOR D-104-1	05/03/88	05/17/88
1633	PENETRATION 097E-E031	04/25/88	05/09/88
1634	PENETRATION 097E-E031	04/25/88	05/09/88
1635	BARRIER 098E	04/25/88	05/09/88
1636	PENETRATION 097F-E014	04/25/88	05/13/88
1637	PENETRATION 097F-E011	04/25/88	05/13/88
1638	PENETRATION 097E-E028	04/25/88	05/09/88
1639	PENETRATION 097S-H001	04/26/88	05/05/88
1641	DAMPER 48-A	04/27/88	/ /
1668	PENETRATION 104E2-E002	05/10/88	/ /
1671	FIRE DOOR 58-1	05/15/88	/ /
1675	PENET-CND. SEAL 3B07	05/23/88	/ /

FIRE PROTECTION SYSTEM IMPAIRMENTS PREVIOUSLY
NOT REPORTED CLOSED

FPI#	DESCRIPTION	OPEN	CLOSED
1311	PENETRAT.CONDUIT 3F401	02/06/88	05/02/88
1322	PENETRATION-030F-M001	02/29/88	05/09/88
1328	PENETRATION 040F-M001	02/29/88	05/02/88
1331	PENETRATION 014N-M020	02/29/88	05/02/88
1345	PENETRATION 036F-M008	02/29/88	05/09/88
1376	DOOR 27-1	01/18/88	05/13/88
1386	PENETRATION 012W-M005	01/20/88	05/02/88
1389	PENETRATION 014N-M025	01/20/88	05/06/88
1394	PENETRATION 016W-M003	01/20/88	05/02/88
1396	BARRIER 11S	01/20/88	05/02/88
1435	PENETRATION 097S-E002	02/23/88	05/13/88
1515	PENETRATION 068W-E001	03/30/88	05/13/88
1528	PENETRATION 067S-E006	04/07/88	05/13/88
1529	PENETRATION 068W-E001	04/07/88	05/13/88
1530	PENETRATION 098F-E055	04/07/88	05/11/88
1531	PENETRATION 106E-E005	04/07/88	05/11/88
1532	PENETRATION 067E-E008	04/07/88	05/11/88
1533	PENETRATION 106S-E002	04/07/88	05/11/88
1534	PENETRATION 106N-E009	04/07/88	05/11/88
1536	BARRIER 098W	04/07/88	05/09/88
1544	PENETRATION 040F-H001	04/12/88	05/02/88
1545	PENETRATION 028N-E018	04/12/88	05/06/88
1738	PENETRATION 108AS-E003	03/22/88	05/02/88
1739	BARRIER 18-58-07 TSI	03/22/88	05/04/88
1741	PENET.-PER CRN-C-1892	04/05/88	05/04/88
1747	PENETRATION 098F-E053	04/14/88	05/09/88