

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8808310217 DOC. DATE: 88/08/15 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME -AUTHOR AFFILIATION
 CONWAY, W.F. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 KAHLE, J.B. Region 2, Ofc of the Director

SUBJECT: Forwards results of NRC confirmatory measurements program samples.

DISTRIBUTION CODE: IE06D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Environ & Radiological (50 DKT)-Insp Rept/Notice of Violation Respons

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD2-2 LA | 1 0 | PD2-2 PD | 1 1 |
| | EDISON, G | 1 1 | | |
| INTERNAL: | AEOD/DOA | 1 1 | AEOD/DSP | 1 1 |
| | NMSS/LLOB 5E4 | 1 1 | NMSS/SGOB 4E4 | 1 1 |
| | NRR/DLPQ/PEB 11 | 1 1 | NRR/DOEA/EAB 11 | 1 1 |
| | NRR/DREP/EPB 10 | 1 1 | NRR/DREP/RPB 10 | 2 2 |
| | NRR/PMAS/ILRB12 | 1 1 | NUDOCS-ABSTRACT | 1 1 |
| | OGC/HDS2 | 1 1 | REG-FILE 02 | 1 1 |
| | RES | 1 1 | RES/DSIR DEPY | 1 1 |
| | RGN2 FILE 01 | 1 1 | RGN2/DRSS/EPRPB | 1 1 |
| | RGN4 MURRAY, B | 1 1 | | |
| EXTERNAL: | LPDR | 1 1 | NRC PDR | 1 1 |
| | NSIC | 1 1 | | |

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 23



017 012:27

AUGUST, 15 1988

L-88-350

U. S. Nuclear Regulatory Commission
Attn: Mr. J. B. Kahle, Chief
Radiological Effluents and Chemistry Section
101 Marietta St., N.W., Suite 2900
Atlanta, GA 30323

Dear Mr. Kahle:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Results of the NRC Confirmatory
Measurements Program Samples

In response to a NRC request dated April 21, 1988, Florida Power & Light Company (FPL) is submitting the results of the spiked sample analysis performed under the subject program.

The sample received by Turkey Point Plant on June 14, 1988, was analyzed in accordance with the instructions that accompanied the sample. The attached results are decay corrected to May 12, 1988.

Should there be any additional information needed, please contact us.

Very truly yours,

W. F. Conway
W. F. Conway
Senior Vice President - Nuclear

WFC/SDF/gp

Attachment

cc: Dr. J. Nelson Grace, Regional Administrator,
Region II, USNRC
Document Control Desk, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

SDF/010.MPS

8808310217 880815
PDR ADOCK 05000250
PDC

111
IE06
an FPL Group company

ATTACHMENT

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Results of the NRC Confirmatory
Measurements Program Samples

| <u>Nuclide</u> | <u>Value</u> | <u>% Uncertainties</u> |
|----------------|--------------|------------------------|
| Tritium | 2.086 E-5 | 10% |
| Sr89 | 1.66 E-4 | 10% |
| Sr90 | 9.01 E-6 | 10% |
| Fe55 | 2.17 E-5 | 10% |

