

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8809190173 DOC.DATE: 88/09/12 NOTARIZED: NO DOCKET #
 FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH.NAME AUTHOR AFFILIATION
 CONWAY,W.F. Florida Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards response to NRC 880812 ltr re violations noted in
 Insp Repts 50-250/86-06 & 50-251/86-06.

DISTRIBUTION CODE: IE01D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-2 PD	1 1	EDISON,G	2 2
INTERNAL: AEOD	1 1	DEDRO	1 1
NRR MORISSEAU,D	1 1	NRR/DLPQ/PEB 11	1 1
NRR/DLPQ/QAB 10	1 1	NRR/DOEA DIR 11	1 1
NRR/DREP/EPB 10	1 1	NRR/DREP/RPB 10	2 2
NRR/DRIS DIR 9A	1 1	NRR/PMAS/ILRB12	1 1
NUDOCS-ABSTRACT	1 1	OE LIEBERMAN,J	1 1
OGC/HDS2	1 1	<u>REG FILE</u> 02	1 1
RES/DSIR DEPY	1 1	RGN2 FILE 01	1 1
INTERNAL: LPDR	1 1	NRC PDR	1 1
NSIC	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 23





SEPTEMBER 12 1988

L-88-400

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555


Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Reply to Notice of Violation
Inspection Report 86-06 (Revised Response)

By letter L-86-228 dated May 29, 1986, Florida Power & Light Company provided a response to the Notice of Violation in NRC Inspection Report Nos. 50-250/86-06 and 50-251/86-06 dated April 15, 1986.

In response to a request by Mr. W. P. Kleinsorge, NRC Region II, made at Turkey Point Plant on August 12, 1988, a revised response is attached.

Very truly yours,


W. F. Conway
Senior Vice President - Nuclear

WFC/RG/gp

Attachment

cc: Dr. J. Nelson Grace, Regional Administrator,
Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

8809190173 880912
PDR ADCK 05000250
Q PNU

IE01
11



Attachment

Finding 1

Title 10, Code of Federal Regulations, Part 50, Appendix B, Criterion V requires activities affecting quality be accomplished in accordance with documented procedures containing appropriate acceptance criteria. American Society of Mechanical Engineers Boiler and Pressure Vessel (ASME B&PV) Code Section XI, 1980 through winter 1981 addenda Paragraph IWP-3111, requires that new reference values be determined or previous values be verified by an inservice test run when a reference value or a set of values may have been affected by repair of a pump. FPL Procedure OP-4004.1 has been identified as the applicable procedure for Testing Containment Spray Pump 4B as required by ASME B&PV Code Section XI.

Contrary to the above, Procedure OP-4004.1 did not contain appropriate acceptance criteria in that, after a repair to the 4B Containment Spray Pump, which reduced the vibration values by a factor of three, the reference value for vibration and the associated acceptance criteria in Procedure OP-4004.1 were not amended to reflect the lower vibration values obtained during the post repair test.

Response

- 1) FPL concurs with the finding.
- 2) The reason for the finding was that procedure OP-4004.1 did not clearly establish requirements for reconfirming or establishing new reference values as required by IWP-3111.
- 3) Corrective steps which were taken at the time of the event included a review of the 4B Containment Spray Pump test data during the period October 5, 1983 to May 23, 1984. This period covers the time from repair until the base line values were revised. The maximum pump vibration for this period was 1.0 mils. Therefore, the 4B Containment Spray Pump was operable during the period.
- 4) Corrective Actions which will be taken include:
 - a) Procedures 3/4-OSP-068.2 (current revision of procedure OP-4004.1) will be revised to establish requirements for reconfirming or establishing new reference values as required by IWP-3111.
 - b) The procedures governing Inservice Testing of other pumps will be reviewed and revised as necessary to establish requirements for reconfirming or establishing new reference values as required by IWP-3111, similar to Item 4b above.
- 5) Full compliance for item 4a above will be achieved by October 31, 1988.
Full compliance for item 4b above will be achieved by November 30, 1988.

