

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8904260359 DOC.DATE: 89/04/21 NOTARIZED: NO DOCKET #
 FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH.NAME AUTHOR AFFILIATION
 CONWAY,W.F. Florida Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Special rept:on 890312 & 16,fire protection impairments
 opened for repairs.

DISTRIBUTION CODE: IE22D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-2 LA	1 1	PD2-2 PD	1 1
EDISON,G	1 1		
INTERNAL: ACRS MICHELSON	1 1	ACRS MOELLER	2 2
ACRS WYLIE	1 1	AEOD/DOA	1 1
AEOD/DSP/TPAB	1 1	AEOD/ROAB/DSP	2 2
DEDRO	1 1	IRM/DCTS/DAB	1 1
NRR/DEST/ADE 8H	1 1	NRR/DEST/ADS 7E	1 0
NRR/DEST/CEB 8H	1 1	NRR/DEST/ESB 8D	1 1
NRR/DEST/ICSB 7	1 1	NRR/DEST/MEB 9H	1 1
NRR/DEST/MTB 9H	1 1	NRR/DEST/PSB 8D	1 1
NRR/DEST/RSB 8E	1 1	NRR/DEST/SGB 8D	1 1
NRR/DLPQ/HFB 10	1 1	NRR/DLPQ/QAB 10	1 1
NRR/DOEA/EAB 11	1 1	NRR/DREP/RPB 10	2 2
<u>NRR/DRIS/SIB 9A</u>	1 1	NUDOCS-ABSTRACT	1 1
<u>REG FILE</u> 02	1 1	RES/DSIR/EIB	1 1
RES/DSR/PRAB	1 1	RGN2 FILE 01	1 1
EXTERNAL: EG&G WILLIAMS,S	4 4	FORD BLDG HOY,A	1 1
L ST LOBBY WARD	1 1	LPDR	1 1
NRC PDR	1 1	NSIC MAYS,G	1 1
NSIC MURPHY,G.A	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 44 ENCL 43

1/A-2
 ah



1

2



FPL

P.O. Box 14000, Juno Beach, FL 33408-0420

APRIL 21 1989

L-89-154

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Special Report - Breached Fire Barriers and
Other Fire Protection System Impairments

In accordance with Technical Specification 6.9.3.c, the attached
Special Report is provided for your information.

Should there be any questions on this information, please contact
us.

Very truly yours,

W. F. Conway
W. F. Conway
Senior Vice President - Nuclear

WFC/JRH/cm

Attachment

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

8904260359 890421
PDR ADUCK 05000250
S PDC

LEAD
11

Attachment:

SPECIAL REPORT

FIRE PROTECTION SYSTEM IMPAIRMENTS REQUIRING NRC NOTIFICATION

PURPOSE

Technical Specification (TS) 3.14.5.b requires the submission of a report to the NRC if a non-functional fire barrier penetration is not returned to functional status within 7 days. TS 3.14 also states that certain other conditions require NRC notification. In accordance with the above requirements, this special report is being submitted in order to notify the NRC.

EVENT

Fire Protection Impairment (FPI) 2337 was opened on barrier 093C. FPI 2347 is on detector alarm point 29. FPI 2348 was opened on thermolag barrier B-3K1811. FPI 2365 was opened on thermolag barrier 4F141. FPIs 2379 thru 2383, 2385 thru 2387, 2390 thru 2440 and 2443 thru 2446 were opened for not meeting acceptance criteria during the performance of the semi-annual fire door surveillance. See the attached list.

CAUSE AND CORRECTIVE ACTIONS

FPI 2337, opened March 12, 1989 to repair a cracked barrier, was closed on March 21, 1989. FPI 2347, opened March 16, 1989 for welding in area, was closed on April 4, 1989. FPI 2348, opened March 16, 1989 for thermolag repair, was closed on March 23, 1989. FPI 2365, opened March 27, 1989 to remove a pump, is still being worked. Engineering is presently evaluating the discrepancies identified by the fire door surveillance. The plant continues to implement the compensatory measures as applicable.

STATUS UPDATE

FPI 2311, reported open in FPL letter L-89-130, dated April 4, 1989, was closed on March 23, 1989. FPI 2204, reported open in FPL letter L-89-012, dated January 9, 1989, was closed March 30, 1989. FPI 2257, reported open in FPL letter L-89-58, dated February 23, 1989, was closed on April 1, 1989. FPI 2297, reported open in FPL letter L-89-114, dated March 23, 1989, was closed on April 4, 1989.

FIRE PROTECTION SYSTEM IMPAIRMENTS OPENED SINCE LAST REPORT WHICH
HAVE BEEN OPEN FOR LONGER THAN TECHNICAL SPECIFICATION LIMITS

<u>FPI #</u>	<u>FEATURE TYPE</u>	<u>OPENED</u>	<u>CLOSED</u>
2337	Barrier 093C	03/12/89	03/21/89
2347	Detector 29-1 & 29-2	03/16/89	04/04/89
2348	Thermolag Barrier B-3K1811	03/16/89	03/23/89
2365	Thermolag Barrier 4F141	03/27/89	
2379	Door 61-2	03/27/89	
2380	Door 61-1	03/27/89	
2381	Door 67-1	03/27/89	
2382	Door 67-2	03/27/89	
2383	Door 67-3	03/27/89	
2385	Door 68-1	03/27/89	
2386	Door 63-2	03/27/89	
2387	Door 63-1	03/27/89	
2390	Door 72-1	03/27/89	
2391	Door 74-1	03/27/89	
2392	Door 70-1	03/27/89	
2393	Door 70-2	03/27/89	
2394	Door 71-1	03/27/89	
2395	Door 131-2	03/27/89	
2396	Door 73-1	03/27/89	
2397	Door 75-1	03/27/89	
2398	Door 72-2	03/27/89	
2399	Door 132-2	03/27/89	
2400	Door 104-3	03/27/89	

<u>FPI #</u>	<u>FEATURE TYPE</u>	<u>OPENED</u>	<u>CLOSED</u>
2401	Door 106-2	03/27/89	
2402	Door 132-1	03/27/89	
2403	Door 97-1	03/27/89	
2404	Door 98-2	03/27/89	
2405	Door 104-1	03/27/89	
2406	Door 108A-1	03/27/89	
2407	Door 58-4	03/27/89	
2408	Door 30-2	03/27/89	
2409	Door 30-1	03/27/89	
2410	Door 46-1	03/27/89	
2411	Door 58-3	03/27/89	
2412	Door 40-2	03/27/89	
2413	Door 40-1	03/27/89	
2414	Door 55-1	03/27/89	
2415	Door 41-1	03/27/89	
2416	Door 28-1	03/27/89	
2417	Door 22-1	03/27/89	
2418	Door 21-1	03/27/89	
2419	Door 25-1	03/27/89	
2420	Door 20-1	03/27/89	
2421	Door 19-1	03/27/89	
2422	Door 26-1	03/27/89	
2423	Door 108A-2	03/27/89	
2424	Door 108A-3	03/27/89	
2425	Door 108A-4	03/27/89	
2426	Door 98-1	03/27/89	

<u>FPI #</u>	<u>FEATURE TYPE</u>	<u>OPENED</u>	<u>CLOSED</u>
2427	Door 104-2	03/27/89	
2428	Door 106-1	03/27/89	
2429	Door 96-2	03/27/89	
2430	Door 108B-1	03/27/89	
2431	Door 108B-2	03/27/89	
2432	Door 95-1	03/27/89	
2433	Door 93-1	03/27/89	
2434	Door 94-2	03/27/89	
2435	Door 94-1	03/27/89	
2436	Door 15-1	03/27/89	
2437	Door 27-1	03/27/89	
2438	Door 58-2	03/27/89	
2439	Door 58-1	03/27/89	
2440	Door 58-1	03/27/89	
2443	Door 96-1	03/27/89	
2444	Door 62-2	03/27/89	
2445	Door 62-1	03/27/89	
2446	Door 12-1	03/27/89	