

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9104150042 DOC. DATE: 91/04/03 NOTARIZED: YES DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME AUTHOR AFFILIATION  
 BOHLKE, W.H. Florida Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-31 & DPR-41, changing  
 Tech Spec 3/4.2.5, "Power Distribution Limits, DNB  
 Parameters" to provide addl operational margin to limits  
 associated w/RCS flow & RCS average temp.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4 + 16  
 TITLE: OR Submittal: General Distribution

### NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD2-2 LA		1	1		PD2-2 PD		1	1
	AULUCK, R		2	2					
INTERNAL:	NRR/DET/ECMB 9H		1	1		NRR/DET/ESGB		1	1
	NRR/DOEA/OTSB11		1	1		NRR/DST 8E2		1	1
	NRR/DST/SELB 8D		1	1		NRR/DST/SICB 7E		1	1
	NRR/DST/SRXB 8E		1	1		NUDOCS-ABSTRACT		1	1
	OC/LFMB		1	0		OGC/HDS3		1	0
	REG FILE 01		1	1		RES/DSIR/EIB		1	1
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16

AA2/W





APR 03 1991

L-91-86

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Proposed License Amendment  
DNB Parameters, Limiting Condition for Operation

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) requests that Appendix A of Facility Operating Licenses DPR-31 and DPR-41 be amended to modify the Turkey Point Units 3 and 4 Technical Specification 3/4.2.5, Power Distribution Limits, DNB Parameters, Limiting Condition for Operation and the Bases Section 3/4.2.5, Power Distribution Limits, DNB Parameters.

The proposed amendment provides additional operational margin associated with the DNB parameters by changing the indicated values of the operating parameters as follows:

1. Reactor Coolant System (RCS) Flow from  $\geq 277,900$  gpm to  $\geq 275,000$  gpm,
2. RCS average temperature from  $\leq 576.6$  °F to  $\leq 577.5$  °F,
3. Pressurizer pressure from  $\geq 2209$  psig to  $\geq 2205$  psig.

The proposed amendment also revises the Bases Section 3/4.2.5, Power Distribution Limits, DNB Parameters, to reflect the changes listed above.

Additional operational margin to the limits associated with the measurement and indication of RCS flow, RCS average temperature, and pressurizer pressure may be provided by the improvement of procedures, replacement of instrumentation, and recalculation of the limits with the use of the NRC approved Westinghouse Setpoint Methodology.

FPL has determined that the proposed amendment does not involve a significant hazard pursuant to 10 CFR 50.92. The proposed revised Technical Specification change is shown in Attachment 1. A description of the amendment request and the supporting safety analysis which forms the basis for a no significant hazards determination is provided in Attachment 2. Attachment 3 provides the no significant hazards determination in support of the proposed amendment.

9104150042 910403  
PDR ADOCK 05000250  
P PDR

A201  
11/11

SECRET


10/27

In accordance with 10 CFR 50.91(b) (1), a copy of this proposed license amendment is being forwarded to the State Designee for the State of Florida.

The proposed amendment has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the FPL Company Nuclear Review Board.

Should there be any questions on this request, please contact us.

Very truly yours,

  
\_\_\_\_\_  
W. H. Bohlke  
Vice President  
Nuclear Engineering and Licensing

WHB/OIH

Attachments

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant  
Mr. Jacob Daniel Nash, Florida Department of Health and  
Rehabilitative Services

STATE OF FLORIDA       )  
                              ) ss.  
COUNTY OF DADE       )

W. H. Bohlke being first duly sworn, deposes and says:

That he is Vice President, Nuclear Engineering and Licensing,  
of Florida Power and Light Company, the Licensee herein;


That he has executed the foregoing document; that the statements  
made in this document are true and correct to the best of his  
knowledge, information and belief, and that he is authorized to  
execute the document on behalf of said Licensee.



W. H. Bohlke

Subscribed and sworn to before me this

3rd day of April, 1991.



NOTARY PUBLIC, in and for the County of  
Dade, State of Florida

My Commission expires \_\_\_\_\_

Notary Public, State of Florida  
My Commission Expires Jan. 16, 1993  
Bonded Thru Troy Fain - Insurance Inc.

RECEIVED  
FEB 10 1966  
U.S. AIR FORCE  
HONOLULU, HAWAII

Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
DNB Parameters, Limiting Condition for Operation

**ATTACHMENT 1**



