

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9104180027 DOC. DATE: 91/04/08 NOTARIZED: NO DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME PLUNKETT, T.F. AUTHORITY AFFILIATION Florida Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION Document Control Branch (Document Control Desk)

SUBJECT: Responds to Generic Ltr 89-10, "Safety-Related Motor Operated Valve Testing & Surveillance." Valve program description & schedule developed by util & available for NRC review since 910101.

DISTRIBUTION CODE: A064D COPIES RECEIVED: LTR / ENCL 0 SIZE: /  
 TITLE: Response to Generic Ltr 89-10, "Safety-Related MOV Testing & Surveillance"

### NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD2-2 LA		1	0		PD2-2 PD		1	1
	AULUCK, R		1	1					
INTERNAL:	BAER, B RES		1	1		NRR/DET/EMEB 7E		1	1
	NRR/LPEB/BC		1	1		<u>REG FILE</u>		1	1
	RES/DSIR/EIB/B		1	1					
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 0

MA 4/11





FPL

P.O. Box 029100, Miami, FL, 33102-9100

APR 08 1991  
I-91-91

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Safety-Related Motor-Operated Valve  
Testing and Surveillance - Generic Letter 89-10

On June 28, 1989, the NRC issued Generic Letter (GL) 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillance," recommending that licensees establish a program to provide for the testing, inspection, and maintenance of safety-related motor-operated valves (MOV) and certain other MOVs in safety-related systems. The GL requested that a description of the MOV program and schedule be available on site for NRC review by June 28, 1990, or the first refueling outage after December 28, 1989, whichever was later.

Supplement 2 to Generic Letter 89-10: "Availability of Program Descriptions," issued by the NRC on August 3, 1990, provided an extension to the original due date specified in the GL by which licensees were required to have a description and schedule of the MOV program. Because of the amount of effort required to be expended on MOVs, the NRC decided to delay onsite inspections of the MOV program for 6 months, therefore, licensees were not required to have the MOV program available for NRC review until at least January 1, 1991.

Florida Power and Light has developed the Turkey Point Units 3 and 4 MOV program description and schedule addressing items a. through h. of GL 89-10, as specified in the GL. The Turkey Point Units 3 and 4 MOV program description has been available for NRC review since January 1, 1991, in accordance with the GL 89-10, Supplement 2 requirements. The above information is being provided as requested by Mr. Rajender Auluck, Turkey Point Project Manager.

Should there be any questions please contact us.

Very truly yours,

*T.F. Plunkett by G.W. Pearce*

T. F. Plunkett  
Vice President  
Turkey Point Plant Nuclear

TFP/OIH

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

9104180027 910408  
PDR ADOCK 05000250  
PDR

an FPL Group company

150130

1/0  
A064

102 10 1947