

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)


ACCESSION NBR: 8404120055 DOC. DATE: 84/04/04 NOTARIZED: YES DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 WILLIAMS, J.W. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 EISENHUT, D.G. Division of Licensing

SUBJECT: Application to amend Licenses DPR-31 & DPR-41 modifying
 Tech Specs re U-235 linear loading & deleting reactor core
 U-235 enrichment spec to accomodate higher enrichments for
 possible use in future cycles.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3 + 32
 TITLE: OR Submittal: General Distribution

NOTES:

RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL	
NRR ORB1 BC	01	7	7				
INTERNAL: ELD/HDS4		1	0	NRR/DE/MTEB		1	1
NRR/DL DIR		1	1	NRR/DL/ORAB		1	0
NRR/DSI/METB		1	1	NRR/DSI/RAB		1	1
REG FILE	04	1	1	RGN2		1	1
EXTERNAL: ACRS	09	6	6	LPDR	03	1	1
NRC PDR	02	1	1	NSIC	05	1	1
NTIS		1	1				



April 4, 1984
L-84-92

Office of Nuclear Reactor Regulation
Attention: Darrell G. Eisenhut
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Turkey Point Units 3 & 4
Docket Nos. 50-250 and 50-251
Proposed Amendment to
Facility Operating License DPR-31 and 41
Fuel Storage U-235 Linear Loading Increase

Dear Mr. Eisenhut:

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) submits herewith three signed originals and forty copies of a request to amend Facility Operating Licenses DPR-31 and 41.

FPL proposes to modify the existing Turkey Point Units 3 and 4 U-235 linear loading and delete the reactor core U-235 enrichment specification to accommodate storage of higher enrichments for possible use in future fuel cycles.

The proposed modification will involve Technical Specification changes as described below and as shown on the accompanying Technical Specification pages. (Attachment I).

Technical Specification Page 5.2.1


The reactor core description specification is modified to reflect the deletion of the enrichment restriction.

Technical Specification Page 5.4.1

The fuel storage specification is modified to reflect the proposed increase in fuel storage U-235 linear loading and increase the limiting reactivity in the new fuel storage area.

The proposed facility modification has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the FPL Company Nuclear Review Board. FPL has concluded that operation of the Turkey Point Plants under the proposed license amendments would not:

- I. Involve a significant increase in the probability or consequences of an accident previously evaluated; or



A001
11

Page 2
Office of Nuclear Reactor Regulation
Mr. Darrell G. Eisenhut
Division of Licensing

2. Create the possibility of a new or different kind of accident from any accident previously evaluated; or
3. Involve a significant reduction in a margin of safety.


Attachment 2 provides an evaluation of the proposed action in light of three standards contained in 10 CFR 50.92 (listed above, regarding the issue of no significant hazards consideration.

In summary, FPL submits that the activities associated with the proposed amendments do not constitute a significant hazard to the public health and safety or to the environment and, therefore, that these amendments do not involve a significant hazards consideration. FPL respectfully requests therefore, that this application be processed pursuant to 10 CFR 50.91 and 50.92, as involving no significant hazards consideration.

Approval of these technical specification changes is desired by August 1, 1984 in order to meet our enrichment notification schedules to allow use of enrichments greater than 3.5 w/o in Turkey Point Unit 4, Cycle 11.

In accordance with 10 CFR 170.22, this proposed license amendment has been determined to represent a Class I and III amendment. Accordingly, a check for \$4,400.00 will be forwarded under separate cover.

Very truly yours,



J. W. Williams, Jr.
Vice President
Nuclear Energy

JWW/ERK/cab

cc: Mr. J. P. O. Reilly
Mr. Harold Reis, Esquire

Lyle E. Jerrett, Administrator
Radiological Health & Rehabilitative Services
1323 Winewood Boulevard
Tallahassee, Florida 32301

Attachments


1. Proposed Technical Specification (pages 5.2-1, 5.4-1)
2. No Significant Hazards Consideration
3. Safety Analysis Report

STATE OF FLORIDA)
)
COUNTY OF DADE) ss.

J. W. Williams, Jr., being first duly sworn, deposes and says:

That he is a Vice President of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.



J. W. Williams, Jr.

Subscribed and sworn to before me this

4 day of APRIL, 1984.



NOTARY PUBLIC, in and for the County
of Dade, State of Florida.

My commission expires: 2-14-1988

NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXP. FEB 14, 1988
BONDED THRU GENERAL INS. UND.

