

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8502200344 DOC. DATE: 85/02/08 NOTARIZED: YES DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME: AUTHOR AFFILIATION
 WILLIAMS, J. W. Florida Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 EISENHUT, D. G. Division of Licensing

SUBJECT: Application for amend to Licenses DPR-31 & DPR-41, combining
 reactor mats surveillance programs at both units into
 single integrated program. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 3 ENCL 39 SIZE: 2+16
 TITLE: OR Submittal: General Distribution

NOTES:

OL: 07/19/72


05000250

OL: 04/14/73

05000251

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR ORB1 BC	01	7	7			
INTERNAL:	ACRS	09	6	6	ADM/LFMB		1 0
	ELD/HDS4		1	0	NRR/DE/MTEB		1 1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1 0
	NRR/DL/TSRG		1	1	NRR/DSI/METB		1 1
	NRR/DSI/RAB		1	1	<u>REG FILE</u>	04	1 1
	RGN2		1	1			
EXTERNAL:	LPDR	03	1	1	NRC PDR	02	1 1
	NSIC	05	1	1			

Rec'd w/check \$150.00 #6332



February 8, 1985
L-85-66

Office of Nuclear Reactor Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Proposed License Amendment
Reactor Plant Surveillance Material Program

In accordance with 10 CFR 50.90, Florida Power & Light Company submits herewith three signed originals and forty copies of a request to amend Appendix A of Facility Operating Licenses DPR-31 and 41.

This amendment is proposed to combine the reactor materials surveillance program at Unit 3 and 4 into a single integrated program which conforms to the requirements of 10 CFR 50 Appendices G and H.

The proposed amendment is described below and shown on the accompanying Technical Specification pages.

Table 4.2-1 and Page 4.20-1

The Irradiation Specimen Schedule (item 7-2) on Table 4.2-1, is deleted and a revised version to reflect the proposed integrated program is added to Page 4.20-1.

Pages B 3.1-3, B 4.2-12, B 4.2-13, B 4.20-1 and delete B 4.2-14

The bases associated with the above changes are revised.

The proposed amendment has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the Florida Power & Light Company Nuclear Review Board.

FPL requests issuance of this proposed amendment before the beginning of the Spring 1985 Unit 3 refueling outage (currently scheduled to begin 3-30-85) in order to allow proper implementation of the single integrated program.

In accordance with 10 CFR 50.91(b)(I), a copy of the proposed amendment is being forwarded to the State Designee for the State of Florida.

8502200344 850208
PDR ADDCK 05000250
P PDR

Rec'd w/ check \$150.00
#6332

Acc'l
3/39


Director

Page 2

In accordance with 10 CFR 170.12(c), a check for \$150 is attached.

Also attached is an evaluation of the proposed action in light of the three standards contained in 10 CFR 50.92 (No Significant Hazards).

Very truly yours,


J. W. Williams, Jr.
Group Vice President
Nuclear Energy

JWW/SAV/js

Attachment

cc: J. Nelson Grace, Region II
Harold F. Reis, Esquire
Lyle Jerrett, Ph.D., Director
Office of Radiation Control
Dept. of Health & Rehabilitative Services
1323 Winewood Boulevard
Tallahassee, FL 32301
PNS-LI-85-058-1