

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8502220018 DOC. DATE: 85/02/15 NOTARIZED: YES DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME: AUTHOR AFFILIATION
 WILLIAMS, J.W. Florida Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 THOMPSON, H.L. Division of Licensing

SUBJECT: Application for amend to Licenses DPR-31 & DPR-41, changing
 Tech Specs to substitute linear rampdown of allowable
 moderator temp. coefficient in place of current step change
 at 70% power. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 3 ENCL 40 SIZE: 3+7
 TITLE: OR Submittal: General Distribution

NOTES:

OL: 07/19/72


05000250

OL: 04/14/73

05000251

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
NRR ORB1 BC 01	7 7		
INTERNAL: ACRS 09	6 6	ADM/LFMB	1 0
ELD/HDS4	1 0	NRR/DE/MTEB	1 1
NRR/DL DIR	1 1	NRR/DL/ORAB	1 0
NRR/DL/TSRG	1 1	NRR/DSI/METB	1 1
NRR/DSI/RAB	1 1	<u>REG FILE</u> 04	1 1
RGN2	1 1		
EXTERNAL: LPDR 03	1 1	NRC PDR 02	1 1
NSIC 05	1 1		

*w/check #150
 #6331*



FEB 15 1985

L-85-70

Office of Nuclear Reactor Regulation
Attention: Mr. Hugh L. Thompson, Jr., Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Proposed License Amendment
Moderator Temperature Coefficient

In accordance with 10 CFR 50.90, Florida Power & Light Company submits herewith three signed originals and forty copies of a request to amend Appendix A of Facility Operating Licenses DPR 31 and 41.

The purpose of this change is to substitute a linear rampdown of the allowable Moderator Temperature Coefficient (MTC) from $+5 \times 10^{-5} \Delta k/k/^{\circ}F$ to zero between 70 percent and 100 percent rated power in place of the current step change at 70 percent power.

The proposed amendment is described below and shown on the accompanying Technical Specification pages.

Page 3.1-2a

The MTC requirement is revised as discussed above.

Page B 3.1-3

The bases for the MTC requirements are revised.

This proposed amendment references the plant power conditions in modes. In our January 20, 1985 letter (L-85-52) from J. W. Williams to D. G. Eisenhut, we proposed an amendment which defines those modes, therefore, that amendment should be issued prior to the one requested here.

The safety evaluation and No Significant Hazards considerations are attached in support of this amendment request.

8502220018 850215
PDR ADDCK 05000250
PDR


A001
3/40
w/checkbox \$150
#6331

In accordance with 10 CFR 50.91(b)(1), a copy of this proposed license amendment is being forwarded to the State Designee for the State of Florida.

In accordance with 10 CFR 170.12(c), a check for \$150 is attached.

The proposed amendment has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the Florida Power and Light Company Nuclear Review Board.

Very truly yours,

for 
J. W. Williams, Jr.
Group Vice President
Nuclear Energy

JWW/SAV/js

cc: Dr. J. Nelson Grace, Region II, USNRC
Harold F. Reis, Esquire
PNS-LI-84-360-2


Lyle Jerrett, Ph.D., Director
Office of Radiation Control
Dept. Health and Rehabilitative Services
1323 Winewood Boulevard
Tallahassee, FL 32301

STATE OF FLORIDA)
)
COUNTY OF DADE) ss.

C. O. Woody, being first duly sworn, deposes and says:

That he is Vice President Nuclear Operations of Florida Power & Light Company,
the licensee herein;

That he has executed the foregoing document; that the statements made in this
document are true and correct to the best of his knowledge, information, and
belief, and that he is authorized to execute the document on behalf of said
Licensee.


C. O. Woody

Subscribed and sworn to before me this

15 day of FEBRUARY, 1985.



NOTARY PUBLIC, in and for the County of
Dade, State of Florida.

NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXP. FEB 14, 1988
BONDED THRU GENERAL INS. UND.

My commission expires: 2/14/88

