

ACTION:

With one or more of the isolation valve(s) specified above inoperable, maintain at least one isolation valve OPERABLE in each affected penetration that is open and:

- a) Restore the inoperable valve(s) to OPERABLE status within 4 hours, or
- b) Isolate each affected penetration within 4 hours by use of at least one deactivated automatic containment isolation valve secured in the isolation position, or
- c) Isolate each affected penetration within 4 hours by use of at least one closed manual containment isolation valve or blind flange, or
- d) Be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

3.3.4 CONTAINMENT AIR LOCKS

Each containment air lock shall be OPERABLE with:

- a) Both doors closed except 1) when the air lock is being used for normal transit entry and exit through the containment or 2) during the performance of containment air lock surveillance and/or testing requirements, then at least one air lock door shall be closed, and
- b) An overall air lock leakage rate in compliance with Specifications 4.4.1 and/or 4.4.2 as applicable.

APPLICABILITY: MODES 1, 2, 3, and 4

ACTION:

- a) With one containment air lock door inoperable:
  - 1) Maintain at least the OPERABLE air lock door closed and either restore the inoperable air lock door to OPERABLE status within 24 hours or lock the OPERABLE air lock door closed;
  - 2) Operation may then continue until performance of the next required overall air lock leakage test provided that the operable air lock door is verified to be locked closed at least once per 31 days;
  - 3) Otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours; and
  - 4) The provisions of Specification 3.0.4 are not applicable.
- b) With the containment air lock inoperable, except as the result of an inoperable air lock door, maintain at least one air lock door closed; restore the inoperable air lock to OPERABLE status within 24 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

8506170124 850611  
PDR ADDCK 05000250  
PDR

