

---

# **Safety Criteria and Methodology for Acceptable Cycle Reload Analyses**

BAW-10179NP-A  
Revision 9

## **Topical Report**

November 2017

AREVA Inc.

---

(c) 2017 AREVA Inc.

**Copyright © 2017**

**AREVA Inc.  
All Rights Reserved**



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

November 21, 2017

Mr. Gary Peters, Director  
Licensing and Regulatory Affairs  
AREVA Inc.  
3315 Old Forest Road  
Lynchburg, VA 24501

SUBJECT: REVISED FINAL SAFETY EVALUATION FOR AREVA INC. TOPICAL REPORT  
BAW-10179P, REVISION 9, "SAFETY CRITERIA AND METHODOLOGY FOR  
ACCEPTABLE CYCLE RELOAD ANALYSES" (CAC NO. MF8167)

Dear Mr. Peters:

By letter dated April 15, 2016 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16106A285), AREVA Inc. (AREVA) submitted Topical Report (TR) BAW-10179P, Revision 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses," to the U.S. Nuclear Regulatory Commission (NRC) staff for review and approval. By letter dated September 11, 2017 (ADAMS Accession No. ML17199Q901), an NRC draft safety evaluation (SE) regarding our approval of TR BAW-10179P, Revision 9, was provided for your review and comment. By letter dated October 5, 2017 (ADAMS Accession No. ML17283A111), AREVA provided comments on the draft SE. The NRC staff's disposition of the AREVA comments on the draft SE are discussed in the attachment (ADAMS Accession No. ML17279A960) to the revised final SE enclosed with this letter.

By letter dated November 2, 2017 (ADAMS Accession No. ML17279A980), the original final SE was issued informing AREVA that the NRC staff has found that TR BAW-10179P, Revision 9, is acceptable for referencing in licensing applications for nuclear power plants to the extent specified and under the limitations delineated in the TR and in the final SE, which defines the basis for NRC acceptance of the TR. Upon receipt of the original final SE, AREVA identified that the draft SE for another TR was referenced when the final SE for that TR is available. The NRC staff has corrected the reference. The revised final SE enclosed with this letter supersedes the original final SE issued on November 2, 2017.

Our acceptance applies only to material provided in the subject TR. We do not intend to repeat our review of the acceptable material described in the TR. When the TR appears as a reference in licensing action requests, our review will ensure that the material presented applies to the specific plant involved. Requests for licensing actions that deviate from this TR will be subject to a plant-specific review in accordance with applicable review standards.


In accordance with the guidance provided on the NRC website, we request that AREVA publish approved versions of TR BAW-10179P, Revision 9, within 3 months of receipt of this letter. The approved versions shall incorporate this letter and the enclosed final SE after the title page. Also, they must contain historical review information, including NRC requests for additional information and your responses. The approved versions shall include an "-A" (designating approved) following the TR identification symbol.

As an alternative to including the RAIs and RAI responses behind the title page, if changes to the TR were provided to the NRC staff to support the resolution of RAI responses, and if the NRC staff reviewed and approved those changes as described in the RAI responses, there are two ways that the accepted version can capture the RAIs:

1. The RAIs and RAI responses can be included as an Appendix to the accepted version.
2. The RAIs and RAI responses can be captured in the form of a table (inserted after the final SE) which summarizes the changes as shown in the approved version of the TR. The table should reference the specific RAIs and RAI responses which resulted in any changes, as shown in the accepted version of the TR.

If future changes to the NRC's regulatory requirements affect the acceptability of this TR, AREVA will be expected to revise the TR appropriately or justify its continued applicability for subsequent referencing. Licensees referencing this TR would be expected to justify its continued applicability or evaluate their plant using the revised TR.

Sincerely,



Dennis C. Morey, Chief  
Licensing Processes Branch  
Division of Licensing Projects  
Office of Nuclear Reactor Regulation

Project No. 728

Enclosure:  
Final Safety Evaluation (Proprietary)

FINAL SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION RELATED

TO AREVA TOPICAL REPORT BAW-10179P, REVISION 9

"SAFETY CRITERIA AND METHODOLOGY FOR ACCEPTABLE CYCLE RELOAD ANALYSES"

PROJECT NO. 728

CAC NO. MF8167

## **1.0 INTRODUCTION**

AREVA Inc. (AREVA) submitted Topical Report (TR) BAW-10179P, Revision 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses," to the U.S. Nuclear Regulatory Commission (NRC) for staff review and approval by letter dated April 15, 2016 (Reference 1). This TR revision provides an update to the methodology that is used to determine plant-specific and cycle-specific parameter operating limits in accordance with NRC Generic Letter (GL) 1988-16, "Removal of Cycle-Specific Parameter Limits from Technical Specifications," specifically for Babcock and Wilcox (B&W) designed 177-Fuel Assembly (FA) nuclear power plants (Reference 2)<sup>1</sup>. In its review, the NRC staff issued a request for additional information (RAI) letter, to which AREVA responded by letter dated March 23, 2017 (Reference 3).

This revision to the TR is a complete, stand-alone revision, similar to the effort undertaken in Revision 7 (Reference 4). Other revisions, including Revision 8, served to append additional material to the TR (Reference 5). In Reference 1, the additional material is incorporated directly into the body of the TR and no appendices exist.

The specific changes made are summarized succinctly on Pages i – ii of the TR. Primarily, the changes are limited to updates that bring the TR more in line with current AREVA editorial style guidance and to correct or update cross-references and inadvertent omissions and inaccuracies. The most substantial change, however, updates the discussion relating to loss-of-coolant accident (LOCA) analysis methods, to incorporate BAW-10192P-A, Revision 0, Supplement 1P, Revision 0 (Reference 6). This report supplement was developed to provide a means to account for the degradation of thermal conductivity in nuclear fuel that occurs as a function of burnup. This phenomenon is not modeled accurately in the TACO3 and GDTACO fuel performance codes, which provide fuel stored energy data used to initialize the emergency core cooling system performance evaluation. The NRC staff issued a final safety evaluation (SE) determining that BAW-10192P-A, Revision 0, Supplement 1P, Revision 0, was approved for use by the NRC by letter to AREVA dated November 2, 2017 (Reference 7).

---

<sup>1</sup> The TR and the SEs approving prior revisions note that the scope of BAW-10179 has been expanded beyond that originally envisioned in GL 1988-16. However, the principal purpose of the document remains to describe the methods used to generate cycle-specific parameters that have some relevance to plant safety, and thus, some level of regulatory significance that warrants control under the plant Technical Specifications. The present revision does not propose to expand the scope of the document any further.

Enclosure

## **2.0 REGULATORY BASIS AND REVIEW APPROACH**

Generally, Reference 1 is a compendium of NRC-approved methods that are used to determine the plant-specific and cycle-specific parameter operating limits (i.e., reload licensing) for B&W-designed 177-FA nuclear power plants. As such, the TR is largely administrative in nature. Meanwhile, the technical details of each analytic method used in reload licensing are contained in the supporting TRs referenced therein. In addition, the NRC staff positions, including the technical and regulatory bases for determining each referenced TR is acceptable, are contained in the NRC staff SEs approving each of the respective TRs. This consideration reduces the NRC staff review scope of Reference 1 so that the review establishes that all proposed edits reflect mere clarifications, or are otherwise supported by an NRC staff-approved or accepted document.

## **3.0 TECHNICAL EVALUATION**

This evaluation is structured consistently with the content on Pages i – ii of the TR (hereafter, the Change List). The NRC staff review also included an effort to verify, using Revisions 7 and 8 of BAW-10179, that all changes were described in the change listing (References 4 and 5). The NRC staff did not identify any additional changes other than those listed. The NRC staff review identified a general issue, which formed the basis for RAI 1.

In its review, the NRC staff observed that Step 2 of the process delineated on Page 1-5 of Reference 1 appears not to reflect the practice used most recently between the NRC and AREVA in two noteworthy respects. First, the NRC has provided separate SEs approving BAW-10179 revisions and new methodology TRs. In addition, Reference 4 incorporated all material that had previously been included in appendices. Reference 1, presently under review, also incorporates appendices to the main body of the TR. The NRC staff issued RAI 1 to address this issue. In response, AREVA provided revised wording, and committed to include this revised wording in the approved copy of BAW-10179 (Reference 3). The NRC staff reviewed the revised wording and determined that it addresses the issues identified in the RAI. As such, the NRC staff concluded that the response to RAI 1 was acceptable.

### **3.1 ABSTRACT AND INTRODUCTION**

AREVA replaced both the Abstract and the Introduction to reflect the purpose and intent of Reference 1. These updates are administrative in nature and reflect the current revision status; as such, the NRC staff determined that they are acceptable. These changes constitute Items 1 and 2 of the Change List.

### **3.2 FUEL ASSEMBLY AND FUEL ROD STRESS ANALYSIS CRITERIA**

AREVA deleted fuel rods from the stress criteria provided in Section 4.1.2.1, stating that these criteria were covered already in Section 4.2 of the report. The NRC staff confirmed that fuel rods are discussed in this separate section of the TR, and in that respect, the proposed changes are acceptable. This change constitutes Item 3.a of the Change List.

Also in Section 4.1.2.1 of the TR, AREVA added guide tube stress criteria for Conditions III and IV events, stating that such criteria had been inadvertently omitted. AREVA noted that these criteria are contained within Section 3.3 of the main body of BAW-10133PA, "Mark C Fuel

Assembly LOCA-Seismic Analyses" (Reference 8). The NRC staff reviewed Section 3.3 of BAW-10133PA and determined that the discussion in BAW-10179P, Revision 9, is consistent with Section 3.3 of BAW-10133PA in that certain exceptions are provided for guide tubes, which are required to maintain a path for control rod insertion. The NRC staff review concluded that this change is acceptable based on the above consideration. This change constitutes Item 3.b of the Change List.

Stress intensity criteria for Zircaloy components were clarified in Section 4.1.2.1. The NRC staff issued RAI 3 because some language pertaining to allowable stress intensity, contained in Section 4.1.2.1, appeared to introduce less restrictive acceptance criteria specifically for stainless steel and Inconel materials. In the response to RAI 3, AREVA clarified that the specific criteria were applied similarly among Zircaloy, M5, stainless steel, and Inconel. AREVA also proposed revised wording to the TR to reflect this clarification. The NRC staff reviewed the revised pages, which AREVA will include in the NRC-approved copy of the TR, and determined that the concern discussed in RAI 3 was resolved. This change constitutes Item 3.c of the Change list.

Item 3.d is the addition of stress intensity criteria for M5 fuel assembly components. AREVA stated that these are the same criteria as those approved in TR BAW-10227(P)(A), "Evaluation of Advanced Cladding and Structural Material (M5) in PWR Reactor Fuel" (Reference 9). The change specifically identifies the same criteria as being applicable to both Zircaloy and M5. The NRC staff reviewed BAW-10227(P)(A) and determined that while M5 has different correlations to determine minimum yield stress and ultimate stress, the criteria were unchanged from those used for Zircaloy. Thus, the NRC staff confirmed, based on its review, that these stress intensity criteria are applicable to M5. Based on this consideration, the NRC staff determined that this proposed change was acceptable.

### 3.3 HOLD-DOWN ANALYSIS CRITERIA

AREVA proposes to modify the hold-down analysis criteria for consistency with the response to RAI 6 associated with the BAW-10179, Revision 0, review (Reference 10). The only change is to broaden a design requirement, formerly applicable to Condition I events, so that it now applies to both Condition I and II events. Specifically, the TR now requires that the hold-down spring system shall be capable of maintaining fuel assembly contact with the lower support plate during Condition I and II events. Condition II events, more commonly considered as anticipated operational occurrences, are more severe than Condition I events, such that this change is more restrictive. The NRC staff understands, however, that in practice AREVA performs hold-down analyses consistent with the RAI 6 for Revision 0 of BAW-10179, such that this change is editorial. Based on these considerations, the NRC staff determined that the modification to the hold-down analysis criteria was acceptable. This constitutes Item 4 on the Change List.

### 3.4 LOSS-OF-COOLANT ACCIDENT ANALYSIS METHOD

AREVA revised the grid strength definition provided in Section 4.1.9.2 of the TR. In its review, the NRC staff observed that the proposed changes appeared to delete an existing requirement, and issued RAI 4 to obtain clarifying information. In its response, AREVA clarified that existing language in prior revisions of BAW-10179 could have been misinterpreted relative to what is defined in the source TR (BAW-10133PA, Revision 1) and that the modified language improves

consistency with existing NRC-approved grid strength definitions (Reference 8). Based on AREVA's confirmation that the intent of the TR is to reference the BAW-10133PA without alteration, the NRC staff determined that the concern expressed in RAI 4 was resolved and that the modified wording is acceptable. This change constitutes Item 5 on the Change List.

### 3.5 FUEL ROD STRESS ANALYSIS CRITERIA

AREVA made further changes to the Fuel Rod Stress Analysis Criteria contained in Section 4.2.5.1. AREVA separated Conditions I & II and Conditions III & IV stress criteria for fuel rod cladding and revised the Conditions III & IV stress criteria, citing Section 4.7 of the SE approving BAW-10227P-A (Reference 9). These changes constitute Items 6.a, and 6.b of the Change List. The NRC staff was unable to determine that these changes are acceptable as set forth in the Change List. RAI 2 was issued to address these changes.

The NRC staff identified an issue, in that some proposed revisions to the Stress Analysis Criteria discussed in Section 4.2.5.1 of the TR appeared inconsistent with the NRC approval of prior methodologies, and with the event classification scheme provided in American National Standards Institute/American Nuclear Society 57.5, "Light Water Reactors Fuel Assembly Mechanical Design and Evaluation," which is referenced in Section 2 of the TR. In the response to RAI 2, AREVA proposed to modify the revised text to provide consistency with previously approved AREVA TRs. AREVA provided references to the specific NRC approvals, and revised pages of Reference 1, which will be included in the NRC-approved version of the TR. The NRC staff reviewed the cited NRC approvals and revised TR pages and determined that the apparent inconsistency identified by the NRC staff had been resolved. Based on this consideration, the NRC staff concluded that the response to RAI 2 was acceptable, as are the proposed changes to Items 6.a and 6.b of the Change List.

### 3.6 FUEL ROD STRAIN ANALYSIS METHOD

AREVA proposed to revise Section 4.2.6.2 of the TR to reflect that TACO3, GDTACO, and COPENIC have different cladding strain definitions (References 11, 12, 13). The NRC staff reviewed the proposed change and determined that it does not alter any computational methods, and merely introduces information already contained in NRC-approved TRs. Therefore, the NRC staff determined that the change is acceptable. This change constitutes Item 7 on the Change List.

### 3.7 FUEL ROD PRESSURE

AREVA revised Section 4.2.8.2 to clarify the different burnup limits that apply when using either TACO3 and GDTACO, or COPENIC. This change introduces the burnup limits applicable for the COPENIC code, which were previously not mentioned in the TR. The NRC staff determined that this revision is appropriate since it clarifies burnup limits appropriate for the COPENIC code, which are different from those established for TACO3 and GDTACO. This constitutes Item 8 on the Change List.

### 3.8 FCT LIMIT ANALYSIS CRITERIA

This section of the TR was revised to distinguish between melt temperatures of uranium oxide (UO<sub>2</sub>) and gadolinia. Previously, the criteria stated simply that maximum fuel temperature must



be less than the melting temperature of  $\text{UO}_2$ . Including the allowance for gadolinia is appropriate, because gadolinia has a different melting temperature than  $\text{UO}_2$ . This constitutes Item 9 on the Change List.

### 3.9 FCT LIMIT ANALYSIS METHOD

The analysis method was revised to incorporate COPENIC-specific burnup limits, and to allow for the calculation of [ ]. Previously, the TR had stated that the [

]. In response to RAI 5, AREVA clarified that the changed language reflects a more modern understanding of fuel cycle behavior, yet remains consistent with the original approval of Reference 10. Based on this clarification, the NRC staff determined that the RAI response was acceptable, as was the proposed change to Section 4.2.9.2 of the TR. This constitutes Item 10 on the Change List.

### 3.10 CORE THERMAL HYDRAULIC DESIGN CRITERIA

AREVA revised the second paragraph of Section 6.1, regarding the hold-down criterion for core thermal hydraulic design. Previously, the hold-down capability of the fuel assembly was characterized using the term "gravity" but is now characterized using the term "weight". In addition, the prior capability requirement related to normal operation, which AREVA has clarified to mean during Condition I and II events. These changes are both editorial. In particular, the change to Condition I and II events has the effect of clarifying that conditions of normal operation *include anticipated operational occurrences*, which is phrasing common for the NRC's general design criteria. The change is also consistent with the response to RAI 6, associated with the review of Reference 10. In that RAI response, AREVA provided similar clarifying information. Based on the clarifying nature of these changes, the NRC staff determined that they were acceptable. This constitutes Item 11 on the Change List.

### 3.11 LOSS-OF-COOLANT ACCIDENT EVALUATION

AREVA revised Chapter 9 of the TR, which describes the LOCA evaluation. Changes to this section were made to incorporate a new supplement to BWNT LOCA (BAW-10192P-A, Revision 0, Supplement 1P, Revision 0). The new supplement describes updated methods that are used to account for nuclear fuel thermal conductivity degradation as a function of fuel burnup. The NRC staff approved the supplement by letter dated November 2, 2017 (Reference 7). Since the supplement is approved for use by the NRC, the NRC staff determined that its inclusion in Reference 1 is acceptable. This constitutes Item 12 on the Change List.

### 3.12 RECONSTITUTED FUEL ASSEMBLIES

During the NRC staff review of Reference 1, AREVA submitted a letter to the NRC staff requesting clarification of the NRC staff interpretation of its approval of BAW-2149A, "Evaluation of Replacement Rods in BWFC [Babcock and Wilcox Fuels Company] Fuel Assemblies" (References 14 and 15). Specifically, AREVA requested that the NRC clarify whether its approval of BAW-2149A applied to fresh fuel assemblies containing stainless steel replacement rods. The NRC issued a letter to AREVA dated February 1, 2017, indicating that the NRC staff approval of BAW-2149 applies to fresh fuel assemblies (Reference 16). The RAI response

letter included changes to Reference 1 to reflect the clarified NRC staff position and incorporate references to the NRC staff letter. Based on the consistency of these revisions with Reference 16, the NRC staff determined that these changes are acceptable.

#### **4.0 CONCLUSION**

Based on the review described above, the NRC staff determined that Reference 1 is acceptable. Revision 9 of BAW-10179P is approved for referencing by the NRC.

#### **5.0 REFERENCES**

1. AREVA Inc., BAW-10179P, Revision 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses," April 15, 2016 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16106A285).
2. NRC Generic Letter 1988-16, "Removal of Cycle-Specific Parameter Limits from Technical Specifications," October 4, 1988 (ADAMS Accession No. ML031200485).
3. AREVA Inc., "Response to Request for Additional Information Regarding BAW-10179P Revision 9, 'Safety Criteria and Methodology for Acceptable Cycle Reload Analyses,'" March 23, 2017 (ADAMS Accession No. ML17088A723).
4. AREVA Inc., BAW-10179P-A, Revision 7, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses," May 13, 2008 (ADAMS Accession No. ML081430520).
5. AREVA Inc., BAW-10179P-A, Revision 8, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses," August 6, 2010 (ADAMS Accession No. ML102210446).
6. AREVA Inc., BAW-10192PA-00, Supplement 1P, Revision 0, "BWNT LOCA: BWNT Loss-of-Coolant Accident Evaluation Model for Once-Through Steam Generator Plants," November 25, 2015 (ADAMS Accession No. ML15337A257).
7. Final Safety Evaluation for Topical Report BAW-10192PA-00, Supplement 1, Revision 0, "BWNT LOCA – BWNT Loss-of-Coolant Accident Evaluation Model for Once-Through Steam Generator Plants," November 2, 2017 (ADAMS Accession No. ML17264B086).
8. Babcock and Wilcox, A McDermott Company, BAW-10133PA, Revision 1, "Mark C Fuel Assembly LOCA-Seismic Analyses," June 1986. Proprietary document is not located in ADAMS.
9. Framatome Cogema Fuels, BAW-10227(P)(A), Revision 1, "Evaluation of Advanced Cladding and Structural Material (M5) in PWR Reactor Fuel," April 19, 2004, (ADAMS Accession No. ML15162B043) ADAMS package does not contain a publicly available copy of the report.
10. Babcock and Wilcox Fuel Company, BAW-10179P-A, Revision 0, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses," August 1993. Proprietary document is not located in ADAMS.

11. Babcock and Wilcox Nuclear Technologies, BAW-10162P-A, "TACO3 – Fuel Pin Thermal Analysis Computer Code," December 13, 1989 (ADAMS Accession No. ML15040A369). Complete document and publicly available version were not found in ADAMS.
12. Babcock and Wilcox Nuclear Technologies, BAW-10184P-A, "GDTACO – Urania Gadolinia Fuel Pin Thermal Analysis Code," February 1995, (ADAMS Accession No. ML15028A446) (Proprietary report; no non-proprietary version available).
13. Framatome ANP, Inc., BAW-10231(P)(A), Revision 1, "COPERNIC Fuel Rod Design Computer Code," September 30, 2004 (ADAMS Accession No. ML042930233).
14. Peters, Gary, AREVA, Inc., letter to U.S. NRC, "Request for NRC Concurrence Regarding the Applicability of Topical Report BAW-2149A 'Evaluation of Replacement Rods in BWFC Fuel Assemblies' to Cores Containing Fresh Fuel Assemblies With Stainless Steel Rods," July 7, 2016 (ADAMS Accession No. ML16193A060).
15. Babcock and Wilcox Owners Group, BAW-2149A, "Evaluation of Replacement Rods in BWFC Fuel Assemblies," October 22, 1993 (ADAMS Accession No. ML16252A435). Publicly available version was not located in ADAMS.
16. Kevin Hsueh, U.S. NRC, letter to Gary Peters, AREVA, Inc., "Request for U. S. Nuclear Regulatory Commission Concurrence Regarding the Applicability of Topical Report BAW-2149A, 'Evaluation of Replacement Rods in BWFC Fuel Assemblies', to Cores Containing Fresh Fuel Assemblies with Stainless Steel Rods," February 1, 2017 (ADAMS Accession No. ML16357A669).

Attachment: Resolution of Comments

Principal Contributor: B. Parks, NRR/DSS/SNPB

Date: November 21, 2017

RESOLUTION OF COMMENTS BY THE OFFICE OF NUCLEAR REACTOR  
REGULATION ON DRAFT SAFETY EVALUATION FOR TOPICAL REPORT  
BAW-10179P, REVISION 9, "SAFETY CRITERIA AND METHODOLOGY FOR  
ACCEPTABLE CYCLE RELOAD ANALYSES"

AREVA, INC.

Project No. 728

This attachment provides the U.S. Nuclear Regulatory Commission (NRC) staff's review and disposition of the comments made by AREVA Inc. on the draft safety evaluation (SE) for Topical Report BAW-10179PA, Revision 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses."

| Page | Line | Proposed Change/Comment   | NRC Resolution of Comments  |
|------|------|---|---|
| 2    | 23   | Should Reference 1 be Reference 4?                                    | The NRC staff agrees that 4 is the correct reference. Change implemented in final SE. |
| 6    | 24   | Supplement 1 should be Supplement 1P.                                 | The NRC staff agrees with the editorial suggestion. Change implemented in final SE.   |
| 6    | 13   | Delete the word "Operating" to be consistent with the document title. | The NRC staff agrees with the editorial suggestion. Change implemented in final SE.   |



April 15, 2016  
NRC:16:008

U.S. Nuclear Regulatory Commission  
Document Control Desk  
11555 Rockville Pike  
Rockville, MD 20852

**Request for Review and Approval of BAW-10179P, Revision 9 "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses"**

Ref. 1: Letter, Gayle Elliott (AREVA Inc.) to Document Control Desk (NRC), "Request for Review and Approval of BAW-10192PA-00, Supplement 1, Revision 0 'BWNT LOCA - BWNT Loss-of-Coolant Accident Evaluation Model for Once-Through Steam Generator Plants'," NRC:15:047, November 25, 2015.

AREVA Inc. (AREVA) requests the NRC's review and approval of the topical report BAW-10179P, Revision 9 "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses" for referencing in licensing actions.

This revision includes updates to text and references to be consistent with current approved methods supporting B&W designed plants and integrates current information into a more easily followed format. This revision also incorporates the method of analysis changes from BAW-10192PA-00, Supplement 1, Revision 0 "BWNT LOCA - BWNT Loss-of-Coolant Accident Evaluation Model for Once-Through Steam Generator Plants," accounting for fuel thermal conductivity degradation (TCD) with burnup, which was submitted for approval in Reference 1.

In support of the Office of Nuclear Reactor Regulation's prioritization efforts, the Topical Report Prioritization Scheme is included as an enclosure with this letter.

AREVA would appreciate the NRC approval of this topical report in parallel with the approval of topical report BAW-10192PA-00, Supplement 1, Revision 0 "BWNT LOCA - BWNT Loss-of-Coolant Accident Evaluation Model for Once-Through Steam Generator Plants," since the use of these reports in licensing actions is closely tied.

AREVA considers some of the material contained in the enclosed document to be proprietary. As required by 10 CFR 2.390(b), an affidavit is enclosed to support the withholding of the information from public disclosure. A proprietary version and a non-proprietary version of the report are enclosed.

There are no commitments within this letter or its enclosures.


**AREVA INC.**

---

3315 Old Forest Road, Lynchburg, VA 24501  
Tel.: 434 832 3000 - [www.areva.com](http://www.areva.com)

If you have any questions related to this information, please contact Mr. Morris E. Byram, Product Licensing Manager, by telephone at (434) 832-4665, or by e-mail at [Morris.Byram@areva.com](mailto:Morris.Byram@areva.com).

Sincerely,

A handwritten signature in black ink that reads "Gary A. Peters". The signature is fluid and cursive, with the first name "Gary" being more prominent than the last name "Peters".

Gary A. Peters, Director  
Licensing & Regulatory Affairs  
AREVA Inc.

cc: J. G. Rowley  
Project 728

Enclosures:

1. Proprietary copy of topical report BAW-10179P, Revision 9 "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses"
2. Non-Proprietary copy of topical report BAW-10179P, Revision 9 "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses"
3. BAW-10179P, Revision 9 Priority Form
4. Notarized Affidavit

Document Components for NRC:16:008

001 AREVA Transmittal Letter NRC 16 008.pdf, 428,860 bytes

002 BAW10179P Rev 9 Proprietary.pdf, 2,379,835 bytes, Proprietary

003 BAW10179NP Rev 9 NonProprietary.pdf, 2,514,861 bytes

004 TR Priority 10179PR9.pdf, 78,523 bytes

005 NRC 16 008 Affidavit.pdf, 237,791 bytes

| TR Prioritization Scheme   |   |  |                         |
|--|---|--|-------------------------|
| Title: BAW-10179P, Rev. 9 "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses" |   |  |                         |
| Expect submitting FY   | TAC   | PM                                       | Today's Date: 4/15/2015 |
| Technical Review Division(s)   |   | Technical Review Branch(s)               |                         |
| Factors  | Select the Criteria That the TR satisfies   | Points can be Assigned for Each Criteria | Assigned Points         |
| <b>TR Classification</b><br>(Select one only)  | Resolve Generic Safety Issue (GSI)  | 6  | 3                       |
|  | Emergent NRC Technical Issue  | 3  |                         |
|  | New technology improves safety  | 2  |                         |
|  | TR Revision reflecting current requirements or analytical methods.  | 2  |                         |
|  | Standard TR   | 1  |                         |
| <b>TR Applicability</b><br>(Select one only)   | Potential industry-wide applications  | 3  | 1                       |
|  | Potentially applicable to entire groups of licensees.   | 2  |                         |
|  | Intended for only partial groups of licensees.  | 1  |                         |
| <b>TR Implementation Certainty</b><br>(Select one only)  | Industry-wide Implementation expected   | 3  | 2                       |
|  | Expected implementation by an entire group of licensees (BWROG, PWROG, BWRVIP, etc.) who sponsored the TR.                      | 2  |                         |
|  | Docketed intent by U.S. plant(s) but no formal LAR schedule yet   | 1  |                         |
|  | No US plants have indicated strong intent on docket to implement yet.   | 0  |                         |
| <b>Tie to a LAR</b><br>(Select if applicable)  | A SE is requested by a certain date (less than two years) to support a licensing activity or renewal date (note it in Comments) | 3  |                         |
| <b>Review Progress</b><br>(Points are cumulative as applicable)                                  | Accepted for review   | 0.3                                      |                         |
|  | RAI issued  | 0.5                                      |                         |
|  | RAI responded   | 1.2                                      |                         |
|  | SE Drafted  | 2.0                                      |                         |
| <b>Management (LT/ET) discretion adjustment</b>  |   | -3 to +3                                 |                         |
| <b>Total Points (Add the total points from each factor and total here):</b>                      |   |  | 6                       |
| <b>Comments: Request Combined SE with BAW-10192P-00, Supplement 1P.</b>                          |   |  |                         |



## AFFIDAVIT

COMMONWEALTH OF VIRGINIA    )  
  ) ss.  
CITY OF LYNCHBURG            )

1. My name is Morris Byram. I am Manager, Product Licensing, for AREVA Inc. (AREVA) and as such I am authorized to execute this Affidavit.

2. I am familiar with the criteria applied by AREVA to determine whether certain AREVA information is proprietary. I am familiar with the policies established by AREVA to ensure the proper application of these criteria.

3. I am familiar with the AREVA information contained in the AREVA document BAW-10179P, Rev. 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses," and referred to herein as "Document." Information contained in this Document has been classified by AREVA as proprietary in accordance with the policies established by AREVA Inc. for the control and protection of proprietary and confidential information.

4. This Document contains information of a proprietary and confidential nature and is of the type customarily held in confidence by AREVA and not made available to the public. Based on my experience, I am aware that other companies regard information of the kind contained in this Document as proprietary and confidential.

5. This Document has been made available to the U.S. Nuclear Regulatory Commission in confidence with the request that the information contained in this Document be withheld from public disclosure. The request for withholding of proprietary information is made in accordance with 10 CFR 2.390. The information for which withholding from disclosure is

requested qualifies under 10 CFR 2.390(a)(4) "Trade secrets and commercial or financial information."

6. The following criteria are customarily applied by AREVA to determine whether information should be classified as proprietary:

- (a) The information reveals details of AREVA's research and development plans and programs or their results.
- (b) Use of the information by a competitor would permit the competitor to significantly reduce its expenditures, in time or resources, to design, produce, or market a similar product or service.
- (c) The information includes test data or analytical techniques concerning a process, methodology, or component, the application of which results in a competitive advantage for AREVA.
- (d) The information reveals certain distinguishing aspects of a process, methodology, or component, the exclusive use of which provides a competitive advantage for AREVA in product optimization or marketability.
- (e) The information is vital to a competitive advantage held by AREVA, would be helpful to competitors to AREVA, and would likely cause substantial harm to the competitive position of AREVA.

The information in this Document is considered proprietary for the reasons set forth in paragraphs 6(c) and 6(d) above.

7. In accordance with AREVA's policies governing the protection and control of information, proprietary information contained in this Document has been made available, on a limited basis, to others outside AREVA only as required and under suitable agreement providing for nondisclosure and limited use of the information.

8. AREVA policy requires that proprietary information be kept in a secured file or area and distributed on a need-to-know basis.


9. The foregoing statements are true and correct to the best of my knowledge,  
information, and belief.

Monica E. Bynard

SUBSCRIBED before me this 15th  
day of April, 2016.

Sherry L. McFaden

Sherry L. McFaden  
NOTARY PUBLIC, COMMONWEALTH OF VIRGINIA  
MY COMMISSION EXPIRES: 10/31/18  
Reg. # 7079129





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

September 2, 2016

Mr. Gary Peters, Director  
Licensing and Regulatory Affairs  
AREVA Inc.  
3315 Old Forest Road  
Lynchburg, VA 24501

SUBJECT: ACCEPTANCE FOR REVIEW OF AREVA INC. TOPICAL REPORT  
BAW-10179P, REVISION 9, "SAFETY CRITERIA AND METHODOLOGY FOR  
ACCEPTABLE CYCLE RELOAD ANALYSES" (CAC NO. MF8167)

Dear Mr. Peters:

By letter dated April 15, 2016 (Agencywide Documents Access and Management System Accession Number ML16106A285), AREVA Inc. (AREVA) submitted for U.S. Nuclear Regulatory Commission (NRC) staff review Topical Report (TR) BAW-10179P, Revision 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses." The NRC staff has performed an acceptance review of TR BAW-10179P, Revision 9. We have found that the material presented is sufficient to begin our comprehensive review. The NRC staff expects to issue its request for additional information by September 30, 2016, and issue its draft safety evaluation (SE) by March 31, 2017. This schedule information takes into consideration the NRC's current review priorities and available technical resources and may be subject to change. If modifications to these dates are deemed necessary, we will provide appropriate updates to this information. The NRC staff estimates that the review will require approximately 200 staff hours including project management and contractor time. The review schedule milestones and estimated review costs were discussed and agreed upon in a telephone conference between AREVA Product Licensing Manager, Jerald Holm, and the NRC staff on August 16, 2016.

Section 170.21 of Title 10 of the *Code of Federal Regulations* requires that TRs are subject to fees based on the full cost of the review. You did not request a fee waiver; therefore, NRC staff hours will be billed accordingly.


As with all topical reports, the SE will be reviewed by the NRC's Office of the General Counsel (OGC) to determine whether it falls within the scope of the Congressional Review Act (CRA). During the course of this review, OGC considers whether any endorsement or acceptance of a TR by the NRC amounts to a rule as defined in the CRA. If this initial review concludes that the SE, with its accompanying TR, may be a rule, the NRC will forward the package to the Office of Management and Budget (OMB) for further review and consideration. Any review by OMB would impact the schedule for the issuance of the final SE.

G. Peters

- 2 -

If you have questions regarding this matter, please contact Jonathan G. Rowley at (301) 415-4053.

Sincerely,

A handwritten signature in black ink, appearing to read "Kevin Hsueh". The signature is fluid and cursive, with the first name "Kevin" and last name "Hsueh" clearly distinguishable.

Kevin Hsueh, Chief  
Licensing Processes Branch  
Division of Policy and Rulemaking  
Office of Nuclear Reactor Regulation

Project No. 728



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

March 7, 2017

Mr. Gary Peters, Director  
Licensing and Regulatory Affairs  
AREVA Inc.  
3315 Old Forest Road  
Lynchburg, VA 24501

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING AREVA INC.  
TOPICAL REPORT BAW-10179P, REVISION 9, "SAFETY CRITERIA AND  
METHODOLOGY FOR ACCEPTABLE CYCLE RELOAD ANALYSES"  
(CAC NO. MF8167)

Dear Mr. Peters:

By letter dated April 15, 2016 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16106A286), AREVA Inc. (AREVA) submitted for U.S. Nuclear Regulatory Commission (NRC) staff review and approval Topical Report BAW-10179P, Revision 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses." Upon review of the information provided, the NRC staff has determined that additional information is needed to complete the review. On January 27, 2017, Jerry Holm, AREVA Product Licensing Manager, and I agreed that the NRC staff will receive the response to the enclosed request for additional information (RAI) questions within 30 days from the date of this letter.

If you have any questions regarding the enclosed RAI questions, please contact me at 301-415-4053.

Sincerely,

A handwritten signature in cursive script, reading "Jonathan Rowley", is positioned above the typed name.

Jonathan G. Rowley, Project Manager  
Licensing Processes Branch  
Division of Policy and Rulemaking  
Office of Nuclear Reactor Regulation

Project No. 728

Enclosure:  
RAI Questions (Non-Proprietary)

REQUEST FOR ADDITIONAL INFORMATION  
RELATED TO TOPICAL REPORT BAW-10179P, REVISION 9  
"SAFETY CRITERIA AND METHODOLOGY FOR ACCEPTABLE CYCLE RELOAD  
ANALYSES"  
AREVA INC.  
PROJECT NO. 728  
CAC NO. MF8167

**RAI-1**

Step 2 of the process delineated on page 1-5 of Topical Report (TR) BAW-10179, Revision 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16106A285) appears not to reflect the practice used most recently between the U.S. Nuclear Regulatory Commission (NRC) and AREVA Inc. (AREVA) in two noteworthy respects. First, the NRC has provided separate safety evaluations (SEs) approving BAW-10179 revisions and new methodology TRs. In addition, Revision 7 incorporated all material that had previously been included in appendices. Revision 9, presently under review, also incorporates appendices into the main body of the TR. Please consider revised wording for Step 2 to incorporate this recent practice.

**RAI-2**

In Section 4.2.5.1 of the TR, additional clarification regarding AREVA's approach to satisfying the American National Standards Institute/American Nuclear Society (ANSI/ANS) 57.5, "Light Water Reactors Fuel Assembly Mechanical Design and Evaluation," event classification scheme is warranted.

First, the NRC staff observed that the methods in the TR take a specific approach to the ANSI/ANS-57.5 event classification scheme that is inconsistent with the final, revised criterion in Section 4.2.5.1. Specifically, page 2-2 of the TR states, "AREVA assures compliance with the NRC regulations by requiring the limiting Condition III transient to meet the acceptance criteria for Condition II events." However, the criteria for stress levels [

] in Section 4.2.5.1 of the TR.

Furthermore, the discussion in Section 4.7, "Fuel Rod Mechanical Fracturing," of the SE approving BAW-10227P-A, "Evaluation of Advanced Cladding and Structural Material (M5®) in PWR Reactor Fuel" (ADAMS Accession No. ML15162B043), appears to relate more to design criteria applicable specifically to Condition IV events, discussing the process used to evaluate postulated accidents. Note that, in Figure 2-1 of the TR, the majority of overlap between the NRC's accident classification occurs with the ANSI/ANS-57.5 Condition IV event. Also, the unrevised criterion, in discussing solely a faulted condition, appears more consistent with the discussion in Section 4.7 of the BAW-10227 SE, which discusses accident conditions. This is reflected also in the Revision 8 and earlier wording in Section 4.1.2.1 of the TR, which stated that the limits for fuel rods applied to Condition IV only.

Enclosure

Finally, the discussion in Section 4.7 of the SE approving BAW-10227P-A refers to Revision 3 of BAW-10179 for acceptance criteria, stating that these are unchanged and previously approved. This reference appears circular, and absent further explanation, does not properly justify the proposed revision to the acceptance criterion.

Therefore, for several reasons, this proposed revision appears inadequately justified and inconsistent with referenced, supporting documentation. Please provide additional information to explain, and consider proposing a revision that rectifies the noted inconsistencies. For example, explain whether fuel rod performance under Condition III event conditions is evaluated by applying limiting conditions associated with the less frequent, but more severe, Condition IV events.

### RAI-3

Regarding the allowable stress intensity, for which a distinction between Zircaloy and M5® and stainless steel and Inconel is proposed to be made, the allowable membrane stress intensity for stainless and Inconel does not indicate that the limit at room temperature must be the least of  $2/3 S_y$  (minimum yield stress) or  $1/3 S_u$  (ultimate stress). Given the difference in wording, and the use of the phrase "whichever is less at room temperature" in the Zircaloy and M5 limits, please provide a justification for applying different, and apparently less restrictive, criteria to stainless and Inconel.

### RAI-4

In Section 4.1.9.2 of the TR, proposed changes appear to remove specificity from, and relax requirements in, the reload licensing document. The prior revisions state that the combined seismic and loss-of-coolant accident (LOCA) loads must be within [

], whereas the proposed revision states that that maximum load must be within the limit defined in BAW-10133P-A, "Mark C Fuel Assembly LOCA - Seismic Analysis," and supplements. In addition, this paragraph (on page 4-9 of the TR) changes a stated requirement so that it now appears as a logical conclusion. Previously, the TR stated, "[

]" The statement is now changed to conclude,

"[ Please clarify which limits, specifically, are referenced in BAW-10133 and supplements, and explain whether the requirement related to [ ]. If so, provide a basis for doing so. ]"

### RAI-5

In Section 4.2.9.2 of the TR, the revised text will shift the reload safety analysis method from one in which the [

]. Please provide a basis for this change.





March 23, 2017

NRC:17:014

U.S. Nuclear Regulatory Commission  
Document Control Desk  
11555 Rockville Pike  
Rockville, MD 20852

**Response to Request for Additional Information Regarding BAW-10179P Revision 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses"**

AREVA Inc. (AREVA) requested the NRC's review and approval of topical report BAW-10179P Revision 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses" in Reference 1. The NRC provided a Request for Additional Information (RAI) in Reference 2. The response to this RAI is enclosed with this letter.


AREVA requested the NRC's concurrence (Reference 3) that topical report BAW-2149A is applicable to cores containing fresh fuel assemblies containing stainless steel rods as well as reconstituted fuel assemblies. The NRC provided a letter (Reference 4) indicating concurrence that the topical report BAW-2149A is applicable to fresh fuel assemblies. In Reference 4 the NRC requested that AREVA provide a revision to BAW-10179PA Revision 8 reflecting the NRC concurrence. The changes to BAW-10179P reflect the NRC concurrence and are included as additional information in the enclosed RAI response.

AREVA considers some of the information contained in the enclosed documents to be proprietary. As required by 10 CFR 2.390(b) an affidavit is enclosed to support the withholding of the information from public disclosure. Proprietary and non-proprietary versions of the RAI responses are enclosed.

There are no commitments within this letter or its enclosures.

If you have any questions related to this information, please contact Ms. Gayle F. Elliott, Product Licensing Manager, by telephone at (434) 832-3347, or by e-mail at [Gayle.Elliott@areva.com](mailto:Gayle.Elliott@areva.com).

Sincerely,



Gary Peters, Director  
Licensing & Regulatory Affairs  
AREVA Inc.

cc: J. G. Rowley  
Project 728

**AREVA INC.**

3315 Old Forest Road, Lynchburg, VA 24501  
Tel.: 434 832 3000 - [www.areva.com](http://www.areva.com)

## References

- Ref. 1: Letter, Gary Peters (AREVA Inc.) to Document Control Desk (NRC), "Request for Review and Approval of BAW-10179P, Revision 9 'Safety Criteria and Methodology for Acceptable Cycle Reload Analyses'," NRC:16:008, April 15, 2016.
- Ref. 2: Letter, Jonathan G. Rowley (NRC) to Gary Peters (AREVA Inc.) "Request for Additional Information Regarding AREVA Inc. Topical Report BAW-10179P, Revision 9, 'Safety Criteria and Methodology for Acceptable Cycle Reload Analyses', (CAC No. MF8167)," February 23, 2017.
- Ref. 3: Letter, Gary Peters (AREVA Inc.) to Document Control Desk (NRC), "Request for NRC Concurrence Regarding the Applicability of Topical Report BAW-2149A 'Evaluation of Replacement Rods in BWFC Fuel Assemblies' to Cores Containing Fresh Fuel Assemblies With Stainless Steel Rods," NRC:16:018, July 7, 2016.
- Ref. 4: Letter, Kevin Hsueh (NRC) to Gary Peters (AREVA Inc.), "Request for U.S. Nuclear Regulatory Commission Concurrence Regarding the Applicability of Topical Report BWR-2149A, 'Evaluation of Replacement Rods in BWFC Fuel Assemblies' to Cores Containing Fresh Fuel Assemblies with Stainless Steel Rods," February 1, 2017.

## Enclosures

1. BAW-10179 Revision 9, Q1P Revision 0, "Response to Request for Additional Information – BAW-10179P Revision 9"
2. BAW-10179 Revision 9, Q1NP Revision 0, "Response to Request for Additional Information – BAW-10179P Revision 9"
3. Notarized Affidavit

## AFFIDAVIT

COMMONWEALTH OF VIRGINIA    )  
  ) ss.  
CITY OF LYNCHBURG            )

1. My name is Tom Ryan. I am Manager, Product Licensing, for AREVA Inc. (AREVA) and as such I am authorized to execute this Affidavit.

2. I am familiar with the criteria applied by AREVA to determine whether certain AREVA information is proprietary. I am familiar with the policies established by AREVA to ensure the proper application of these criteria.

3. I am familiar with the AREVA information contained in the AREVA document "BAW-10179 Revision 9, Q1P Revision 0, "Response to Request for Additional Information – BAW-10179P Revision 9", and referred to herein as "Document." Information contained in this Document has been classified by AREVA as proprietary in accordance with the policies established by AREVA Inc. for the control and protection of proprietary and confidential information.

4. This Document contains information of a proprietary and confidential nature and is of the type customarily held in confidence by AREVA and not made available to the public. Based on my experience, I am aware that other companies regard information of the kind contained in this Document as proprietary and confidential.

5. This Document has been made available to the U.S. Nuclear Regulatory Commission in confidence with the request that the information contained in this Document be withheld from public disclosure. The request for withholding of proprietary information is made in accordance with 10 CFR 2.390. The information for which withholding from disclosure is

requested qualifies under 10 CFR 2.390(a)(4) "Trade secrets and commercial or financial information."

6. The following criteria are customarily applied by AREVA to determine whether information should be classified as proprietary:

- (a) The information reveals details of AREVA's research and development plans and programs or their results.
- (b) Use of the information by a competitor would permit the competitor to significantly reduce its expenditures, in time or resources, to design, produce, or market a similar product or service.
- (c) The information includes test data or analytical techniques concerning a process, methodology, or component, the application of which results in a competitive advantage for AREVA.
- (d) The information reveals certain distinguishing aspects of a process, methodology, or component, the exclusive use of which provides a competitive advantage for AREVA in product optimization or marketability.
- (e) The information is vital to a competitive advantage held by AREVA, would be helpful to competitors to AREVA, and would likely cause substantial harm to the competitive position of AREVA.

The information in this Document is considered proprietary for the reasons set forth in paragraphs 6(a), 6(c) and 6(d) above.

7. In accordance with AREVA's policies governing the protection and control of information, proprietary information contained in this Document has been made available, on a limited basis, to others outside AREVA only as required and under suitable agreement providing for nondisclosure and limited use of the information.

8. AREVA policy requires that proprietary information be kept in a secured file or area and distributed on a need-to-know basis.


9. The foregoing statements are true and correct to the best of my knowledge,  
information, and belief.


Tam Ryan

SUBSCRIBED before me this 21<sup>st</sup>  
day of March, 2017.

Sherry L. McFaden

Sherry L. McFaden  
NOTARY PUBLIC, COMMONWEALTH OF VIRGINIA  
MY COMMISSION EXPIRES: 10/31/18  
Reg. # 7079129





---

# **Response to Request for Additional Information – BAW-10179P Revision 9**

BAW-10179  
Revision 9 Q1NP  
Revision 0

## **Topical Report**

March 2017

AREVA Inc.

---

(c) 2017 AREVA Inc.

**Copyright © 2017**

**AREVA Inc.  
All Rights Reserved**

**Nature of Changes**

| Item | Section(s)<br>or Page(s) | Description and Justification |
|------|--------------------------|-------------------------------|
| 1    | All                      | Initial Issue                 |



**Contents**

|                                       | <u>Page</u> |
|---------------------------------------|-------------|
| 1.0 RAI 1 .....                       | 1           |
| 2.0 RAI 2 .....                       | 2           |
| 3.0 RAI 3 .....                       | 5           |
| 4.0 RAI 4 .....                       | 6           |
| 5.0 RAI 5 .....                       | 8           |
| 6.0 ADDITIONAL INFORMATION .....      | 9           |
| 7.0 REFERENCES .....                  | 10          |
| 8.0 TOPICAL REPORT MARKUP PAGES ..... | 11          |

## Nomenclature

| Acronym | Definition                                  |
|---------|---|
| ASME    | American Society of Mechanical Engineers    |
| LOCA    | Loss of Coolant Accident                    |
| NRC     | United States Nuclear Regulatory Commission |
| OBE     | Operating Basis Earthquake                  |
| RAI     | Request for Additional Information          |
| SSE     | Safe Shutdown Earthquake                    |

## **Introduction**

The United States Nuclear Regulatory Commission (NRC) provided a request for additional information (RAI) regarding the topical report BAW-10179P Revision 9 (Reference 1) in Reference 2. A total of 5 questions were received from the NRC.

The following sections document the response to the five questions.

Section 8.0 provides markup pages for the topical report. The markup includes changes to incorporate NRC concurrence (Reference 5) that the currently approved methodology for analysis of stainless steel replacement rods applies to analysis of fresh fuel assemblies fabricated with stainless steel replacement rods.

**1.0      RAI 1****Question:**

Step 2 of the process delineated on page 1-5 of Topical Report (TR) BAW-10179, Revision 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16106A285) appears not to reflect the practice used most recently between the U.S. Nuclear Regulatory Commission (NRC) and AREVA Inc. (AREVA) in two noteworthy respects. First, the NRC has provided separate safety evaluations (SEs) approving BAW-10179 revisions and new methodology TRs. In addition, Revision 7 incorporated all material that had previously been included in appendices. Revision 9, presently under review, also incorporates appendices into the main body of the TR. Please consider revised wording for Step 2 to incorporate this recent practice.

**Response:**

Revised wording for Step 2 in Section 1.0, page 1-5, is provided in the markup section (Section 8.0) of this document. This revised wording will be incorporated into the approved version of BAW-10179P Revision 9 when it is issued.

## 2.0 RAI 2

### Question:

In Section 4.2.5.1 of the TR, additional clarification regarding AREVA's approach to satisfying the American National Standards Institute/American Nuclear Society (ANSI/ANS) 57.5, "Light Water Reactors Fuel Assembly Mechanical Design and Evaluation," event classification scheme is warranted.

First, the NRC staff observed that the methods in the TR take a specific approach to the ANSI/ANS-57.5 event classification scheme that is inconsistent with the final, revised criterion in Section 4.2.5.1. Specifically, page 2-2 of the TR states, "AREVA assures compliance with the NRC regulations by requiring the limiting Condition III transient to meet the acceptance criteria for Condition II events." However, the criteria for stress levels [ ] in Section 4.2.5.1 of the TR.

Furthermore, the discussion in Section 4.7, "Fuel Rod Mechanical Fracturing," of the SE approving BAW-10227P-A, "Evaluation of Advanced Cladding and Structural Material (M5<sup>®</sup>) in PWR Reactor Fuel" (ADAMS Accession No. ML15162B043), appears to relate more to design criteria applicable specifically to Condition IV events, discussing the process used to evaluate postulated accidents. Note that, in Figure 2-1 of the TR, the majority of overlap between the NRC's accident classification occurs with the ANSI/ANS-57.5 Condition IV event. Also, the unrevised criterion, in discussing solely a faulted condition, appears more consistent with the discussion in Section 4.7 of the BAW-10227 SE, which discusses accident conditions. This is reflected also in the Revision 8 and earlier wording in Section 4.1.2.1 of the TR, which stated that the limits for fuel rods applied to Condition IV only.

Finally, the discussion in Section 4.7 of the SE approving BAW-10227P-A refers to Revision 3 of BAW-10179 for acceptance criteria, stating that these are unchanged and previously approved. This reference appears circular, and absent further explanation, does not properly justify the proposed revision to the acceptance criterion.

Therefore, for several reasons, this proposed revision appears inadequately justified and inconsistent with referenced, supporting documentation. Please provide additional information to explain, and consider proposing a revision that rectifies the noted inconsistencies. For example, explain whether fuel rod performance under Condition III event conditions is evaluated by applying limiting conditions associated with the less frequent, but more severe, Condition IV events.

**Response:**

The text in BAW-10179P, Revision 9 summarizing criteria for fuel rod stresses under faulted conditions is being modified to provide consistency with previous approvals of AREVA Topical Reports.

- For M5<sup>®</sup> material, the Revised Safety Evaluation (SE) for Topical Report BAW-10227PA, (TAC No. M99903, S.A. Richards to T.A. Coleman, dated February 4, 2000) pages xxiv and xxv under fuel rod mechanical fracturing (Section 4.7) states "The design limit proposed by FCF to prevent fracturing is that the stresses due to postulated accidents in combination with the normal steady-state fuel rod stresses should not exceed the yield strength of the components in their fuel assemblies."
- For Zircaloy-4 material, the Technical Evaluation Report for the original submittal of BAW-10179P (Appendix A of NRC Safety Evaluation, TAC No. M80189, A.C. Thadani (NRC) to J.D. McCarthy (B&W Owners Group), dated March 16, 1993), under fuel rod mechanical fracturing (Section 4.7) also states that the stresses due to postulated accidents in combination with the normal steady-state fuel rod stresses should not exceed the yield strength.

However, the analysis criteria shown in BAW-10179P Rev. 07, Section 4.2.5.1 stated fuel rod stresses under faulted conditions are evaluated using the methods outlined in

[

] For consistency

and for conservatism, the limit for faulted fuel rod stresses is limited to the [

] in the updated section 4.2.5.1. For further consistency with previous versions of BAW-10179, the text will be modified to reflect only the change in allowable faulted condition stresses.

A revision to Section 4.2.5.1 (page 4-20) in BAW-10179P Revision 9 is provided in the markup section (Section 8.0) of this document. This revised wording will be incorporated into the approved version of BAW-10179P Revision 9 when it is issued.

**3.0 RAI 3****Question:**

Regarding the allowable stress intensity, for which a distinction between Zircaloy and M5<sup>®</sup> and stainless steel and Inconel is proposed to be made, the allowable membrane stress intensity for stainless and Inconel does not indicate that the limit at room temperature must be the least of  $2/3 S_y$  (minimum yield stress) or  $1/3 S_u$  (ultimate stress). Given the difference in wording, and the use of the phrase "whichever is less at room temperature" in the Zircaloy and M5 limits, please provide a justification for applying different, and apparently less restrictive, criteria to stainless and Inconel.

**Response:**

The text in BAW-10179P Revision 9 summarizing criteria for component stresses is being modified to provide consistency with previous approvals of AREVA Topical Reports. No changes in the NRC approved criteria are being proposed.

$S_m$  is defined directly above the referenced criteria in the question as "the lowest of the following:". However, for consistency and clarification, AREVA will change the wording for stainless steels and Inconel as follows:

"For stainless steel and Inconel components: the least of  $2/3 S_y$  or  $1/3 S_u$  at room temperature, the least of  $1/3 S_u$  or  $0.9 S_y$  at operating temperature."

A revision to Section 4.1.2.1 (page 4-3) in BAW-10179P Revision 9 is provided in the markup section (Section 8.0) of this document. This revised wording will be incorporated into the approved version of BAW-10179P Revision 9 when it is issued.



**4.0 RAI 4****Question:**

In Section 4.1.9.2 of the TR, proposed changes appear to remove specificity from, and relax requirements in, the reload licensing document. The prior revisions state that the combined seismic and loss-of-coolant accident (LOCA) loads must be within [

] whereas the proposed revision states that that maximum load must be within the limit defined in BAW-10133P-A, "Mark C Fuel Assembly LOCA – Seismic Analysis," and supplements. In addition, this paragraph (on page 4-9 of the TR) changes a stated requirement so that it now appears as a logical conclusion. Previously, the TR stated, "[

] " The statement is now changed to conclude, "[

] " Please clarify which limits, specifically, are referenced in BAW-10133 and supplements, and explain whether the requirement related to [

] If so, provide a basis for doing so.

**Response:**

BAW-10179 references BAW-10133PA as the appropriate methodology for evaluating the fuel assembly response to external loads such as seismic and LOCA for fuel in B&W plants. The intent of BAW-10179 is to reference the BAW-10133PA methodology without alteration. The wording in Section 4.1.9.2 that has previously accompanied the reference to BAW-10133PA is intended to be descriptive and was not intended to overwrite any aspect of the methodology in BAW-10133PA.

Specifically, BAW-10179PA Revision 8 Section 4.1.9.2 contains the following wording:

[

] The

use of the words “elastic” and “no permanent grid deformation” in these statements may be misinterpreted relative to what is defined in BAW-10133PA.

Section 3 of the main body of BAW-10133PA provides the definition of grid acceptance criteria for OBE, SSE, and SSE+LOCA conditions. Under OBE conditions, BAW-10133PA defines grid strength as the yield load limit determined from testing. For accident conditions (SSE and LOCA), BAW-10133PA defines “a permanent deformation limit” which has been shown to maintain a control rod path and a coolable core geometry.

The use of the terminology “no permanent deformation” and “elastic” stem from NUREG/CR-1018 which defines “no deformation” as deformation within the manufacturing tolerance of the grid. While the use of these terms is historically consistent, AREVA views that the continued use of these terms can lead to confusion. Thus, the language for BAW-10179P Revision 9 was revised to be consistent with the NRC approved grid strength definitions.

## **5.0 RAI 5**

### **Question:**

In Section 4.2.9.2 of the TR, the revised text will shift the reload safety analysis method from one in which the [

] Please provide a basis for this change.

### **Response:**

[

]

## **6.0 ADDITIONAL INFORMATION**

AREVA Inc. (AREVA) requested NRC concurrence (Reference 4) that topical report BAW-2149A is applicable to cores containing fresh fuel assemblies fabricated with stainless steel rods as well as reconstituted fuel assemblies. The NRC provided a letter (Reference 5) indicating concurrence that topical report BAW-2149A is applicable to fresh fuel assemblies. In Reference 5 the NRC requested that AREVA provide a revision to BAW-10179PA Revision 8 reflecting the NRC concurrence.

In Section 8.0 of this document markup pages for BAW-10179P Revision 9 (Reference 1) are provided reflecting the NRC concurrence. Markup pages are provided for: page ii, page xiv, page 1-3, page 4-16, page 5-28, page 6-30, and page 11-7.

## 7.0 REFERENCES

1. BAW-10179P Revision 9, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses," April 2016.
2. Letter from Jonathan G. Rowley (NRC) to Gary Peters (AREVA Inc.) "Request for Additional Information Regarding AREVA Inc. Topical Report BAW-10179P, Revision 9, 'Safety Criteria and Methodology for Acceptable Cycle Reload Analyses', (CAC No. MF8167)," February 23, 2017.
3. Letter from J. McCarthy (B&W Owners Group) to R. C. Jones (NRC), "B&W Owner's Group, Core Performance Committee: Response to Request for Information for Topical Report BAW-10179P, 'Safety Criteria and Methodology for Acceptable Reload Analyses'," August 25, 1992.
4. Letter to Document Control Desk (NRC) from Gary Peters (AREVA Inc.), "Request for NRC Concurrence Regarding the Applicability of Topical Report BAW-2149A 'Evaluation of Replacement Rods in BWFC Fuel Assemblies' to Cores Containing Fresh Fuel Assemblies With Stainless Steel Rods," NRC:16:018, July 7, 2016.
5. Letter from Kevin Hsueh (NRC) to Gary Peters (AREVA Inc.), "Request for NRC Concurrence Regarding the Applicability of Topical Report BWR-2419A, 'Evaluation of Replacement Rods in BWFC Fuel Assemblies', to Cores Containing Fresh Fuel Assemblies with Stainless Steel Rods," February 1, 2017.

## **8.0 TOPICAL REPORT MARKUP PAGES**

Markup pages to BAW-10179P Revision 9 are provided reflecting the changes discussed in this document. The markups are for:

Question 1 – page 1-5

Question 2 – page 4-20

Question 3 – page 4-3

Additional Information - page ii, page xiv, page 1-3, page 4-16, page 5-28, page 6-30, and page 11-7

| <b>Item</b> | <b>Section(s) or Page(s)</b>  | <b>Description and Justification</b>  |
|-------------|---|---|
| 9           | Section 4.2.9.1<br>Fuel Temperature<br>(Centerline Fuel<br>Melt) Limit Analysis<br>Criteria | Updated to correct and clarify criteria for application to predicted maximum fuel temperature of UO <sub>2</sub> and gadolinia fuel types.  |
| 10          | Section 4.2.9.2<br>Fuel Temperature<br>(Centerline Fuel<br>Melt) Limit Analysis<br>Method   | Updated to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications, and to clarify application of burnup-dependent fuel melt limits in analyses.   |
| 11          | Section 6.1<br>Core Thermal-<br>Hydraulics Design<br>Criteria                               | Revised for consistency with approved response to RAI Question #6 of BAW-10179P Revision 0  |
| 12          | Section 9.0<br>Loss-of-Coolant<br>Accident<br>Evaluation                                    | Revised to address analysis methodology changes for the fuel initialization codes and adjustments to the fuel pin input and steady-state initialization process for the LOCA transient codes to account for burnup-dependent fuel thermal conductivity degradation (TCD) as described in the supplement to BAW-10192P-A Revision 0. |
| 13          | Section 11.0<br>References  | a) Updated Reference 75 to refer to BAW-10164P-A Revision 6, consistent with BAW-10179P-A Revision 8.<br>b) Added Reference 83 to BAW-10179P.<br>c) Added Reference 84 to BAW-10179P  |
| 14          | Throughout  | Updated report format to conform to AREVA's current topical report style guide; updated Company name; and corrected misspelled words and symbols.   |
| 15          | Sections 4.1.13,<br>5.4, 6.8  | Added Reference 84 to text  |

(Section 9.0).

- Update the methodology for fuel assembly stress analysis criteria (Section 4.1.2.1), fuel assembly grid strength definition (Section 4.1.9.2), and fuel rod stress analysis criteria (Section 4.2.5.1) to be consistent with the response to RAI Question 13 issued during the review of BAW-10179P Revision 0.
- Update the fuel assembly hold down analysis criteria (Section 4.1.3.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Update the transient cladding strain analysis description (Section 4.2.6.2) to correct and clarify differences in transient cladding strain definitions used in approved TACO3, GDTACO, and COPENIC applications.
- Update the fuel rod pressure analysis description (Section 4.2.8.2) to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications.
- Update the fuel temperature (centerline fuel melt) limit analysis criteria (Section 4.2.9.1) and analysis method description (Section 4.2.9.2) to correct and clarify application to UO<sub>2</sub> and gadolinia fuel types, and to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications.
- Update the core thermal-hydraulics design criteria (Section 6.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Correct misspelled words and symbols, as appropriate, throughout the report.
- Update the description for analysis of fuel assemblies containing stainless steel rods per Reference 84.



- Update the methodology for fuel assembly stress analysis criteria (Section 4.1.2.1), fuel assembly grid strength definition (Section 4.1.9.2), and fuel rod stress analysis criteria (Section 4.2.5.1) to be consistent with the response to RAI Question 13 issued during the review of BAW-10179P Revision 0.
- Update the fuel assembly hold down analysis criteria (Section 4.1.3.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Update the transient cladding strain analysis description (Section 4.2.6.2) to correct and clarify differences in transient cladding strain definitions used in approved TACO3, GDTACO, and COPENIC applications.
- Update the fuel rod pressure analysis description (Section 4.2.8.2) to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications.
- Update the fuel temperature (centerline fuel melt) limit analysis criteria (Section 4.2.9.1) and analysis method description (Section 4.2.9.2) to correct and clarify application to UO<sub>2</sub> and gadolinia fuel types, and to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications.
- Update the core thermal-hydraulics design criteria (Section 6.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Correct misspelled words and symbols, as appropriate, throughout the report.
- Update the description for analysis of fuel assemblies containing stainless steel rods per Reference 84.

AREVA has developed criteria for determining when a design change must be submitted to the NRC for review and approval. The criteria are:

1. The change meets any of the eight criteria specified in paragraph (c)(2) of 10CFR50.59.
2. A change to the plant technical specifications is required.
3. The applicability of NRC-approved design/analysis evaluation methods is affected.

This report describes the entire spectrum of methodologies that are applicable to the reload fuel currently supplied by AREVA for the B&W 177-FA plants. An overview of the design considerations addressed in these methods is provided in Section 2.0. A brief description of the Mark-B fuel design is provided in Section 3.0. The mechanical design methods are described in Section 4.0. The nuclear design methods are described in Section 5.0, which also includes the radiological evaluation parameters. The thermal-hydraulics methods are described in Section 6.0. Section 7.0 includes the methods for determining reactor protection system (RPS) trip setpoints. Section 8.0 describes the non-LOCA accident evaluation methods, and Section 9.0 presents the LOCA accident evaluation methods. Figure 1-1 provides an overview on how the different analytical disciplines interact to complete a reload evaluation. Section 10.0 provides generic guidelines on the use of limited scope high burnup lead test assemblies.

The methodology described in this report is constantly evolving to include improvements and enhancements to analytical techniques. This will result in a succession of updates to BAW-10179P-A. To facilitate these updates AREVA will implement the following procedure:

1. For revisions to NRC-approved topical reports already referenced in BAW-10179P-A, such revisions will be incorporated by referencing the latest approved revision in the COLR.
2. For new methodology topical reports, AREVA will prepare a corresponding revision to BAW-10179P-A. ~~and include it with the submittal.~~ The revision to BAW-10179P-A will include ~~an appendix that provides~~ a brief summary of the methodology topical and its range of applicability. When the NRC completes its review of the ~~methodology topical, a single SER will be issued which approves both the methodology topical and the revision to BAW-10179P-A. Accepted versions of both topical reports will then be prepared and the latest revision of BAW-10179P-A will be available for referencing in the plant COLR. Any NRC conditions or limitations on the methodology will be included in the accepted version of BAW-10179P-A.~~ revision to BAW-10179 an approved version will be issued.

where

$P_m$  = general primary membrane stress intensity,

$P_l$  = local primary membrane stress intensity,

$P_b$  = primary bending stress intensity,

$Q$  = secondary stress,

$S_m$  = allowable membrane stress intensity which is equal to the lowest of following:

For Zircaloy and M5<sup>®</sup> components:

$S_m = 2/3 S_y$  or  $1/3 S_u$ , whichever is less at room temperature, or

$S_m = 2/3 S_y$  or  $1/3 S_u$  at operating temperature.

(For conservative purposes, the unirradiated material properties are used to define the stress limits. Room temperature values are the minimum specified.)

For stainless steel and Inconel components:

$S_m$  = the least of  $2/3 S_y$  or  $1/3 S_u$  at room temperature,

$S_m$  = the least of  $1/3 S_u$  or  $0.9 S_y$  at operating temperature.

(For conservative purposes, the stainless steel unirradiated material properties are used to define the stress limits. Room temperature values are the minimum specified.)

$S_y$  = minimum yield stress,

$S_u$  = ultimate stress.

#### **4.1.13 Stainless Steel Replacement Rod Methodology**

The in-field repair of irradiated fuel assemblies with leaking rods involves the replacement of defective fuel rods with heat producing and/or non-heat producing rods. BAW-2149-A (reference 23) provides justification for the use of replacement rods without imposing unnecessary power peaking restrictions on the repaired fuel assemblies. This report addresses the nuclear, thermal-hydraulic, and mechanical aspects of the design that are affected by repair operations. The use of replacement rods for AREVA supplied fuel assemblies is determined to be acceptable by the NRC per the SER included in BAW-2149-A.

The NRC concurred in Reference 84 that the topical report BAW-2149A is applicable to the use of stainless steel rods in fresh (i.e. unirradiated) fuel assemblies.

The stainless steel replacement rods weigh slightly less than Zircaloy-clad fuel rods, but the effect on fuel assembly weight of up to 10 replacement rods is negligible. Therefore, the use of stainless steel replacement rods has an insignificant effect on fuel assembly hydraulic lift.

Stainless steel replacement rods are designed and analyzed to ensure that there is no adverse impact on fuel assembly performance. The rods are designed to ensure that adequate performance with respect to differential thermal expansion, irradiation growth, seismic-LOCA response, grid relaxation, and fretting due to vibration will be maintained. The replacement rods can be installed in any fuel rod location in the fuel assembly.

#### **4.2 Fuel Rod Design**

The design of the fuel rod must ensure that the integrity of the cladding is maintained under all Condition I and II events. The integrity of the cladding is maintained by requiring that the fuel rod design meet the constraints discussed below.

Analysis criteria and methods are applicable to both Zircaloy-4 and M5<sup>®</sup> cladding types as noted. The M5<sup>®</sup> cladding is approved for use in AREVA fuel in reference 18.

#### **4.2.5 Stress**

##### **4.2.5.1 Analysis Criteria**

The NRC concurred in Reference 84 that the topical report BAW-2149A is applicable to the use of stainless steel rods in fresh (i.e. unirradiated) fuel assemblies.

#### **5.4.1 Transient Neutronic Parameters**

The safety analysis evaluations performed for the accidents in the SAR assumed values for the neutronic parameters related to the reactivity coefficients and worths, control system reactivity, kinetics, and transient power peaking. When the accidents were analyzed, parametric cases were evaluated to determine the combination of conditions and the key neutronic parameters that would produce the most severe transients. The resulting limiting conditions, and bounding values of the key neutronic parameters, are the ones that must be analyzed for each reload cycle. The methodology used for the reload analysis must consequently ensure that the calculations of the key neutronic parameters are performed with the appropriate limiting conditions. The results are then reviewed using the methods described in Section 8.0 to ensure that the values are bounded by those used in the safety analyses. If the reload calculations contain the proper conditions, and the results are within the bounds of the reference safety analysis, then the SAR results will continue to be applicable to each respective reload cycle.

##### **5.4.1.1 Acceptance Criteria**

1. The key neutronic parameters shall be determined using the appropriate limiting conditions. The key neutronic parameters are then reviewed using the methods described in Section 8.0 to ensure that the values are bounded by those used in the safety analysis.
2. Design changes shall be reviewed with respect to the accident scenarios in the safety analyses to ensure that the change does not affect the scenario for defining the appropriate limiting conditions for calculating the neutronic parameters.

1. The LCO on RCS pressure is established such that during normal plant operation the steady-state core exit pressure will be maintained at a level greater than or equal to the value assumed for DNBR analysis of Condition II transients from full power.
2. The LCO on RCS hot leg temperature is established such that during normal plant operation the steady-state RCS hot leg temperature will not be greater than that corresponding to the initial conditions assumed for DNBR analysis of Condition II transients from full power.
3. The LCO on RCS flow rate is established such that during normal plant operation the steady-state RCS flow rate will not be less than the initial condition value assumed for DNBR analysis of Condition II transients initiated from full power.

Transient core thermal-hydraulic analyses are performed with either a single-pass LYNXT model or the closed-channel RADAR code initialized to a LYNXT initial condition DNBR prediction. For full-power transients, the initial conditions modeled are as described in Table 6-2. Transient inputs to the core thermal-hydraulic calculation typically include RCS flow and pressure, core inlet temperature, and neutron power.

## **6.8      *Stainless Steel Replacement Rod Methodology***


BAW-2149-A (reference 23) defines a methodology for the use of stainless steel replacement rods in AREVA fuel designs. Reference 23 addresses the nuclear, thermal-hydraulic, and mechanical aspects of the fuel design that are affected by the use of stainless steel replacement rods.

The NRC concurred in Reference 84 that the topical report BAW-2149A is applicable to the use of stainless steel rods in fresh (i.e. unirradiated) fuel assemblies.

NRC approval has been obtained for the methodology for the use of as many as ten stainless steel replacement rods within a single fuel assembly. From a DNB perspective, the impact of the stainless steel rods on the peaking of adjacent heat-producing fuel rods is to be explicitly examined on a cycle-by-cycle basis to ensure continued compliance to the  $F_{\Delta H}^N$  design limit.

79. Letter from H. N. Berkow (NRC) to J. F. Mallay (Framatome ANP), Subject: Evaluation of Framatome ANP Preliminary Safety Concern (PSC) 2-00 Relating to Core Flood Line Break and Operator Action Time, April 10, 2003.
80. Letter from R. A. Gramm (NRC) to J. S. Holm (Framatome ANP), Subject: Request for Amendment of Safety Evaluation for "Report of Preliminary Safety Concern (PSC) 2-00 Related to Core Flood Line Break with 2-Minute Operator Action Time, January 10, 2005.
81. BAW-10242-A, "ZPPT Modifications for B&W Designed Reactors," November 2003.
82. BAW-10243P-A, "Statistical Fuel Assembly Hold Down Methodology," September 2005.
83. BAW-10192P-A, Revision 0, Supplement 1P, Revision 0, "BWNT LOCA – BWNT Loss-of-Coolant Accident Evaluation Model for Once-Through Steam Generator Plants," November 2015.
84. Letter from Kevin Hsueh (NRC) to Gary Peters (AREVA Inc.), "Request for U.S. Nuclear Regulatory Commission Concurrence Regarding the Applicability of Topical Report BWR-2149A, 'Evaluation of Replacement Rods in BWFC Fuel Assemblies' to Cores Containing Fresh Fuel Assemblies with Stainless Steel Rods," February 1, 2017.





---

# **Safety Criteria and Methodology for Acceptable Cycle Reload Analyses**

BAW-10179NP  
Revision 9

## **Topical Report**

April 2016

AREVA Inc.

---

(c) 2016 AREVA Inc.

**Nature of Changes**

| <b>Item</b> | <b>Section(s) or Page(s)</b>                                    | <b>Description and Justification</b>   |
|-------------|---|--|
| 1           | Abstract  | Replaced to discuss purpose of BAW-10179P Revision 9.  |
| 2           | Section 1.0<br>Introduction                                     | Replaced to discuss purpose of BAW-10179P Revision 9.  |
| 3           | Section 4.1.2.1<br>Fuel Assembly<br>Stress Analysis<br>Criteria | <p>a) Deleted fuel rods from Section 4.1.2.1, since they are included in Section 4.2.5.1.</p> <p>b) Added guide tube stress criteria for Conditions III &amp; IV; these were inadvertently omitted. They are from approved topical report BAW-10133P-A (Section 3.3 of the main body of the report).</p> <p>c) Clarified the stress intensity criteria for Zircaloy components; the clarification was inadvertently omitted. The clarification was approved in response to RAI Question #13 of BAW-10179P Revision 0.</p> <p>d) Added stress intensity criteria for M5<sup>®</sup> material. These are the same criteria as those approved in topical report BAW-10227P-A.</p> |
| 4           | Section 4.1.3.1<br>Hold Down<br>Analysis Criteria               | Revised for consistency with approved response to RAI Question #6 of BAW-10179P Revision 0   |
| 5           | Section 4.1.9.2<br>LOCA Analysis<br>Method                      | Revised the grid strength definition to point to NRC approved topical reports BAW-10133P-A Revision 1 and BAW-10133P-A Revision 1, Addendum 1 and Addendum 2.  |
| 6           | Section 4.2.5.1<br>Fuel Rod Stress<br>Analysis Criteria         | <p>a) Separated Conditions I &amp; II and Conditions III &amp; IV stress criteria for fuel rod cladding.</p> <p>b) Revised Conditions III &amp; IV stress criteria. This revision is per Section 4.7 of SER of approved topical report BAW-10227P-A.</p>   |
| 7           | Section 4.2.6.2<br>Strain Analysis<br>Method                    | Updated to correct and clarify differences in transient cladding strain definitions used in TACO3, GDTACO, and COPENIC applications.   |
| 8           | Section 4.2.8.2<br>Fuel Rod Pressure<br>Analysis Method         | Updated to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications.   |

| <b>Item</b> | <b>Section(s) or Page(s)</b>  | <b>Description and Justification</b>  |
|-------------|---|---|
| 9           | Section 4.2.9.1<br>Fuel Temperature<br>(Centerline Fuel<br>Melt) Limit Analysis<br>Criteria | Updated to correct and clarify criteria for application to predicted maximum fuel temperature of UO <sub>2</sub> and gadolinia fuel types.  |
| 10          | Section 4.2.9.2<br>Fuel Temperature<br>(Centerline Fuel<br>Melt) Limit Analysis<br>Method   | Updated to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPERNIC applications, and to clarify application of burnup-dependent fuel melt limits in analyses.  |
| 11          | Section 6.1<br>Core Thermal-<br>Hydraulics Design<br>Criteria                               | Revised for consistency with approved response to RAI Question #6 of BAW-10179P Revision 0  |
| 12          | Section 9.0<br>Loss-of-Coolant<br>Accident<br>Evaluation                                    | Revised to address analysis methodology changes for the fuel initialization codes and adjustments to the fuel pin input and steady-state initialization process for the LOCA transient codes to account for burnup-dependent fuel thermal conductivity degradation (TCD) as described in the supplement to BAW-10192P-A Revision 0. |
| 13          | Section 11.0<br>References  | a) Updated Reference 75 to refer to BAW-10164P-A Revision 6, consistent with BAW-10179P-A Revision 8.<br>b) Added Reference 83 to BAW-10179P.<br>c) Added Reference 84 to BAW-10179P  |
| 14          | Throughout  | Updated report format to conform to AREVA's current topical report style guide; updated Company name; and corrected misspelled words and symbols.   |
| 15          | Sections 4.1.13,<br>5.4, 6.8  | Added Reference 84 to text  |

## Contents

|   | <u>Page</u> |
|---|-------------|
| 1.0 INTRODUCTION .....  | 1-1         |
| 2.0 DESIGN CONSIDERATIONS .....   | 2-1         |
| 2.1 Safety Criteria .....   | 2-1         |
| 2.2 Plant Conditions .....  | 2-1         |
| 2.2.1 Condition I -- Normal Operation and Operational<br>Transients ..... | 2-1         |
| 2.2.2 Condition II -- Events of Moderate Frequency .....                  | 2-2         |
| 2.2.3 Condition III -- Infrequent Events .....                            | 2-2         |
| 2.2.4 Condition IV -- Limiting Faults .....                               | 2-2         |
| 3.0 REFERENCE FUEL DESCRIPTION FOR MARK-B DESIGN .....                    | 3-1         |
| 3.1 Fuel Pellet .....   | 3-1         |
| 3.2 Fuel Rod .....  | 3-1         |
| 3.3 Fuel Assembly .....   | 3-1         |
| 3.4 Alternate Mark-B Fuel Designs .....                                   | 3-2         |
| 3.4.1 Small Pin Fuel Assembly Design .....                                | 3-2         |
| 4.0 MECHANICAL SAFETY AND DESIGN CRITERIA .....                           | 4-1         |
| 4.1 Fuel Assembly Design .....  | 4-1         |
| 4.1.1 Growth .....  | 4-1         |
| 4.1.2 Stress .....  | 4-2         |
| 4.1.3 Hold Down .....   | 4-4         |
| 4.1.4 Buckling .....  | 4-5         |
| 4.1.5 Grids .....   | 4-6         |
| 4.1.6 Fretting .....  | 4-6         |
| 4.1.7 Rod Bow .....   | 4-7         |
| 4.1.8 Seismic .....   | 4-7         |
| 4.1.9 LOCA .....  | 4-8         |
| 4.1.10 Shipping .....   | 4-11        |
| 4.1.11 Material .....   | 4-12        |
| 4.1.12 Extended Burnup .....  | 4-14        |
| 4.1.13 Stainless Steel Replacement Rod Methodology .....                  | 4-16        |
| 4.2 Fuel Rod Design .....   | 4-16        |
| 4.2.1 Shipping .....  | 4-17        |
| 4.2.2 Plenum Space .....  | 4-17        |
| 4.2.3 Corrosion .....   | 4-18        |
| 4.2.4 Creep Ovality .....   | 4-19        |

|       |   |      |
|-------|---|------|
| 4.2.5 | Stress .....  | 4-20 |
| 4.2.6 | Strain .....  | 4-22 |
| 4.2.7 | Fatigue .....                                       | 4-23 |
| 4.2.8 | Fuel Rod Pressure .....                             | 4-24 |
| 4.2.9 | Fuel Temperature (Centerline Fuel Melt) Limit ..... | 4-26 |
| 5.0   | NUCLEAR DESIGN .....                                | 5-1  |
| 5.1   | Nuclear Design Codes .....                          | 5-1  |
| 5.2   | Fuel Cycle Design .....                             | 5-2  |
| 5.2.1 | Final Fuel Cycle Design .....                       | 5-2  |
| 5.3   | Power Distribution Analysis .....                   | 5-6  |
| 5.3.1 | Axial Power Imbalance Protective Limits .....       | 5-6  |
| 5.3.2 | Power Distribution-Related LCO Limits .....         | 5-14 |
| 5.3.3 | EOC Full Power Extension Maneuvers .....            | 5-21 |
| 5.3.4 | Xenon Stability Index .....                         | 5-22 |
| 5.3.5 | Power Level Cutoff Hold Removal .....               | 5-23 |
| 5.3.6 | Overcooling Transient .....                         | 5-24 |
| 5.3.7 | Inoperable Control Rods .....                       | 5-25 |
| 5.4   | Nuclear Parameters for Safety Analysis .....        | 5-27 |
| 5.4.1 | Transient Neutronic Parameters .....                | 5-28 |
| 5.4.2 | Reactivity-Related LCOs .....                       | 5-32 |
| 5.4.3 | Radiation Parameters .....                          | 5-38 |
| 5.4.4 | Fuel Loading .....                                  | 5-39 |
| 5.5   | Startup Physics Testing .....                       | 5-41 |
| 5.5.1 | Acceptance Criteria .....                           | 5-42 |
| 5.5.2 | Analysis Methods .....                              | 5-43 |
| 6.0   | CORE THERMAL HYDRAULICS .....                       | 6-1  |
| 6.1   | Design Criteria .....                               | 6-1  |
| 6.2   | Analysis Methods .....                              | 6-2  |
| 6.2.1 | LYNX Codes .....                                    | 6-2  |
| 6.2.2 | Power Distribution .....                            | 6-6  |
| 6.2.3 | Engineering Hot Channel Factors .....               | 6-7  |
| 6.2.4 | Reactor Core Coolant Flow .....                     | 6-8  |
| 6.2.5 | Core Inlet Flow Distribution .....                  | 6-9  |
| 6.2.6 | Fuel Rod Bowing .....                               | 6-10 |
| 6.2.7 | Fuel Densification Effects .....                    | 6-11 |
| 6.2.8 | DNB Design and Analysis Limits .....                | 6-12 |
| 6.2.9 | Statistical Core Design .....                       | 6-13 |
| 6.3   | Fuel Assembly Hydraulics .....                      | 6-15 |

|       |   |      |
|-------|---|------|
| 6.3.1 | Fuel Assembly Lift.....                                       | 6-15 |
| 6.3.2 | Core Pressure Drop .....                                      | 6-17 |
| 6.3.3 | Hydraulic Compatibility.....                                  | 6-18 |
| 6.4   | Reactor Coolant System DNB Safety Limits .....                | 6-20 |
| 6.5   | Flux/Flow Protective Limit.....                               | 6-22 |
| 6.6   | Maximum Allowable Peaking Limits.....                         | 6-24 |
| 6.6.1 | Calculation of Safety Limit MAPs (RPS MAPs).....              | 6-25 |
| 6.6.2 | Calculation of Operating Limit MAPs.....                      | 6-27 |
| 6.6.3 | Verification of Calculated Margins (Physics Check Cases)..... | 6-29 |
| 6.7   | Transient Core Thermal-Hydraulic Analysis.....                | 6-29 |
| 6.8   | Stainless Steel Replacement Rod Methodology .....             | 6-30 |
| 6.9   | Reload Safety Evaluation.....                                 | 6-31 |
| 7.0   | REACTOR PROTECTION SYSTEM SETPOINTS.....                      | 7-1  |
| 7.1   | High Reactor Coolant System Pressure Trip .....               | 7-1  |
| 7.1.1 | Functional Description.....                                   | 7-1  |
| 7.1.2 | Analysis Criteria .....                                       | 7-1  |
| 7.1.3 | Analysis Trip Setpoint Calculations .....                     | 7-2  |
| 7.1.4 | Delay Times .....   | 7-3  |
| 7.2   | Low Reactor Coolant System Pressure Trip .....                | 7-4  |
| 7.2.1 | Functional Description.....                                   | 7-4  |
| 7.2.2 | Analysis Criteria .....                                       | 7-4  |
| 7.2.3 | Analysis Trip Setpoint Calculations .....                     | 7-5  |
| 7.2.4 | Delay Times .....   | 7-6  |
| 7.3   | Power/Imbalance/Flow Trip .....                               | 7-6  |
| 7.3.1 | Functional Description.....                                   | 7-6  |
| 7.3.2 | Analysis Criteria .....                                       | 7-7  |
| 7.3.3 | Analysis Trip Setpoint Calculations .....                     | 7-7  |
| 7.3.4 | Delay Times .....   | 7-15 |
| 7.4   | High Flux Trip .....  | 7-15 |
| 7.4.1 | Functional Description.....                                   | 7-15 |
| 7.4.2 | Analysis Criteria .....                                       | 7-15 |
| 7.4.3 | Analysis Trip Setpoint Calculations .....                     | 7-16 |
| 7.4.4 | Delay Times .....   | 7-18 |
| 7.5   | High Reactor Coolant Outlet Temperature Trip .....            | 7-19 |
| 7.5.1 | Functional Description.....                                   | 7-19 |
| 7.5.2 | Analysis Criteria .....                                       | 7-19 |

|       |  |      |
|-------|--|------|
| 7.5.3 | Analysis Trip Setpoint Calculations .....                                      | 7-20 |
| 7.5.4 | Delay Times .....  | 7-20 |
| 7.6   | Variable Low RC Pressure Trip .....  | 7-21 |
| 7.6.1 | Functional Description .....   | 7-21 |
| 7.6.2 | Analysis Criteria .....  | 7-21 |
| 7.6.3 | Analysis Trip Setpoint Calculations .....                                      | 7-22 |
| 7.6.4 | Delay Times .....  | 7-24 |
| 7.7   | High Reactor Building Pressure Trip .....                                      | 7-24 |
| 7.7.1 | Functional Description .....   | 7-24 |
| 7.7.2 | Analysis Criteria .....  | 7-24 |
| 7.7.3 | Analysis Trip Setpoint Calculations .....                                      | 7-25 |
| 7.7.4 | Delay Times .....  | 7-25 |
| 7.8   | Power/Pump Monitors Trip .....   | 7-26 |
| 7.8.1 | Functional Description .....   | 7-26 |
| 7.8.2 | Analysis Criteria .....  | 7-26 |
| 7.8.3 | Accident Analysis Trip Setpoint Calculations .....                             | 7-27 |
| 7.8.4 | Delay Times .....  | 7-28 |
| 8.0   | NON-LOCA ACCIDENT EVALUATION .....   | 8-1  |
| 8.1   | Systems Response Analyses .....  | 8-1  |
| 8.1.1 | Moderator and Doppler Coefficients .....                                       | 8-1  |
| 8.1.2 | BOC Soluble Boron Concentration .....  | 8-3  |
| 8.1.3 | Dropped Control Rod Worth .....  | 8-3  |
| 8.1.4 | Ejected Rod Worth .....  | 8-4  |
| 8.1.5 | Single and All-Control-Rod-Group Worth .....                                   | 8-4  |
| 8.1.6 | Delayed Neutron Fraction ( $\beta_{eff}$ ) .....                               | 8-5  |
| 8.1.7 | Additional Cycle-Specific Evaluations .....                                    | 8-5  |
| 8.1.8 | EOC Average Reactor Coolant Temperature<br>Reduction .....                     | 8-6  |
| 8.2   | Accident Evaluation .....  | 8-6  |
| 9.0   | LOSS-OF-COOLANT ACCIDENT EVALUATION .....                                      | 9-1  |
| 9.1   | Analysis Criteria .....  | 9-1  |
| 9.2   | Analysis Methods .....   | 9-2  |
| 9.2.1 | CRAFT2 EM .....  | 9-3  |
| 9.2.2 | RELAP5 EM .....  | 9-4  |
| 9.2.3 | Steady-State Fuel Data Input to LOCA EMs .....                                 | 9-7  |
| 9.3   | Generic LOCA Evaluations .....   | 9-8  |
| 9.4   | Application of Generic Evaluations to Cycle-Specific Plant<br>Conditions ..... | 9-10 |

|      |   |      |
|------|---|------|
| 10.0 | LIMITED SCOPE HIGH BURNUP LEAD TEST ASSEMBLIES.....       | 10-1 |
| 10.1 | Use of Lead Test Assemblies .....                         | 10-1 |
| 10.2 | Definition of a Lead Test Assembly .....                  | 10-1 |
| 10.3 | Conditions for Limited Scope High Burnup LTA Program..... | 10-1 |
| 10.4 | Nuclear Design and Safety Analysis Considerations .....   | 10-4 |
|      | 10.4.1 Core Loading Pattern Development.....              | 10-4 |
|      | 10.4.2 Safety Analysis.....                               | 10-4 |
| 10.5 | Evaluation of Limited Scope High Burnup LTAs .....        | 10-5 |
| 11.0 | REFERENCES.....   | 11-1 |



## List of Tables

|           |   |      |
|-----------|---|------|
| Table 3-1 | Typical Mark-B Fuel Assembly Parameters .....               | 3-3  |
| Table 5-1 | Example Calculation of the Shutdown Margin.....             | 5-45 |
| Table 5-2 | Reload Startup Physics Testing for B&W-Designed Plants..... | 5-46 |
| Table 6-1 | Core Inlet Flow Factors .....                               | 6-32 |
| Table 6-2 | Initial Conditions for Transient DNBR Calculations .....    | 6-33 |
| Table 6-3 | Significant Parameters - Core Thermal-Hydraulics .....      | 6-34 |

## List of Figures

|            |  |      |
|------------|--|------|
| Figure 1-1 | Reload Evaluation Flowchart .....  | 1-6  |
| Figure 2-1 | Categories of Events.....  | 2-3  |
| Figure 3-1 | Typical Mark-B Fuel Assembly Sketch.....   | 3-4  |
| Figure 5-1 | Example Axial Power Imbalance Protective Limits .....                              | 5-47 |
| Figure 5-2 | Example Centerline Fuel Melt vs. Offset Correlation .....                          | 5-48 |
| Figure 5-3 | Rod Index and Regulating Bank Position Relationship .....                          | 5-49 |
| Figure 6-1 | Example of Reactor Core Safety Limits .....  | 6-35 |
| Figure 6-2 | Example of Maximum Allowable Radial Peaks .....                                    | 6-36 |
| Figure 6-3 | Example of Maximum Allowable Total Peaks .....                                     | 6-37 |
| Figure 7-1 | General Setpoint Philosophy.....   | 7-29 |
| Figure 7-2 | Power/Imbalance/Flow Trip Setpoint .....   | 7-30 |
| Figure 7-3 | Power/Imbalance/Flow Detectability Envelope .....                                  | 7-31 |
| Figure 7-4 | Power/Imbalance/Flow Trip Setpoints for Four, Three and Two Pump<br>Operation..... | 7-32 |
| Figure 7-5 | Variable Low Pressure Trip Setpoint.....   | 7-33 |
| Figure 7-6 | Variable Low Pressure Setpoint Slope Rotation .....                                | 7-34 |

## Nomenclature

| Acronym   | Definition                                 |
|-----------|--|
| AMSAC     | ATWS Mitigation System Actuation Circuitry |
| ANS       | American Nuclear Society                   |
| ANSI      | American National Standards Institute      |
| APS       | Axial Power Shape                          |
| APSR      | Axial Power Shaping Rod                    |
| AROCBC    | All Rods Out Critical Boron Concentration  |
| ASME      | American Society of Mechanical Engineers   |
| ATWS      | Anticipated Transient Without Scram        |
| $B_{eff}$ | Effective Delayed Neutron Fraction         |
| B&W       | The Babcock and Wilcox Company             |
| BOC       | Beginning-of-Cycle                         |
| BPRA      | Burnable Poison Rod Assembly               |
| BWOG      | B&W Owners Group                           |
| CFM       | Centerline Fuel Melt                       |
| CFR       | Code of Federal Regulations                |
| CHF       | Critical Heat Flux                         |
| COLR      | Core Operating Limits Report               |
| CRA       | Control Rod Assembly                       |
| CRAFT2    | CRAFT2 Transient Analysis Computer Code    |
| CRDM      | Control Rod Drive Mechanism                |
| CRG       | Control Rod Group                          |
| DNB       | Departure from Nucleate Boiling            |
| DNBR      | Departure from Nucleate Boiling Ratio      |
| DSS       | Diverse SCRAM System                       |
| ECCS      | Emergency Core Cooling System              |
| EFPD      | Effective Full Power Days                  |
| EM        | Evaluation Model                           |
| EOC       | End-of-Cycle                               |
| EPRI      | Electric Power Research Institute          |
| FFCD      | Final Fuel Cycle Design                    |
| FP        | Full Power (Full Rated Thermal Power)      |
| FSAR      | Final Safety Analysis Report               |
| GDC       | General Design Criteria                    |
| GWd/mtU   | Gigawatt Days per Metric Ton of Uranium    |

| <b>Acronym</b> | <b>Definition</b>                                |
|----------------|--|
| HFP            | Hot Full Power                                   |
| HPI            | High Pressure Injection                          |
| HZP            | Hot Zero Power                                   |
| ID             | Inner Diameter                                   |
| ITC            | Isothermal Temperature Coefficient               |
| LBB            | Leak-Before-Break                                |
| LBLOCA         | Large Break Loss-of-Coolant Accident             |
| LCO            | Limiting Condition for Operation                 |
| LHR            | Linear Heat Rate                                 |
| LOCA           | Loss-of-Coolant Accident                         |
| LOCF           | Loss-of-Coolant-Flow                             |
| LTA            | Lead Test Assembly                               |
| MAP            | Maximum Allowable Peaking                        |
| MTC            | Moderator Temperature Coefficient                |
| MWd/mtU        | Megawatt Days per Metric Ton of Uranium          |
| NRC            | Nuclear Regulatory Commission                    |
| NSAC           | Nuclear Safety Analysis Center                   |
| NSSS           | Nuclear Steam Supply System                      |
| OBE            | Operational Basis Earthquake                     |
| OD             | Outside Diameter                                 |
| pcm            | Percent millirho (a reactivity measurement unit) |
| PCT            | Peak Cladding Temperature                        |
| PIE            | Post-Irradiation Examination                     |
| ppm            | Parts Per Million                                |
| PSC            | Preliminary Safety Concern                       |
| P-T            | Pressure-Temperature                             |
| PV             | Pressure-Velocity                                |
| RC             | Reactor Coolant                                  |
| RCS            | Reactor Coolant System                           |
| RELAP5         | RELAP5/MOD2-B&W Transient Analysis Computer Code |
| RIL            | Rod Insertion Limit                              |
| RPD            | Relative Power Density                           |
| RPS            | Reactor Protection System                        |
| RTP            | Rated Thermal Power                              |
| RV             | Reactor Vessel                                   |
| SAFDL          | Specified Acceptable Fuel Design Limit           |

| <b>Acronym</b>   | <b>Definition</b>  |
|------------------|--|
| SAR              | Safety Analysis Report   |
| SBLOCA           | Small Break Loss-of-Coolant Accident   |
| SCD              | Statistical Core Design  |
| SDL              | Statistical Design Limit   |
| SDM              | Shutdown Margin  |
| SER              | Safety Evaluation Report   |
| SGTR             | Steam Generator Tube Rupture   |
| SRSS             | Square-Root-of-Sum-of-Squares  |
| SSE              | Safe Shutdown Earthquake   |
| T <sub>avg</sub> | Average Reactor Coolant Temperature  |
| TCS              | Transient Cladding Strain  |
| TCD              | Thermal Conductivity Degradation   |
| TD               | Theoretical Density  |
| TDL              | Thermal Design Limit   |
| TIL              | Time-in-Life<br>(refers to burnup between 0 GWd/mtU and maximum analyzed burnup) |
| VAFT             | Volume-average Fuel Temperature  |
| VLPT             | Variable Low Reactor Coolant Pressure Trip                                       |
| VMFT             | Vessel Model Flow Test   |
| ZPPT             | Zero Power Physics Testing   |
| 4PSUT            | Fourth Pump Startup Temperature  |
| 177-FA           | 177 Fuel Assembly  |

## ABSTRACT

Subsequent to the issuance of NRC Generic Letter 88-16, the B&W Owners Group (BWOOG) authorized the preparation of Topical Report BAW-10179P-A, entitled: "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses."

BAW-10179P-A was reviewed and approved by the NRC and is referenced in the technical specification reporting requirements for Core Operating Limit Report parameters for B&W-designed nuclear plants.

Since its original approval, eight revisions to the report have been issued. Revisions 1 through 6 were issued in the form of appendices to incorporate additional NRC-approved codes and methods. Revision 7 comprised a more extensive update of the report that incorporated the information contained in the appendices (through Revision 6) into the body of the report; it also included the COPENIC methodology, incorporated the statistical fuel assembly hold down methodology, summarized the modified zero power physics testing program, and added a section to address generic guidelines for the use of limited scope high burnup lead test assemblies (LTAs) based on requirements in WCAP-15604-NP, Revision 2-A, "Limited Scope High Burnup Lead Test Assemblies." Revision 8 added a single appendix that updated the reference to the RELAP5/MOD2-B&W transient analysis code topical report (BAW-10164P-A) to the latest revision level (Revision 6).

The purpose of Revision 9 is to:

- Incorporate analysis methodology changes to the BWNT LOCA Evaluation Model for once-through steam generator plants described in the supplement to BAW-10192P-A, which addresses adjustments to the fuel rod input and steady-state initialization process for LOCA transient evaluation based upon burnup-dependent thermal conductivity degradation (TCD); this information has been added to Section 9.0 of BAW-10179P.
- Update the reference to BAW-10164P-A Revision 6 (from Appendix B to BAW-10179P-A, Revision 8) in the LOCA methodology discussion of the report

(Section 9.0).

- Update the methodology for fuel assembly stress analysis criteria (Section 4.1.2.1), fuel assembly grid strength definition (Section 4.1.9.2), and fuel rod stress analysis criteria (Section 4.2.5.1) to be consistent with the response to RAI Question 13 issued during the review of BAW-10179P Revision 0.
- Update the fuel assembly hold down analysis criteria (Section 4.1.3.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Update the transient cladding strain analysis description (Section 4.2.6.2) to correct and clarify differences in transient cladding strain definitions used in approved TACO3, GDTACO, and COPENIC applications.
- Update the fuel rod pressure analysis description (Section 4.2.8.2) to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications.
- Update the fuel temperature (centerline fuel melt) limit analysis criteria (Section 4.2.9.1) and analysis method description (Section 4.2.9.2) to correct and clarify application to  $\text{UO}_2$  and gadolinia fuel types, and to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications.
- Update the core thermal-hydraulics design criteria (Section 6.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Correct misspelled words and symbols, as appropriate, throughout the report.
- Update the description for analysis of fuel assemblies containing stainless steel rods per reference 84.

## 1.0 INTRODUCTION

Nuclear Regulatory Commission (NRC) Generic Letter 88-16, issued in October 1988, allows the removal of cycle-dependent variables from technical specifications provided the values of these variables are determined with NRC-approved methodology and are included in a Core Operating Limits Report (COLR). In reference 1 the NRC agreed that this philosophy can be extended to the cycle-dependent protective and maximum allowable setpoint limits. AREVA Inc. (AREVA) designs and fabricates fuel, and prepares reload safety evaluations for a number of B&W 177 fuel assembly (177-FA) nuclear power plants. All of these plants use Mark-B fuel assemblies. The methodology for performing reload design evaluations for this class of plants operating with Mark-B fuel is presented in topical report BAW-10179P-A, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses." The utility owners for whom AREVA performs reload safety evaluations reference BAW-10179P-A in the Administrative Controls (Reporting Requirements) sections of the plant technical specifications. The technical specifications identify BAW-10179P-A as the NRC-approved AREVA methodology for determining the limits contained in the COLR. The technical specifications also state that the latest approved revision of BAW-10179P-A shall be specified in the COLR.

The COLR for a B&W-designed plant typically contains the following parameters:

- Control rod physical insertion, sequence, and overlap limits
- Control rod program
- Axial power shaping rod (APSR) insertion limits
- Axial power imbalance operating limits
- Quadrant power tilt limits
- End-of-cycle moderator temperature coefficient (MTC)
- Nuclear heat flux hot channel factor limit,  $F_Q^N$
- Nuclear enthalpy rise hot channel factor limit,  $F_{\Delta H}^N$
- Refueling boron concentration



- Axial power imbalance protective limits
- Trip setpoint for nuclear overpower based on reactor coolant system (RCS) flow

These parameters were identified by the NRC in the original approval of BAW-10179P-A. Individual utility owners of the B&W-designed plants have successfully negotiated with the NRC to include additional parameters in their COLRs.

Since its original approval, eight revisions of BAW-10179P-A have been issued. Revisions 1 through 6 were issued in the form of appendices to incorporate additional NRC-approved codes and methods. Revision 7 comprised a more extensive update that incorporated the information contained in the appendices from those six previous revisions into the main body of the report; it also updated the methodology to incorporate the NRC-approved COPENIC design code, incorporated the statistical fuel assembly hold down methodology, summarized the modified zero power physics testing program, and added a section to address generic guidelines for the use of limited scope high burnup lead test assemblies (LTAs) to satisfy the requirement to incorporate WCAP-15604-NP, Revision 2-A, "Limited Scope High Burnup Lead Test Assemblies," explicitly into the licensee's Technical Specifications by direct reference in BAW-10179P-A. Revision 8 added a single appendix that updated the reference to the RELAP5/MOD2-B&W transient analysis code topical report (BAW-10164P-A) to the latest revision level (Revision 6).

The purpose of Revision 9 is to:

- Incorporate analysis methodology changes to the BWNT LOCA Evaluation Model for once-through steam generator plants described in the supplement to BAW-10192P-A, which addresses adjustments to the fuel rod input and steady-state initialization process for LOCA transient evaluation based upon burnup-dependent thermal conductivity degradation (TCD); this information has been added to Section 9.0 of BAW-10179P.
- Update the reference to BAW-10164P-A Revision 6 (from Appendix B to BAW-10179P-A, Revision 8) in the LOCA methodology discussion of the report (Section 9.0).

- Update the methodology for fuel assembly stress analysis criteria (Section 4.1.2.1), fuel assembly grid strength definition (Section 4.1.9.2), and fuel rod stress analysis criteria (Section 4.2.5.1) to be consistent with the response to RAI Question 13 issued during the review of BAW-10179P Revision 0.
- Update the fuel assembly hold down analysis criteria (Section 4.1.3.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Update the transient cladding strain analysis description (Section 4.2.6.2) to correct and clarify differences in transient cladding strain definitions used in approved TACO3, GDTACO, and COPENIC applications.
- Update the fuel rod pressure analysis description (Section 4.2.8.2) to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications.
- Update the fuel temperature (centerline fuel melt) limit analysis criteria (Section 4.2.9.1) and analysis method description (Section 4.2.9.2) to correct and clarify application to  $\text{UO}_2$  and gadolinia fuel types, and to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications.
- Update the core thermal-hydraulics design criteria (Section 6.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Correct misspelled words and symbols, as appropriate, throughout the report.
- Update the description for analysis of fuel assemblies containing stainless steel rods per reference 84.

AREVA has developed criteria for determining when a design change must be submitted to the NRC for review and approval. The criteria are:

1. The change meets any of the eight criteria specified in paragraph (c)(2) of 10CFR50.59.
2. A change to the plant technical specifications is required.
3. The applicability of NRC-approved design/analysis evaluation methods is affected.

4. A material not previously qualified for in-reactor operation in a similar application is introduced.
5. Burnup limits are extended beyond those previously approved.

AREVA has developed criteria for determining when a change in evaluation methods must be submitted to the NRC for review and approval. The criteria are:

1. The change consists of replacement of an existing approved design code or method.
2. The core power distribution monitoring methodology is changed.
3. An approved method is extended beyond previously acceptable limits.

Any design or evaluation method changes that meet the above criteria must receive NRC review and approval prior to implementation.

Limitations and conditions specified in the safety evaluation reports (SERs) of referenced NRC-approved topical reports are applicable to BAW-10179P-A, unless specifically stated otherwise in this report.


All currently operating nuclear power plants store spent fuel assemblies on site. For economic and safety purposes, some of these assemblies are periodically returned to the reactor for additional cycles of operation. These assemblies were analyzed with the methodology that was current at the time the fuel was fabricated. Some of this methodology has changed as nuclear technology evolved over the lifetime of the nuclear power plants. Design parameters (e.g., burnup, pin power, CFM limit, LOCA limit, etc.) for some of the fuel assemblies were determined with codes or methods that are no longer used. However, these methods are NRC-approved and design parameters determined with these methods remain valid and applicable for reinserted fuel assemblies.

This report describes the entire spectrum of methodologies that are applicable to the reload fuel currently supplied by AREVA for the B&W 177-FA plants. An overview of the design considerations addressed in these methods is provided in Section 2.0. A brief description of the Mark-B fuel design is provided in Section 3.0. The mechanical design methods are described in Section 4.0. The nuclear design methods are described in Section 5.0, which also includes the radiological evaluation parameters. The thermal-hydraulics methods are described in Section 6.0. Section 7.0 includes the methods for determining reactor protection system (RPS) trip setpoints. Section 8.0 describes the non-LOCA accident evaluation methods, and Section 9.0 presents the LOCA accident evaluation methods. Figure 1-1 provides an overview on how the different analytical disciplines interact to complete a reload evaluation. Section 10.0 provides generic guidelines on the use of limited scope high burnup lead test assemblies.

The methodology described in this report is constantly evolving to include improvements and enhancements to analytical techniques. This will result in a succession of updates to BAW-10179P-A. To facilitate these updates AREVA will implement the following procedure:

1. For revisions to NRC-approved topical reports already referenced in BAW-10179P-A, such revisions will be incorporated by referencing the latest approved revision in the COLR.
2. For new methodology topical reports, AREVA will prepare a corresponding revision to BAW-10179P-A. The revision to BAW-10179P-A will include a brief summary of the methodology topical and its range of applicability. When the NRC completes its review of the revision to BAW-10179 an approved version will be issued.

### Figure 1-1 Reload Evaluation Flowchart



## **2.0 DESIGN CONSIDERATIONS**

### **2.1 *Safety Criteria***

The safety criteria for the design of nuclear power plants are provided in various parts of Title 10 of the Code of Federal Regulations (CFR). The radiological dose criteria are located in 10CFR100 (reference 2). The acceptance criteria for emergency core cooling systems are given in 10CFR50.46 (reference 3). The general design criteria (GDC) are found in 10CFR50 Appendix A (reference 3).

The criteria given in 10CFR50.46 and 10CFR100 are quantitative in nature and are well defined. Compliance with these criteria can be demonstrated by analysis. The general design criteria found in 10CFR50 Appendix A, as the name implies, are not so specific. Many of these criteria use the term "specified acceptable fuel design limits" (SAFDLs). These SAFDLs take many forms in the mechanical, nuclear, thermal-hydraulic, and safety analyses of light-water reactor fuel. Each design discipline has a set of parameters that is determined to show compliance with the GDC in Appendix A. The specific criteria for each type of analysis are given in the individual sections of this report.

### **2.2 *Plant Conditions***

The normal operation and possible transient modes of nuclear plants are categorized into four conditions commonly referred to as normal, moderate frequency, infrequent incidents, and limiting faults. The specific definitions for these conditions are taken from ANSI/ANS-57.5-1981.

#### **2.2.1 Condition I -- Normal Operation and Operational Transients**

Condition I events are those that are expected frequently or regularly in the normal course of power operation. The design requirement for these events is that they shall be accommodated with margin between any plant parameter and the value of that parameter which would require either automatic or manual protective action.

## **2.2.2 Condition II -- Events of Moderate Frequency**

Condition II events are those that are expected to occur during the life of a plant that may result in reactor shutdown. The design requirement for these events is that they shall be accommodated with, at most, a shutdown of the reactor with the plant capable of returning to power operation after corrective action.

## **2.2.3 Condition III -- Infrequent Events**

Condition III events are incidents that may occur infrequently, if at all, during the life of the plant. The design requirement for these events is that they shall not cause more than a small fraction of the fuel elements in the reactor to be damaged, although sufficient fuel element damage might occur to preclude resumption of operation for a considerable outage time.

## **2.2.4 Condition IV -- Limiting Faults**

These events are not expected to occur, but are postulated because their consequences would include the potential for the release of significant amounts of radioactive material. Condition IV events represent the limiting design case. The design requirement for these events is that they shall not cause a release of radioactive material that results in an undue risk to public health and safety exceeding the guidelines of 10CFR100. A single Condition IV event shall not cause a consequential loss of system functions needed to cope with the event.

The NRC categorizes plant operation into three conditions. They are normal operation, anticipated operational occurrences, and accidents. Figure 2-1 shows the relationship between the NRC scheme and the ANS-57.5 scheme. AREVA assures compliance with the NRC regulations by requiring the limiting Condition III transient to meet the acceptance criteria for Condition II events.

**Figure 2-1 Categories of Events**

| <b>Event<br/>Frequency<br/>Range<br/>(per reactor-year)</b> | <b>NRC<br/>10CFR50</b>                    | <b>AREVA<br/>ANSI/ANS-57.5</b> |
|---|---|--------------------------------|
| Planned Operations  | Normal                                    | Condition I                    |
| ----- $10^{-1}$ -----                                       | Anticipated<br>Operational<br>Occurrences | Condition II                   |
| ----- $10^{-2}$ -----                                       |   | Condition III                  |
| ----- $10^{-3}$ -----                                       | Accidents                                 | Condition IV                   |
| ----- $10^{-4}$ -----                                       |   |                                |
| ----- $10^{-5}$ -----                                       |   |                                |
| ----- $10^{-6}$ -----                                       |   |                                |



### **3.0 REFERENCE FUEL DESCRIPTION FOR MARK-B DESIGN**

#### **3.1 *Fuel Pellet***

The fuel consists of cylindrical pellets. The pellets are sintered and ground, and contain low enriched uranium dioxide. The pellet ends are dished to minimize differential thermal expansion between the fuel and cladding.

#### **3.2 *Fuel Rod***

The fuel rod consists of fuel pellets, cladding, a spring system, and end caps. The spring system consists of springs located below and/or above the pellet stack in the fuel rod. The spring system is designed to accommodate maximum thermal expansion of the fuel column without being deflected beyond solid height and to minimize gaps forming within the fuel rod internals during shipping and handling. All fuel rods are internally pressurized with helium.

#### **3.3 *Fuel Assembly***

The standard Mark-B fuel assembly, as fabricated, consists of 208 fuel rods, 16 control rod guide tubes, 1 instrumentation tube assembly, 8 spacer grids, and 2 end fittings. The guide tubes, spacer grids, and end fittings form a structural cage to arrange the rods and tubes in a 15 x 15 array. The fuel rod outside diameter (OD) is [ ] inches. The typical grid configuration is non-mixing. As an option to enhance fretting resistance, the standard Mark-B product incorporates the HTP grid (reference 4). The center position in the fuel assembly is reserved for instrumentation. Product enhancements, which are described in applicable reload safety evaluation documents, have been made to the Mark-B design. Significant changes include modifications to the end fittings to improve debris resistance and facilitate reconstitution. A [

] to optimize the hold down system and an enhanced grid restraint system have also been incorporated. The NRC staff has found the standard Mark-B fuel to be acceptable to a rod average burnup of 62 GWd/mtU.

Table 3-1 lists various parameters and values for the Mark-B standard fuel design. The information provided in this table is typical for Mark-B fuel designs incorporating Zircaloy-4 and M5<sup>®</sup> material. A typical Mark-B fuel assembly sketch is shown in Figure 3-1.

### **3.4      *Alternate Mark-B Fuel Designs***

#### **3.4.1      Small Pin Fuel Assembly Design**

BAW-10229P-A (reference 5) provides the licensing bases for the small pin fuel assembly design. The small pin design features a [      ] inch OD fuel rod to reduce uranium requirements and mixing vane grids to provide superior thermal performance.

The NRC staff has found the small pin design to be acceptable to a rod average burnup of 62 GWd/mtU. Cycle-specific reload safety evaluations performed by licensees incorporating the small pin design address the same criteria as those considered for the standard Mark-B fuel assembly.


**Table 3-1 Typical Mark-B Fuel Assembly Parameters**

|  |  |
|--|--|
| Assembly Designation   | Mark-B   |
| Fuel Rod Array   | 15x15  |
| Hold Down Spring   | Helical Coil Spring or<br>Multiple Leaf Spring |
| Cladding Material  | Zr-4, M5 <sup>®</sup>                          |
| Guide Tube Material  | Zr-4, M5 <sup>®</sup>                          |
| Assemblies per Core  | 177  |
| Fuel Rods per Assembly   | 208  |
| Control Rod/Guide Tube/Instrument Tube<br>Locations Per Assembly | 17   |
| Debris Protection Feature  | Solid Lower End Plug*                          |
| Rod Pitch, mm<br>(inch)  | 14.4<br>(0.568)                                |
|  |  |
|  |  |
|  |  |
|  |  |
| System Pressure, MPa<br>(psia)                                   | 15.2<br>(2200)                                 |
| Core Inlet Temperature, °C<br>(°F)                               | 292.07<br>(557.7)                              |
| Core Outlet Temperature, °C<br>(°F)                              | 315.7<br>(600.3)                               |

Designs, materials, and dimensions are representative of those used to date. Alternates may be used if they are demonstrated to meet the burnup requirements.

\* Other options available.

\*\* Design has used both densities.

**Figure 3-1 Typical Mark-B Fuel Assembly Sketch**

## **4.0 MECHANICAL SAFETY AND DESIGN CRITERIA**

The mechanical design and operation of the fuel assembly will ensure that under all operating conditions the maximum credible damage will not degrade the design below those capabilities assumed in the safety analysis. The mechanical safety and design criteria compose two areas discussed below.

1. Fuel and control system capabilities are greater than or equal to those assumed in the safety analyses. This criterion is assured when the following three conditions are met:
  - a. Fuel rod cladding integrity is maintained.
  - b. The control rod insertion path remains open.
  - c. A coolable rod geometry is maintained.
2. Fuel and control system dimensions remain within operational tolerances.

Systems that are covered by this section include the fuel assembly and the fuel rod.

### **4.1 *Fuel Assembly Design***

The fuel assembly design criteria make certain that the fuel assembly with the maximum credible damage will be able to ensure that a path for control rod insertion remains, that a coolable fuel rod geometry remains and that the fuel assembly dimensions remain within operational limits. Compliance with the criteria in the following sections will ensure that the fuel assembly can meet those requirements.

#### **4.1.1 Growth**

##### **4.1.1.1 Analysis Criteria**

The gap allowance between the fuel assembly and the reactor internals and the growth allowance gap between the upper end fitting and the fuel rod shall be designed to provide a positive clearance during the assembly lifetime.

**4.1.1.2 Analysis Method****4.1.2 Stress****4.1.2.1 Analysis Criteria**

The stress intensities in the upper and lower end fittings (excluding the hold down spring), and the guide tubes shall be less than the limits shown below. The fuel rod stress criteria are covered separately in Section 4.2. All stress nomenclature is per the ASME Boiler and Pressure Vessel Code, Section III (reference 6).

| <u>Condition</u>    | <u>Stress Intensity Limit</u>  |
|---------------------|--|
| Conditions I & II   | $P_m \leq 1.0 S_m$<br>$P_I \leq 1.5 S_m$<br>$P_m + P_b \leq 1.5 S_m$<br>$P_m + P_b + Q \leq 3.0 S_m$   |
| Conditions III & IV | $P_m \leq 2.4 S_m$ or $0.7 S_u$ except<br>guide tubes<br>$P_m + P_b \leq 3.6 S_m$ or $1.05 S_u$<br>except guide tubes<br>whichever is less<br>$P_m \leq 1.0 S_m$ for guide tubes<br>$P_m + P_b < 1.5 S_m$ for guide<br>tubes |

where

$P_m$  = general primary membrane stress intensity,

$P_l$  = local primary membrane stress intensity,

$P_b$  = primary bending stress intensity,

$Q$  = secondary stress,

$S_m$  = allowable membrane stress intensity which is equal to the lowest of following:

For Zircaloy and M5<sup>®</sup> components:

$S_m = 2/3 S_y$  or  $1/3 S_u$ , whichever is less at room temperature, or

$S_m = 2/3 S_y$  or  $1/3 S_u$  at operating temperature.

(For conservative purposes, the unirradiated material properties are used to define the stress limits. Room temperature values are the minimum specified.)

For stainless steel and Inconel components:

$S_m$  = the least of  $2/3 S_y$  or  $1/3 S_u$  at room temperature,

$S_m$  = the least of  $1/3 S_u$  or  $0.9 S_y$  at operating temperature.

(For conservative purposes, the stainless steel unirradiated material properties are used to define the stress limits. Room temperature values are the minimum specified.)

$S_y$  = minimum yield stress,

$S_u$  = ultimate stress.

#### **4.1.2.2 Analysis Method**



Normal operational loads for the guide tubes are discussed in Section 4.1.4.

#### **4.1.3 Hold Down**

##### **4.1.3.1 Analysis Criteria**

The hold down spring system shall be capable of maintaining fuel assembly contact with the lower support plate during Condition I and II events. The fuel assembly upper and lower end fittings shall maintain engagement with reactor internals for all Condition I through IV events. The fuel assembly shall not compress the hold down spring to solid height for any Condition I or II event.



#### **4.1.3.2 Analysis Method**

#### **4.1.4 Buckling**

##### **4.1.4.1 Analysis Criteria**

Guide tube buckling shall not occur during normal operation (Condition I) or any transient condition where control rod insertion is required by the safety analysis.

##### **4.1.4.2 Analysis Method**

#### **4.1.5 Grids**

##### **4.1.5.1 Analysis Criteria**

No crushing deformation of the spacer grids shall occur due to normal operation (Condition I) and Condition II event loadings, and the spacer grids shall provide adequate support to maintain the fuel rods in a coolable configuration for all conditions as described in reference 7.

##### **4.1.5.2 Analysis Method**

#### **4.1.6 Fretting**

##### **4.1.6.1 Analysis Criteria**

The fuel assembly design shall be shown to provide sufficient support to limit fuel rod vibration and cladding fretting wear.

##### **4.1.6.2 Analysis Method**

#### **4.1.7 Rod Bow**

##### **4.1.7.1 Analysis Criteria**

Fuel rod bowing shall be evaluated with respect to the mechanical and thermal-hydraulic performance of the fuel assembly. Fuel rod bow shall be shown to be less than the limiting bow developed in reference 9 for the Mark-B design.

##### **4.1.7.2 Analysis Method**

#### **4.1.8 Seismic**

##### **4.1.8.1 Analysis Criteria**


The following criteria have been established for the fuel assembly seismic analysis:


1. Operational basis earthquake (OBE) - The fuel assembly is designed to ensure safe operation following an OBE.
2. Safe shutdown earthquake (SSE) - The fuel assembly is designed to allow control rod insertion and to maintain a coolable geometry.

**4.1.8.2 Analysis Method****4.1.9 LOCA****4.1.9.1 Analysis Criteria**

For LOCA or a combined LOCA and SSE, the fuel assembly is designed to allow for the safe shutdown of the reactor by maintaining the overall structural integrity and a coolable geometry within deformation limits consistent with the ECCS and safety analysis as defined in reference 11.

**4.1.9.2 Analysis Method**





#### **4.1.10 Shipping**

##### **4.1.10.1 Analysis Criteria**

The design condition for shipping is [ ] axial and [ ] lateral load on the fuel assembly. The fuel assembly will be analyzed for these load limits.

The spacer grids will maintain sufficient grip on the fuel rods to prevent axial movement during shipping and handling at axial loads of up to [ ]. Lateral loads of up to [ ] will not cause setting of spacer grid spring stops.

#### **4.1.10.2 Analysis Method**

### **4.1.11 Material**

#### **4.1.11.1 Analysis Criteria**

The materials used in the manufacture of the fuel assembly and the fuel rod must be compatible with all other materials in the primary system. That is, all core components must continue to meet their required function with the introduction of a new material.

#### **4.1.11.2 Analysis Method**





#### 4.1.11.3 Evaluation of Advanced Cladding and Structural Material (M5<sup>®</sup>)

BAW-10227P-A (reference 18) provides the justification for use of the alloy M5<sup>®</sup> to replace Zircaloy-4 in the construction of fuel assembly components such as fuel rod cladding, guide tubes, and spacer grids. Analysis criteria and methods are similar for Zircaloy-4 and M5<sup>®</sup>. M5<sup>®</sup> was developed by AREVA and is being implemented on a wide scale domestically and internationally. M5<sup>®</sup> provides improvements that include reduced corrosion, lower hydrogen pickup, decreased axial growth, and lower diametral creep. These improvements provide increased operating margin to the approved fuel rod average burnup limit of 62 GWd/mtU for the Mark-B fuel designs.

#### 4.1.12 Extended Burnup

Extended burnup operation of Mark-B fuel designs is supported by an extensive series of PIEs carried out on lead test assemblies (LTAs), demonstration assemblies, and production fuel assemblies. Prior to the submittal and approval of BAW-10186P-A (reference 9), the approved document containing the burnup limit for AREVA fuel was BAW-10153P-A (reference 19). That limit was [ ] GWd/mtU batch average. Fuel rod burnup is a much better indicator of the phenomena associated with higher burnups.

During the review of BAW-10186P-A, AREVA replaced the OXIDEPC corrosion model used for extended burnup applications with the COROS02 corrosion model. The NRC reviewed BAW-10186P-A for compliance with the criteria of Section 4.2 of the Standard Review Plan (NUREG-0800). In all cases, the AREVA methodology was found acceptable.

On April 29, 1997, the NRC issued the SER for BAW-10186P-A. The conclusions stated in the SER that are applicable to BAW-10179P-A are as follows:

- BAW-10186P-A is acceptable for licensing applications for Mark-B fuel up to burnup levels of 62 GWd/mtU rod average.

- The maximum corrosion limit is acceptable up to the value specified in reference 20 and supplemented with the interpretation of the application of that limit in reference 21.
- The COROS02 model is acceptable for use in predicting maximum corrosion levels.

The only limitation specified in the SER is that a penalty factor for thermal conductivity must be applied for burnups greater than [     ] GWd/mtU. This factor is defined in reference 22.

#### **4.1.12.1 Analysis Criteria**

The ability of the fuel assembly and fuel rod to maintain mechanical integrity at high burnups must be demonstrated. All design and operational criteria are the same for extended burnup fuel assemblies as for the original Mark-B fuel design.

#### **4.1.12.2 Analysis Method**



#### **4.1.13 Stainless Steel Replacement Rod Methodology**

The in-field repair of irradiated fuel assemblies with leaking rods involves the replacement of defective fuel rods with heat producing and/or non-heat producing rods. BAW-2149-A (reference 23) provides justification for the use of replacement rods without imposing unnecessary power peaking restrictions on the repaired fuel assemblies. This report addresses the nuclear, thermal-hydraulic, and mechanical aspects of the design that are affected by repair operations. The use of replacement rods for AREVA supplied fuel assemblies is determined to be acceptable by the NRC per the SER included in BAW-2149-A.

The NRC concurred in reference 84 that the topical report BAW-2149A is applicable to the use of stainless steel rods in fresh (i.e. unirradiated) fuel assemblies.

The stainless steel replacement rods weigh slightly less than Zircaloy-clad fuel rods, but the effect on fuel assembly weight of up to 10 replacement rods is negligible.

Therefore, the use of stainless steel replacement rods has an insignificant effect on fuel assembly hydraulic lift.

Stainless steel replacement rods are designed and analyzed to ensure that there is no adverse impact on fuel assembly performance. The rods are designed to ensure that adequate performance with respect to differential thermal expansion, irradiation growth, seismic-LOCA response, grid relaxation, and fretting due to vibration will be maintained. The replacement rods can be installed in any fuel rod location in the fuel assembly.

#### **4.2 Fuel Rod Design**

The design of the fuel rod must ensure that the integrity of the cladding is maintained under all Condition I and II events. The integrity of the cladding is maintained by requiring that the fuel rod design meet the constraints discussed below.

Analysis criteria and methods are applicable to both Zircaloy-4 and M5<sup>®</sup> cladding types as noted. The M5<sup>®</sup> cladding is approved for use in AREVA fuel in reference 18.

## **4.2.1 Shipping**

### **4.2.1.1 Analysis Criteria**

The spring system must limit gap formation in the fuel stack during transport up to an axial loading of [      ] .

### **4.2.1.2 Analysis Method**

## **4.2.2 Plenum Space**

### **4.2.2.1 Analysis Criteria**

The plenum space must be sufficient so that the spring-spacer system does not go solid with fuel stack swelling.

### **4.2.2.2 Analysis Method**

### **4.2.3 Corrosion**

#### **4.2.3.1 Analysis Criteria**

The fuel rod maximum acceptable predicted oxide thickness limit is [ ] (reference 9) for the maximum burnup fuel rod within each core sub-batch. A sub-batch is defined as fuel that is inserted and discharged from the core at the same time so the fuel assembly residence times are identical.

#### **4.2.3.2 Analysis Method**

### **4.2.3.3 Lead Corrosion Assemblies**

A lead test assembly program to continue collecting corrosion data at high burnups was approved in reference 9. The LTA program allows up to eight fuel assemblies in each fuel cycle to operate to corrosion levels in excess of the limit specified in

Section 4.2.3.1. Such assemblies are designated as lead corrosion assemblies. In a given fuel core, the total number of LTAs (lead corrosion assemblies plus other LTAs) will not exceed twelve.

The eight lead corrosion assemblies may come from different sub-batches, and these assemblies will typically reside in non-limiting core locations with respect to the relative power distribution during the cycle. Corrosion measurements will be taken on the lead corrosion assemblies after they are discharged from the core to verify the cladding corrosion model predictions.

### **4.2.4 Creep Ovality**

#### **4.2.4.1 Analysis Criteria**

Creep collapse of the cladding due to creep ovalization shall not occur during the incore life of the fuel rod.

#### **4.2.4.2 Analysis Method**




#### **4.2.5 Stress**

##### **4.2.5.1 Analysis Criteria**



#### **4.2.5.2 Analysis Method**



#### **4.2.6 Strain**

##### **4.2.6.1 Analysis Criteria**

The uniform transient strain (elastic and plastic) should not exceed [     ]. This strain is defined as the transient-induced deformation with gage lengths corresponding to the cladding dimensions.

#### **4.2.6.2 Analysis Method**



#### **4.2.7 Fatigue**

##### **4.2.7.1 Analysis Criteria**

The total fatigue usage factor for all Condition I and II events shall not exceed [     ] .


#### **4.2.7.2 Analysis Method**

### **4.2.8 Fuel Rod Pressure**

#### **4.2.8.1 Analysis Criteria**

The criterion used for internal pressure evaluations is that during normal operation the maximum internal fuel rod pressure shall not exceed the pressure that would cause (1) the fuel-clad gap to increase due to outward cladding creep during steady-state operation and (2) extensive DNB propagation to occur.

#### **4.2.8.2 Analysis Method**



## **4.2.9 Fuel Temperature (Centerline Fuel Melt) Limit**

### **4.2.9.1 Analysis Criteria**

The predicted maximum fuel temperature at a given rod average burnup value must be less than the melting temperature of the fuel type being evaluated ( $\text{UO}_2$  or gadolinia).

When the best-estimate TACO3 and GDTACO codes are used, the criterion is that the maximum predicted fuel temperature shall be less than or equal to  $T_L$ , a limit value chosen such that there will be a 95% probability at the 95% confidence level that centerline melting will not occur. When the best estimate COPERNIC code is used, the criterion is that the maximum predicted fuel temperature shall be less than or equal to the best estimate fuel melt temperature,  $T_m$ , reduced by the uncertainty in the COPERNIC centerline fuel temperature prediction.

#### **4.2.9.2 Analysis Method**



## **5.0 NUCLEAR DESIGN**

### **5.1 *Nuclear Design Codes***

All neutronic calculations described in this chapter are performed with NRC-approved design codes.

BAW-10180-A (reference 32) presents the NEMO methodology. The NEMO computer code calculates the three-dimensional core power distribution for each pin in a manner that accounts for individual pin burnup and spectral effects. NEMO also calculates control rod worth, and the reactivity effects of moderator density, fuel temperature (Doppler), and xenon. Cross section data supplied to NEMO is generated by CASMO-3 (reference 33).

BAW-10221P-A (reference 34) presents the NEMO-K methodology. NEMO-K is used where three-dimensional time dependent solutions are important. This methodology includes time-dependent solutions for neutronic, fuel temperature, and coolant properties. With the addition of the kinetics equations to the NEMO code, it can be used for static and kinetic solutions of steady state and transient problems, respectively.



## **5.2      *Fuel Cycle Design***

### **5.2.1    Final Fuel Cycle Design**

Establishing the final fuel cycle design (FFCD) is the initial portion of the reload safety evaluation for any cycle. The objective of the FFCD is to develop the core loading plan for the fuel, and, if applicable, burnable absorbers. The control rod safety and regulating group locations are also specified, although these do not usually change from cycle to cycle. The radial power distribution is the principal focus in the development of the core loading pattern. Other considerations are discharge burnup, MTCs, ejected rod worth, and shutdown margin (SDM). Although the general pattern of fuel loading is usually predetermined (e.g., in-in-out), the specific placement of the fresh and burned assemblies, and the location and amount of burnable absorbers provide the designer with some degree of control over these parameters. Other variables include the desired cycle length, number of fresh assemblies, and options for control rod group (CRG) 7 and APSR withdrawal, average moderator temperature reduction, and power coastdown.

#### **5.2.1.1    Acceptance Criteria**

1. The maximum calculated steady-state fuel rod relative power density (RPD) for the cycle shall be less than that required to meet the safety criteria and sufficiently low to indicate that acceptable operating limits can be achieved in the power distribution analysis described in Section 5.3. The radial power distribution is controlled by the fuel shuffle and placement of burnable absorbers.
2. The discharge rod burnup shall be less than the applicable limit for that fuel design. The limit is established by the fuel mechanical and thermal design considerations (see Section 4.0) and the most recent NRC-approved burnup limits (reference 9). Discharge burnup is controlled by the batch size selection for a given cycle length requirement, and the fuel shuffle pattern.

3. The design shall be capable of passing subsequent safety analysis checks described in Sections 5.4 and 8.0. These include moderator coefficients, ejected rod worth, and SDM among others. While licensing checks are typically not performed at the FFCD stage, preliminary calculations are made if it is judged that a particular parameter may be close to limiting based upon design changes or previous experience.

#### **5.2.1.2 Analysis Methods**







### **5.3      *Power Distribution Analysis***

#### **5.3.1      Axial Power Imbalance Protective Limits**

During power operation of the reactor core, General Design Criterion (GDC) 10 (reference 3.a) requires that the fuel not sustain damage as a result of normal operation or anticipated operational occurrences. Therefore, the reactor fuel and cladding must be designed and operated with appropriate thermal margin to assure that specified acceptable fuel design limits are not exceeded. In the design of reload cores it is assumed that immediate fuel damage will result if

1. Centerline Fuel Melting (CFM) occurs,
2. A Transient Cladding Strain (TCS) in excess of 1% occurs, or
3. Steady-state Departure from Nucleate Boiling Ratio (DNBR) limits are violated.

For normal operation and anticipated operational occurrences, fuel and cladding protection are provided by an automatic RPS trip function when the ratio of thermal power to reactor coolant flow reaches specified limits, or when axial power imbalance reaches limits specified during the reload safety evaluation. The RPS relies on the global quantities of thermal power level and axial power imbalance to provide the required trip function.

The trip on thermal power to reactor coolant flow (power-to-flow trip) is required to ensure that the DNB limiting criterion is not violated in steady-state with four reactor coolant pump or partial pump operation. The maximum power levels allowed by the trip setpoints are based on a power-to-flow ratio that has been established to accommodate flow-decreasing transients from high power levels. The power level trip setpoint produced by the power-to-flow ratio provides DNB protection from both high power level and low reactor coolant flow for all modes of reactor coolant pump operation. The flow-dependent portion of this trip function is established for design peaking conditions with zero imbalance.

The trip on design overpower (high flux trip) is required to ensure that the local LHR will not exceed either the CFM or TCS limiting criteria (this trip function does not vary the trip setpoint with changes in the core power distribution). The trip on axial power imbalance ensures that the CFM, TCS or DNB limiting criteria are not violated, taking into account variations in the axial power distribution that may occur as a result of core design features, fuel depletion, xenon distribution, and control component positioning.

#### **5.3.1.1 Acceptance Criteria**

To prevent cladding failure, the following safety criteria have been established:

1. The maximum local LHR anywhere in the core must be limited so that CFM does not occur.
2. The maximum local LHR anywhere in the core must be limited so that TCS is maintained below 1%.
3. There must be at least a 95% probability at a 95% confidence level that the hot fuel rod in the core does not experience a DNB condition.

The third criterion is referred to hereafter as the 95/95 DNB criterion. The minimum DNBR value during both normal operation and anticipated transients is limited to the DNBR analysis limit for the particular fuel design in use. The DNBR analysis limit meets the 95/95 DNB criterion and provides an appropriate margin to DNB for all operating conditions. Sections 6.2.8 and 6.2.9 contain a further discussion of DNBR analysis limits.


These acceptance criteria are met by constraining power operation within the RPS axial power imbalance protective limits during normal operation and anticipated operational occurrences. Operation within the RPS axial power imbalance protective limits ensures the maximum allowable LHR based on the CFM, TCS, and DNB peaking criteria will not be exceeded. The following analysis criteria must be preserved by the power distribution analysis:

1. The combination of thermal power and axial power imbalance may not produce a local LHR in excess of the LHR to cause CFM. Section 4.2.9 provides a further discussion of the CFM limit.
2. The combination of thermal power and axial power imbalance may not produce a local LHR in excess of the LHR to cause TCS to exceed 1%. Section 4.2.6 provides a further discussion of the TCS limits.
3. The combination of thermal power and axial power imbalance shall not produce local peaking in excess of the maximum allowable peaking (MAP) limits based on the DNB analysis. Section 6.6 provides a discussion of MAP limits.


#### **5.3.1.2 Technical Specification Limits**

The reactor trip based on the axial power imbalance protective limits prevents the maximum LHR, or the maximum local peaking factor, from causing a violation of the thermal design bases during normal operation and anticipated occurrences. Example axial power imbalance protective limits are shown in Figure 5-1. These protective limits must be error-adjusted to account for measurement system observability and equipment uncertainties. The method used to perform the error adjustment is described in Section 7.3. The axial imbalance protective limits and error-adjusted trip setpoints are specified in the COLR.

### **5.3.1.3 Analysis Methods**














### 5.3.2 Power Distribution-Related LCO Limits

This section addresses the methodology for determining the LCOs related to core power distribution. Limits on the following parameters and process variables are addressed:

- Regulating rod insertion, group sequence, and group overlap
- APSR insertion
- Axial power imbalance
- Quadrant power tilt

The LCOs imposed on control component operation and on monitored process variables ensure that core peaking is maintained within the nuclear heat flux hot channel factor,  $F_Q^N$  (or LOCA LHR limits), and the nuclear enthalpy rise hot channel factor,  $F_{\Delta H}^N$  (or initial condition DNB peaking limits). The  $F_Q^N$  and  $F_{\Delta H}^N$  limits may be expressed either in dimensionless peaking units or in LHR units. Operation within the  $F_Q^N$  limits given in the COLR prevents power peaks that would exceed the LOCA LHR limits derived by the ECCS analysis described in Section 9.0. Operation within the  $F_{\Delta H}^N$  limits given in the COLR prevents DNB during a loss of forced reactor coolant flow event.

In addition to the  $F_Q^N$  and  $F_{\Delta H}^N$  limits, certain reactivity limits are preserved by regulating RILs. The regulating RILs restrict the ejected control rod worth to the values assumed in the safety analyses and preserve the minimum required SDM. The reactivity related LCOs are described further in Section 5.4.2. Regulating rod position is measured by using the rod index, defined as the sum of the positions of groups 5, 6, and 7 in percentage withdrawn. Figure 5-3 illustrates the relationship of rod index to regulating bank position. The regulating rod groups operate with a predetermined amount of position overlap in order to approximate a linear relation between rod worth and rod position (integral rod worth). The regulating rod groups are withdrawn and operate in a predetermined sequence. The automatic control system limits reactivity by moving the regulating rod groups in their specified sequence within analyzed ranges.

### 5.3.2.1 Consequences of Exceeding Limit

The simultaneous occurrence of operation in violation of one or more of these LCOs with the postulated accident could result in (1) exceeding the maximum peak cladding temperature (PCT) of 2200°F, (2) a DNBR below the analysis limit, (3) an ejected rod worth greater than the values assumed in the safety analyses or (4) less than the minimum SDM specified in the Technical Specifications (typically 1%  $\Delta k/k$ ). The concern in exceeding the PCT limit is the failure of the cladding by the resulting Zircaloy-water reaction, which could become self-sustaining due to the extreme heat. The concern in exceeding the DNBR limitation is cladding failure due to overheating, which could occur if film boiling prevents efficient heat transfer to the reactor coolant. The concern in exceeding the ejected rod worth limit is fuel failure due to either DNB or fragmentation of the fuel and cladding if an ejected rod resulted in a fission energy release of more than 280 cal/g. The concern in exceeding the SDM limit is failure to shut down the reactor upon an RPS trip, or that the consequences of an accident may be greater than that determined by the safety analyses. In addition, exceeding any of these limits could require significant analyses and/or inspection to justify continued operation of the unit.

### 5.3.2.2 Acceptance Criteria

The reload safety evaluation methodology must demonstrate that a reasonable probability exists that the fuel design limits can be met and will not be exceeded for normal operation and anticipated operational occurrences over the fuel cycle length. The regulating rod insertion, APSR insertion, axial power imbalance, and quadrant power tilt LCOs preclude core power distributions from occurring that would violate the following fuel design criteria:

1. During a LOCA, the PCT must not exceed a limit of 2200°F (10CFR50.46, reference 3b).

2. During a loss of forced reactor coolant flow accident, there must be at least a 95% probability at a 95% confidence level that the hot fuel rod in the core does not experience a departure from nucleate boiling (DNB) condition (GDC 10, reference 3a).
3. During an ejected rod accident, the fission energy input to the fuel must not exceed 280 cal/g (GDC 28, reference 3c).
4. The control rods must be capable of shutting down the reactor with a minimum required SDM with the highest worth control rod stuck fully withdrawn (GDC 26, reference 3d).

These acceptance criteria preserve the accident initial condition assumptions in the safety analyses related to the core power distribution and reactivity. The regulating RILs, APSR insertion limits, axial power imbalance limits, and quadrant power tilt limits specified in the COLR are determined from power peaking and reactivity limits based on these criteria. These LCOs limit the amount of fuel cladding damage during a postulated accident by preserving these initial condition acceptance criteria. These LCO limits must meet the following analysis criteria:

1. The combination of thermal power, axial power imbalance; and regulating rod insertion, including the steady-state quadrant power tilt allowance, must not cause power peaking that would exceed the allowable nuclear heat flux hot channel factor ( $F_Q^N$ ) or the nuclear enthalpy rise hot channel factor ( $F_{\Delta H}^N$ ) limits.
2. The combination of thermal power and regulating rod insertion must not allow the worth of an ejected rod to exceed the values demonstrated to be acceptable in the safety analyses.
3. The combination of thermal power and regulating rod insertion must not allow the minimum SDM to be less than that specified in the Technical Specifications (e.g., 1%  $\Delta k/k$ ) at hot zero power (HZP), equilibrium xenon with the maximum worth control rod stuck fully withdrawn.


### **5.3.2.3 Technical Specification Limits**

A requirement of 10CFR50.36 (reference 3e) is that LCOs be placed on process variables required for safe operation of the plant. Regulating rod position (rod index), APSR position, axial power imbalance, and quadrant power tilt are process variables that together characterize and control the three-dimensional power distribution of the reactor core. Therefore, administrative limits are established for these variables during the reload safety evaluation, and they are monitored and controlled during power operation to ensure that the power distribution remains within the bounds set by the licensing analysis. If the LCO limits based on power peaking are violated, a short time is allowed for corrective action. However, if the LCO limits are not restored within a reasonably short time, a significant power reduction is required. Operation beyond the SDM RIL is treated differently because it is of common importance to the entire safety analysis. Therefore, immediate action to restore the SDM is required should the SDM RIL be violated.


### **5.3.2.4 Analysis Methods**











### 5.3.3 EOC Full Power Extension Maneuvers

Fuel cycle designs may include provisions for end-of-cycle (EOC) extension maneuvers to allow for continuing operation at rated thermal power at the end of a fuel cycle. EOC extension maneuvers typically include an EOC  $T_{avg}$  reduction and may be coupled with withdrawal of the APSRs. The effects of EOC  $T_{avg}$  reductions on the core power distribution have been evaluated to determine their impact on power peaking factors, and allowable values for the  $T_{avg}$  reduction have been defined. If the capability for an EOC  $T_{avg}$  reduction is designed into the reload core fuel cycle, the core protective and operating limits will be analyzed and set to accommodate its impact on margins to the core peaking limits, i.e., the protective and operating limits specified for the COLR will accommodate the EOC extension maneuver.

### **5.3.4 Xenon Stability Index**

The APSRs are positioned to provide both positive and negative imbalance control to compensate for shifts in the axial power distribution during transient conditions.

Utilization of the APSRs by the operator prevents or damps axial xenon oscillations, and controls transient imbalance during power level maneuvers. The APSRs are controlled manually by the operator and do not trip. When the APSRs are withdrawn, power oscillations can be damped by the regulating rods. The reactivity worth of the APSR group is lower than that of the regulating rod group (typically by a factor of approximately five). Therefore, axial power oscillations may be damped easily by manual positioning of the APSRs with little change in core reactivity.

#### **5.3.4.1 Acceptance Criteria**

APSRs were incorporated in the design of the nuclear steam supply system (NSSS) to prevent or damp axial power oscillations caused by xenon oscillations. The safety criterion addressed by APSRs is from GDC 12 (Suppression of Reactor Power Oscillations, reference 3f):

The reactor core and associated coolant systems shall be designed to assure that power oscillations which can result in conditions exceeding specified acceptable fuel design limits are not possible or can be reliably and readily detected and suppressed.

In reload core designs, the APSRs are inserted in the core for use in controlling the axial power distribution for up to 90% (typically) of the fuel cycle length. Then the APSRs may be withdrawn fully to remove their negative reactivity, so that the cycle may operate to a longer design length for a given fuel loading. For operation after APSR withdrawal, the following analysis criterion is applied in the power distribution analysis:

Axial power oscillations induced by an axial xenon oscillation shall be naturally damped.

If this criterion is not met, however, power restrictions are not applied. Instead, this result would be noted in the safety evaluation, and the regulating rods would be used to damp any induced oscillations, according to station procedures.

#### **5.3.4.2 Analysis Methods**

#### **5.3.5 Power Level Cutoff Hold Removal**

This section is only applicable to those units with a technical specification power level cutoff hold requirement.

The effects of peaking due to transient xenon are explicitly included in the power distribution analysis by direct simulation of limiting power distributions from cycle-specific xenon transients. The simulation of xenon transients as described in reference 36 is further augmented by APSR motion in a manner to generate conservative (higher) peaking factors.

Since all LCO limits are explicitly based on transient xenon data, a power level cutoff hold is not required and the power level cutoff hold value may be set to 100% of RTP.

### **5.3.6 Overcooling Transient**

Overcooling events cause a reduction in reactor coolant inlet temperature. The potential temperature-induced measurement error in the indicated excore neutron power (utilized by the RPS) for some overcooling transients may exceed the value assumed in the safety analyses. Such a condition could cause the actual thermal power level to exceed design overpower without causing a reactor trip, resulting in the potential for CFM, TCS or DNB safety limits to be violated.

#### **5.3.6.1 Acceptance Criteria**

The applicable safety criteria are prevention of violating CFM, TCS, and steady-state DNB safety limits, as specified in Section 5.3.1.1. To ensure that the power distribution limits will preserve the safety criteria, the following analysis criterion is applied in the power distribution analysis:

CFM, TCS, and steady-state DNB peaking margins from power distributions that simulate the overcooling transient shall not violate the CFM, TCS, and steady-state DNB safety criteria.

### **5.3.6.2 Analysis Methods**

### **5.3.7 Inoperable Control Rods**

Inoperable control rod assemblies (CRAs) comprise dropped or misaligned CRAs. These events potentially result in increased power peaking factors. Since inoperable control rods are moderate frequency events, the RPS must prevent the core power distribution from exceeding the core safety limits during those events.


#### **5.3.7.1 Acceptance Criteria**

The applicable safety criteria are prevention of violating CFM, TCS, and steady-state DNB safety limits, as specified in Section 5.3.1.1. To ensure that the power distribution limits will preserve the safety criteria, the following analysis criterion is applied in the power distribution analysis:

CFM, TCS, and steady-state DNB peaking margins from power distributions that simulate single inoperable CRA events shall not violate the CFM, TCS, and steady-state DNB safety criteria.



#### **5.3.7.2 Analysis Methods**



#### **5.4      *Nuclear Parameters for Safety Analysis***

This section describes the methodology used to determine the nuclear parameters that ensure that the safety analyses for the reactor remain valid for the reload cycle. The safety analyses refer to calculations and evaluations performed for the Accident Analysis chapter in the Final Safety Analysis Report (FSAR) and any updates or revisions, hereafter referred to as the Safety Analysis Report (SAR). The methodology supports reload safety evaluations for all Mark-B fuel.

The description of the methodology is divided into four parts, Sections 5.4.1 through 5.4.4. This division is related to the organization of the reload report and the safety evaluations performed for the reload. Section 5.4.1 reviews the procedures for determining the key transient neutronic parameters impacting the safety analyses. This leads into Section 5.4.2, which presents the reactivity related LCOs. Section 5.4.3 describes how radiation parameters, which are important in the source term evaluation, are modeled. Section 5.4.4 addresses the analytical methods employed in developing the actual fuel loading pattern.

Reference 23 addresses the nuclear aspects that are affected by the repair of fuel assemblies with stainless steel replacement rods.

The NRC concurred in reference 84 that the topical report BAW-2149A is applicable to the use of stainless steel rods in fresh (i.e. unirradiated) fuel assemblies.

#### **5.4.1 Transient Neutronic Parameters**

The safety analysis evaluations performed for the accidents in the SAR assumed values for the neutronic parameters related to the reactivity coefficients and worths, control system reactivity, kinetics, and transient power peaking. When the accidents were analyzed, parametric cases were evaluated to determine the combination of conditions and the key neutronic parameters that would produce the most severe transients. The resulting limiting conditions, and bounding values of the key neutronic parameters, are the ones that must be analyzed for each reload cycle. The methodology used for the reload analysis must consequently ensure that the calculations of the key neutronic parameters are performed with the appropriate limiting conditions. The results are then reviewed using the methods described in Section 8.0 to ensure that the values are bounded by those used in the safety analyses. If the reload calculations contain the proper conditions, and the results are within the bounds of the reference safety analysis, then the SAR results will continue to be applicable to each respective reload cycle.

##### **5.4.1.1 Acceptance Criteria**

1. The key neutronic parameters shall be determined using the appropriate limiting conditions. The key neutronic parameters are then reviewed using the methods described in Section 8.0 to ensure that the values are bounded by those used in the safety analysis.
2. Design changes shall be reviewed with respect to the accident scenarios in the safety analyses to ensure that the change does not affect the scenario for defining the appropriate limiting conditions for calculating the neutronic parameters.

#### **5.4.1.2 Analysis Methods**





#### **5.4.2     Reactivity-Related LCOs**

The reactivity-related LCOs are those associated with the control systems. The LCOs are divided into two categories. The first category, and the one that is more complex, is that dealing with the SDM. The second category deals with the ejected rod. The methodologies used to analyze the SDM and the ejected rod are very similar. However, to clarify the discussion, the methodology for analyzing each will be described separately. The SDM discussion is further divided into two areas. The first is the control rod system and the second is the boron injection system.

The methodology for determining the reactivity-related LCOs is based on the control system requirements for specific reactivity margins. These requirements are part of the bounding conditions assumed in the safety analyses for the accidents in the SAR. In order to ensure that the required safety margins are always applicable for the various operating modes of the reactor, many control system requirements have been incorporated into the technical specifications.

#### **5.4.2.1 Shutdown Margin**


The accident analyses chapter in the SAR assumes that following a reactor trip the reactor will have a minimum amount of SDM. In fact, whenever the reactor is shutdown, the accident analyses contain the assumption that prior to criticality in the startup operational mode, the reactor will have a minimum SDM. The control rod system and the boron injection system are the two independent systems that ensure that the SDM can always be met. RILs and boron concentration requirements are determined each cycle to preserve the minimum SDM assumption in the safety analyses.


##### **5.4.2.1.1 Acceptance Criteria**


1. Limits on the allowed rod index versus power level will be determined each reload to ensure that the SDM obtained with the worth of the scrammable control rods is equal to or greater than that assumed in the safety analyses (e.g., 1%  $\Delta k/k$  with the most reactive rod stuck out of the core), including uncertainties.
2. Boron concentration requirements as a function of temperature will be determined for each reload to ensure that the SDM obtained using the boron injection system is equal to or greater than that assumed in the safety analyses (e.g., 1%  $\Delta k/k$  with the most reactive rod stuck out of the core), including uncertainties.
3. Design changes that affect the control rods, boron worth, or boron injection system shall be reviewed or analyzed to ensure that they are within the bounds of the safety analyses.



#### **5.4.2.1.2 Analysis Methods**








#### **5.4.2.2 Ejected Rod Worth**

The methodology for evaluating the ejected rod worth is based on the rod ejection accident presented in the accident analyses chapter in the SAR. The LCOs are based on the safety requirements that establish bounding parameters that limit the consequences of the accident.

##### **5.4.2.2.1 Acceptance Criteria**

Rod insertion limits versus power level will be determined each reload to ensure that the ejected rod worths are equal to or less than the values demonstrated to be acceptable in the safety analyses, including uncertainties.

##### **5.4.2.2.2 Analysis Methods**



### **5.4.3 Radiation Parameters**

Of the results determined for each of the accidents analyzed in the SAR, the dose consequences are the most important. If there is no increase in the environmental doses from radiation sources following an accident, then the consequences of the accident are of minor importance to the health and safety of the public. The methodology for evaluating the nuclear parameters relating to development of radiation sources is discussed in this section.

#### **5.4.3.1 Acceptance Criteria**

The radiation sources are primarily fission products produced in the fuel during power operation. Other sources include materials other than the fuel that are irradiated during operation and become radioactive. Fission products and other radiation sources are not specifically a part of the nuclear parameters evaluated in the nuclear design analysis (Section 5.0). However, the sources are analyzed and evaluated for each reload as described in Section 8.0. The accident analysis review assesses the maximum possible doses from the various accidents for each reload by determining the sources from the nuclear parameters. These parameters are those such as burnup, fluences, uranium, and plutonium fissions, etc. Therefore, the methodology relates to calculation of these types of parameters. The acceptance criteria for the 50.59 licensing procedure integrate the nuclear design methodology with the accident analysis review.

1. The methodology and applicable uncertainties for analyzing the nuclear parameters that lead to the radiation sources shall not be changed without verifying the changes are within acceptance criterion 8 of Section 8.2.

2. Design changes that could affect radioactive sources shall be reviewed and analyzed.


#### **5.4.3.2 Analysis Methods**

#### **5.4.4 Fuel Loading**

Loading the fuel into the core for the reload cycle is simulated during the fuel cycle design process by assuming all fresh fuel is uniformly loaded. In addition, the burned fuel is assumed to have been uniformly loaded initially and to have burned uniformly in the quarter-core. However, during power operation, the fuel may not accumulate exactly symmetric burnup because (1) the manufacturing process creates non-uniformities in the fuel and burnable poison loadings and (2) non-uniformities in the operational characteristics of the core create tilts that lead to non-uniform burnup.

**5.4.4.1 Acceptance Criteria**

Fuel, burnable poison or other components that could induce a radial power asymmetry shall either be loaded into the core to ensure that there is no impact on the power distribution or specifically analyzed.

**5.4.4.2 Analysis Methods**

## **5.5      *Startup Physics Testing***

The purpose of the design analyses of the reload cycle is to ensure that the reference safety analyses remain applicable. The nuclear design analyses are based on modeling the core characteristics using the methods, procedures, and computer calculations described in Sections 5.1, 5.2, 5.3, and 5.4 of this report. The results of the design analyses show that bounding peaking distributions and bounding nuclear parameters are within the criteria required by the safety analyses. However, there remains an uncertainty related to the accuracy of the design calculations and modeling of the reload cycle characteristics relative to actual measurements. Reload startup physics testing is performed following refueling outages to verify that the core is operating as designed.

The previous cycle design predictions are benchmarked to startup test measurements, and core-follow calculations of the power distributions are benchmarked to measured data. The previous cycle is the reference cycle for the reload core design. If there are no design changes or changes to the manufacturing specifications, then the conclusion could be reached that the design calculations are completely satisfactory to ensure that the safety parameters have been accurately analyzed. This conclusion is further supported by the topical reports on the computer codes, methods and procedures, and uncertainties, which have shown that the design analyses are sufficiently accurate.

However, prudence suggests that some amount of startup physics testing is important to ensure that the safety evaluations are valid. A small probability exists that the calculations will have larger-than-expected deviations simply because the calculational accuracy was established statistically. A small probability also exists that loading or manufacturing deviations may occur. Thus, a startup testing program is part of the reload evaluation process for the nuclear analysis.



### 5.5.1 Acceptance Criteria

The previous subsections in this nuclear design section have discussed the methodology for performing design analyses to ensure that the characteristics of a reload cycle are bounded by the reference safety analyses. The methodology referenced the calculational codes, models, and procedures that are used to determine the nuclear parameters. The same calculational codes, models, and procedures must be revalidated during the startup of each reload cycle by performing a minimum amount of startup physics tests which compare the resulting measured values to calculational predictions. Design calculations, using the calculational codes, models, and procedures that were used to verify that the nuclear parameters are bounded by the reference safety analyses, shall model startup conditions to produce predictions that can be compared to measurements.

Startup testing requirements should meet the requirements of ANSI/ANS 19.6.1 (reference 42).

The standard startup physics testing scope for B&W-designed plants complies with ANSI/ANS 19.6.1 (reference 42) with the following exceptions:

1. Reference 42 specifies that if the boron dilution method for determining HZP measured rod worth is employed, then measurement of all control rod groups, or at least 3000 pcm is required. AREVA has justified a ZPPT program that includes only measurement of CRG 7 (partial – at least 80% of the worth of CRG 7 is measured) and CRG 6. This is typically at least 1500 pcm.
2. Reference 42 suggests (the appropriate specification is contained in the Appendix, which is technically not part of the Standard) that the endpoint worth for CRG 7 is measured for the boron equivalent correction to the measured all rods out critical boron concentration (AROCBC). AREVA has justified that up to 200 pcm predicted worth can be used for this correction.

3. Reference 42 requires a measured differential boron worth and application of a test criterion to a comparison of measured to predicted values. AREVA has developed a modified differential boron worth measurement technique not included in the Appendix of reference 42. Rather than eliminate the measurement of differential boron worth entirely, this new technique is employed with the results as information only (no test criterion is applied).

These exceptions are discussed in the NRC-approved topical report on ZPPT modifications for B&W-designed reactors (reference 81). The current minimum scope of reload startup physics testing for B&W-designed plants is contained in Table 5-2.


#### **5.5.2 Analysis Methods**




### Table 5-1 Example Calculation of the Shutdown Margin


**Table 5-2 Reload Startup Physics Testing for B&W-Designed Plants**

| Test   | Acceptance Criterion   | Notes   |
|--|--|---|
| HZP AROCBC                                       | $\pm 50$ ppm -- Acceptance<br>(Predicted – Measured)<br>$\pm 45$ ppm -- Review*    | Up to 200 pcm predicted worth of CRG 7 allowed for endpoint correction.<br>* Only applied if predicted worth used.                                      |
| Isothermal Temperature Coefficient (ITC)         | $\pm 2$ pcm/°F<br>(Predicted – Measured)   |   |
| Moderator Temperature Coefficient                | < Tech Spec Limit  | Measured MTC inferred from measured ITC by application of predicted Doppler coefficient.  |
| Individual CRG Worths                            | $\pm 15\%$<br>$\% \text{ dev} = \{(P-M) / P\} * 100\%$                             | At least 80% of CRG 7 and all of CRG 6. (Consistent with reference 81)  |
| Total CRG Worth                                  | $\pm X \%$<br>$\% \text{ dev} = \{(P-M) / P\} * 100\%$                             | X = SDM related uncertainty on rod worth - always between 5-10%, depending on fuel cycle.   |
| Differential Boron Worth                         | No criterion applied   | Ratio of measured rod worth to measured boron differences during CRG worth measurements.  |
| Flux Symmetry Test                               | Tilt   < full power limit<br>Symmetric incore detector readings within $\pm 10 \%$ | Both of these criteria are considered "review criteria". Evaluation should be accomplished before physics testing is performed at a higher power level. |
| Intermediate Power Level Core Power Distribution | Several specific acceptance criteria apply, including the criteria in reference 42 | Between 40-80 %FP.  |
| HFP AROCBC                                       | $\pm 50$ ppm   | Difference between the HZP AROCBC (P – M) $\Delta$ and the HFP AROCBC (P – M) $\Delta$ .  |
| HFP Core Power Distribution                      | Several specific acceptance criteria apply, including the criteria in reference 42 | Between 90-100 %FP.   |

**Figure 5-1 Example Axial Power Imbalance Protective Limits**

**Figure 5-2 Example Centerline Fuel Melt vs. Offset Correlation**

**Figure 5-3 Rod Index and Regulating Bank Position Relationship**  
**(Typical 25% Overlap Shown)**





## 6.0 CORE THERMAL HYDRAULICS

### 6.1 *Design Criteria*

The DNBR safety criterion is that there shall be at least a 95% probability at a 95% confidence level that the hot fuel rod in the core does not experience a departure from nucleate boiling during normal operation or events of moderate frequency (Condition I or II events). The approach used to ensure that this criterion is met is to apply a corresponding design criterion, which is that the minimum predicted DNBR, using an appropriate critical heat flux (CHF) correlation and computer code, that must be greater than or equal to the DNB design limit value for that correlation. The DNB design limit for each correlation is the DNBR value for which there is a 95% probability at the 95% confidence level that DNB will not occur. Therefore, an alternate protection statement is that 95% of the rods at the DNBR design limit will not experience DNB, with 95% confidence. An appropriate CHF correlation is defined as one that has been approved by the NRC for application to the fuel design type being analyzed. Appropriate computer codes include those approved for use with the CHF correlation being applied. For the B&W 177-FA plants, the approved CHF correlations include B&W-2, BWC, BHTP, and the BWU series (references 44, 45, 4, and 46). The B&W-2 and BWC correlations have been approved for use in the TEMP, LYNX1/LYNX2, and LYNXT (references 47, 48, 49 and 50) codes. Typical DNB design limits are 1.30 for B&W-2 and 1.18 for BWC. The BHTP and BWU series CHF correlations have been approved for use in the LYNXT code. The BWU-N CHF correlation, in the BWU series, is limited to fuel assemblies that have no mixing vane spacer grids (reference 46). The BWU-Z correlation, in the BWU series, is limited to the Mark-B fuel design utilizing mixing vane spacer grids, currently known as the Mark-B11 (references 51 and 52). The BHTP correlation is limited to fuel assemblies utilizing HTP spacer grids (reference 4).

The second criterion addressed in the thermal-hydraulic analyses is that the worst case hydraulic loads should not exceed the hold down capability of the fuel assembly (weight plus hold down spring capability) during Condition I and II events. This criterion is also discussed in Section 4.1.3.

## **6.2      *Analysis Methods***

This section describes the codes and general methods used for core hydraulics and thermal-hydraulics analyses. Analysis techniques associated with specific calculations are discussed in the following sections.

### **6.2.1      *LYNX Codes***

The LYNX code series is composed of three codes, i.e., LYNX1, LYNX2, and LYNXT, all of which have received NRC approval (topical reports BAW-10129-A, BAW-10130-A, and BAW-10156P-A, respectively). These codes calculate fluid conditions and CHF for normal and abnormal operating conditions. Mass and turbulent energy interchange between channels are calculated for both steady-state and transient analysis. Steady-state analyses are performed either with LYNX1 and LYNX2, used in tandem, for a two-pass simulation of the reactor core, or with a single-pass LYNXT model. For transient analysis, the LYNXT code calculates fluid conditions, CHF, cladding temperature, fuel pin pressure, and fuel temperature as a function of time.

Each of the LYNX codes has been verified by benchmarking to appropriate test data and to other thermal-hydraulic codes. The three codes have a common set of fluid property relations and use the same void and heat transfer correlations, thus promoting consistency among themselves. LYNX1 has been benchmarked to experimental crossflow data, to incore temperature distribution measurements from Oconee 1 and Zion 1, and to other codes, with excellent results. LYNX2 has been compared with experimental diversion crossflow tests, with experimental CHF data, and with other codes, again with excellent results. LYNXT has been compared to the experimental data used in the LYNX1 and LYNX2 benchmarking as well as to other CHF data. Since the prediction of CHF is dependent on both the thermal-hydraulic code and the CHF correlation performance, LYNX2 and LYNXT have been qualified independently for each CHF correlation by analysis of its database; in each case where this evaluation has been performed, both codes support the licensed DNBR limit. In addition, since LYNXT has transient analysis capability, this code has been benchmarked to transient

CHF data. The transient analysis demonstrated that the code, with the B&W correlation form, provides a conservative predictor of transient CHF data.

Typical models used with the LYNX codes for core thermal-hydraulic analysis of the B&W 177-FA plants are described in reference 53.

#### **6.2.1.1 LYNX1**

The LYNX1 code performs the steady-state thermal and hydraulic analysis of the reactor core coolant on an assembly basis by solving a set of one-dimensional conservation equations for mass, momentum, and energy. Each individual fuel assembly is taken as a unit in the reactor cross-sectional plane, with the core being divided into a finite number of axial increments. Using an iterative solution method, the program can determine the inlet pressure profile of the reactor core when given an inlet velocity profile. The required boundary condition for the solution is a known exit pressure profile. The program is also capable of determining the inlet velocity profile of the reactor core when given an inlet pressure profile with the same boundary condition. The calculation can be made at full power or at any fraction of the RTP. Inter-assembly diversion crossflow is accounted for in the analysis. LYNX1 is closely related to the subchannel thermal-hydraulic analysis code LYNX2, which takes the calculated inter-assembly crossflow obtained from the LYNX1 solution and performs the thermal-hydraulic analysis on the subchannel basis within an assigned fuel assembly.

LYNX1 is used to predict pressure drop and flow distributions, including diversion crossflow, on a core-wide basis. The core is modeled as a number of parallel, open channels, with each channel representing a single fuel assembly, or a portion of an assembly. A typical model, shown in reference 53, represents 1/4 of the core and extends from below the lower core support plate up to and including the upper grid assembly. Both recoverable and unrecoverable (friction, form-loss) pressure drops are calculated at each axial node. Form-loss coefficients are derived from fuel assembly flow tests in which pressure drop for each component and for the fuel assembly as a whole are measured as a function of flow rate. For DNBR calculations, inter-assembly

diversion crossflow at the boundaries of the limiting, or "hot" assembly, are output to the LYNX2 code.

#### **6.2.1.2 LYNX2**

The LYNX2 code calculates subchannel conditions by conserving mass, momentum, and energy. Inter-subchannel diversion crossflow is determined from transverse pressure differences. Inter-subchannel turbulent interchange and inter-bundle diversion crossflow are also incorporated in the solution. LYNX2 has evolved from COBRA but has been modified to accept up to 324 sub-channels and 289 fuel rods. For each subchannel, the code allows for the description of geometry, location, area, and gap variations, and hot channel factors. For each rod, the code allows for the description of the geometry, location, radial power factor, and axial flux shape. As many as five engineering hot channel factor sets may be input, and axial heat flux shapes may be defined by using polynomials or section sets, or generated internally. Ten form-loss regions may be modeled using position, length, loss coefficient, and area contraction ratio. Turbulent interchange proportionality factors may be input as a function of quality. CHF ratios may be calculated using any of the current CHF correlations.

LYNX2 is typically used to model an individual fuel assembly, on a subchannel basis, incorporating the pin-by-pin power distribution. LYNX2 accepts the LYNX1-predicted crossflow distribution predicted at the boundaries of the fuel assembly and predicts subchannel mass flow, enthalpy, and DNBR distributions. Figures 2-6 and 2-7 of reference 53 show the subchannel and fuel rod numbering scheme and the pin-by-pin peaking distribution, respectively, for a typical full-bundle LYNX2 model.

### 6.2.1.3 LYNXT

LYNXT is a versatile thermal-hydraulics crossflow code capable of predicting flow and temperature distributions within the reactor core. The code has the ability to handle a wide range of reactor flow problems, from inter-bundle to inter-subchannel and is ideally suited to one-pass reactor core analyses. In a one-pass analysis, subchannels, groups of subchannels, bundles, and groups of bundles are modeled in one computer simulation. LYNXT is also able to provide an accurate representation of fuel temperature predictions from sophisticated fuel performance codes such as TACO2 (reference 54). The excellent convergence stability and accurate fuel rod modeling of LYNXT permit the analysis of a wide range of reactor transients, from the relatively slow loss-of-coolant-flow (LOCF) accidents to the rapid asymmetric control rod assembly ejection accident. LYNXT, originally based on the COBRAIV-1 code, has the following features not found in COBRAIV-1: a direct solution of the crossflow equation, convergence enhancements to the crossflow equation, a more extensive CHF library, an option for code-generated water thermal properties, and a dynamic gap conductance fuel model.

LYNXT provides the capability for single-pass core thermal-hydraulic analysis for both steady-state and transient conditions. For steady-state performance analyses, LYNXT is typically used in relatively small model configurations (see Figure 2-9 of reference 53, for example) to predict DNBR response to variations in external parameters such as RCS flow, pressure, temperature, and reactor power. The methodology used to develop single-pass LYNXT models has been qualified by the benchmarking of a number of different models to two-pass LYNX1/LYNX2 analyses and is described in BAW-10156P-A. Each new model that is developed is tested by benchmarking either to a more detailed single-pass model that has been compared to LYNX1/LYNX2 or by direct comparison to the LYNX1/LYNX2 calculations. For transients, LYNXT is also used to predict DNBR response, either from state-point analyses, or by simulating the actual core transient. LYNXT includes three different fuel rod models, which provide different levels of sophistication in modeling to accommodate the need for the analysis of different types of transients. Transient inputs can include core inlet flow velocity and temperature (or enthalpy), core exit pressure, and either neutron or thermal power. Both radial and axial power distributions can also be varied during a transient.

The LYNXT topical report BAW-10156P-A (reference 50) incorporates the Pressure-Velocity Implicit Numerical Solution (PV) algorithm. The PV algorithm provides a supplemental solution technique that can be used as an alternative to the original (COBRAIV-1) implicit algorithm. This solution technique is very useful for the analysis of transients that are characterized by low coolant flow rates.

### 6.2.2 Power Distribution

Reference core DNBR analyses are performed with a design radial power distribution, for which the maximum radial-local peaking factor ( $F_{\Delta H}^N$ ) increases with decreasing power level. A typical value of  $F_{\Delta H}^N$  versus power is given by

$$F_{\Delta H}^N = 1.80 * (1 + 0.3 * (1-P))$$

where P is the fraction of RTP.

The design axial power distribution is typically a 1.65 symmetric chopped cosine shape.

### **6.2.3 Engineering Hot Channel Factors**

Engineering hot channel factors are used to account for the effects of manufacturing variations on DNBR predictions. In addition, the local heat flux hot channel factor is used to account for variations in local LHR. The individual factors are discussed below.

#### **6.2.3.1 Local Heat Flux Factor**

The local heat flux factor,  $F_q$ , accounts for the effects of variations in fuel pellet  $U^{235}$  content and is used to evaluate the maximum LHR. This factor is determined by statistically combining manufacturing tolerances and/or as-built data for the fuel pellet enrichment and weight. [

] As discussed in references 55 and 56, no DNB penalty need be taken for relatively small local heat flux spikes, therefore this factor is not required for DNBR calculations.

#### **6.2.3.2 Statistical Hot Channel Factor on Average Pin Power**

The statistical hot channel factor on average pin power,  $F_q$ , accounts for the effects of manufacturing variations on the total  $U^{235}$  per fuel rod. This factor is determined by statistically combining manufacturing tolerances and/or as-built variations in average enrichment and fuel stack weight. [

]  $F_q$  is incorporated directly in DNBR analyses as a multiplier on hot pin heat generation rate.

### 6.2.3.3 Flow Area Reduction Factor

The flow area reduction factor,  $F_A$ , accounts for the effects of variations in fuel rod pitch and diameter. The factor is developed by statistically combining the effects of variations in pitch and diameter on subchannel flow area. [

] Although this factor includes axial variation effects,  $F_A$  is conservatively applied in DNBR calculations as a flow area reduction over the entire length of the affected subchannel.

### 6.2.4 Reactor Core Coolant Flow

The reactor core coolant flow, or the flow available for heat transfer, is equal to the RCS flow minus the core bypass flow. The core bypass flow fraction has several components that are fixed by the NSSS design (direct inlet to outlet nozzle leakage, vent valve seepage and core barrel leakage) and has two components that are dependent on the fuel design (the shroud gap flow, which is the flow between the outer edges of the peripheral assemblies and the core baffle wall, and the flow through the control rod guide tubes and incore instrument tubes).

#### 6.2.4.1 Reactor Coolant System Flow

For core thermal-hydraulic (DNBR) analyses the minimum RCS flow from technical specifications is used with the maximum bypass flow fraction to produce the minimum core flow used for design purposes.

For core pressure drop calculations, RCS flow and bypass flow are parameterized to span the range from minimum to maximum core flow. The pressure drop is typically reported for the flow conditions used in the core DNBR calculations (minimum flow).

For fuel assembly lift calculations, the maximum RCS flow is used with a minimum bypass flow fraction to produce the maximum core flow.



#### **6.2.4.2 Core Bypass Flow Fraction**

The fuel-dependent components (shroud gap and guide tube bypass flow) of the core bypass flow fraction are determined for each fuel design. The guide tube bypass flow fraction typically varies with reload core designs. The core designs for the B&W 177-FA plants do not use plugging devices in the control rod guide tubes of unrodded assemblies. Burnable poison rod assemblies (BPRAs) are used in some assemblies to provide reactivity hold down, and the BPRA rodlets, which are inserted in the control rod guide tubes, function effectively as plugging devices in those assemblies. In assemblies with neither control rods nor BPRAs, the guide tubes are unplugged. The number of BPRAs, and consequently the number of unplugged guide tubes, varies from one cycle to another, depending on nuclear design requirements. The guide tube bypass flow fraction is determined as a function of the number of unplugged guide tubes and defines the total core bypass flow fraction for a given core configuration.

[

] The

bypass flow fraction (or the corresponding number of unplugged guide tubes) is one of the significant parameters that must be checked for each reload cycle to determine applicability of the reference analysis.

#### **6.2.5 Core Inlet Flow Distribution**

The reactor vessel internals are designed to provide a relatively uniform inlet flow distribution to the core. Two flow regions are defined: the interior and peripheral regions. The interior region assemblies, which are those locations not on the core periphery, have a slightly greater-than-average inlet flow.

Thermal-hydraulic analyses using either the LYNX1/LYNX2 or LYNXT codes assume a uniform inlet flow distribution core-wide [

] The magnitude of the core inlet flow factor is based on a vessel model flow test (VMFT) that was performed on a 1/6 scale model of a reactor vessel and core (reference 57).

Fuel assembly hydraulic lift analyses use the flat inlet flow velocity assumption [

].

#### 6.2.6 Fuel Rod Bowing

The bowing of fuel rods during reactor operation has the potential to affect both local power peaking and the margin to DNB. Prediction of bow magnitudes and effects is performed with the methods of reference 10. Using these methods, no DNBR penalty due to rod bowing is applied to AREVA fuel, [

].

### 6.2.7 Fuel Densification Effects

The phenomenon of in-reactor fuel densification causes an initial shrinkage of  $\text{UO}_2$  fuel pellets, which is counter-acted by thermal expansion of the pellets as they are heated up and later overcome by the effects of irradiation-induced swelling. The concerns associated with densification are stack height shrinkage and the effects of inter-pellet gaps caused by the shrinkage.

The formation of inter-pellet gaps due to densification and pellet hang-up can lead to the occurrence of power spikes in adjacent fuel rods. This was a concern in the early 70's, based on evidence of gap formation that occurred in unpressurized, low density fuel at R. E. Ginna. Since that time, industry-wide changes in fuel designs have been made to increase the fuel density, reduce the propensity for densification, and prepressurize the rods. These changes have reduced the probability of inter-pellet gap formation significantly. [

] Thus, the occurrence of power spikes resulting from densification-induced gaps need not be considered.

### 6.2.8 DNB Design and Analysis Limits

In order to demonstrate that the DNBR criterion is met, DNBR calculational results are compared to a DNB design limit value. A DNB design limit is established for each CHF correlation.

DNBR values greater than the DNB design limit ensure operation within the nucleate boiling regime, where the heat transfer coefficients are very large and, consequently, the cladding surface temperature remains close to the coolant saturation temperature. In order to define the limits of the nucleate boiling regime, CHF correlations are developed to predict the upper boundary, known as the critical heat flux, or the departure from nucleate boiling heat flux. For each CHF correlation a DNB design limit is established, based on its applicable data base, such that 95% of the rods at the DNBR design limit will not experience DNB, with 95% confidence.

In the establishment of core safety limits, the criterion used is that the minimum DNBR shall be greater than or equal to the DNB design limit. In order to reserve margin in the safety limits and safety analyses, a DNB analysis limit may be used in place of the design limit. This reserved margin may then be used to offset small penalties, such as transition core effects or differences in core bypass flow (due to changes in the configuration of plugged versus unplugged control rod guide tubes), or to provide core design flexibility. The reserved margin, expressed as a percentage relative to the design limit, is calculated as follows:

$$\text{Reserved Margin (\%)} = \frac{\text{DNB}_{\text{analysis limit}} - \text{DNB}_{\text{design limit}}}{\text{DNB}_{\text{design limit}}} \times 100\%$$

### **6.2.9 Statistical Core Design**

The design philosophy for core departure from nucleate boiling protection described in other parts of Section 6.0 follows a deterministic approach where uncertainties that affect the minimum DNBR are simultaneously assumed to be at their worst-case values. The minimum core DNBR is calculated using compounding of the uncertainties, for comparison with the DNBR design limit associated with the applicable CHF correlation.

A more realistic assessment of core DNB protection, called Statistical Core Design (SCD), has been developed by application of statistical techniques to treat the core state and bundle uncertainties. SCD is a widely accepted method that is utilized to reduce some of the undue conservatism of traditional methods, while still allowing for the traditional compounding of variables not amenable to statistical treatment.

BAW-10187P-A (reference 62) describes the application of SCD methodology to the analysis of B&W 177-FA plants operating with Mark-B fuel. A response surface model was used to obtain an overall uncertainty on the calculated DNBR. The response surface model was based on a full central composite design method in order to reduce uncertainty in the response surface model fit. The uncertainty distribution for each of the applicable variables was subjected to a Monte Carlo propagation analysis to determine an overall statistical DNBR uncertainty, which was used to establish a Statistical Design Limit (SDL). The SDL is higher than the CHF limit upon which it is based, because it contains allowances for all of the propagated uncertainties as well as the uncertainty on the original CHF correlation. When the minimum DNBR is calculated, the variables treated statistically are entered into the LYNXT thermal-hydraulic calculations at their nominal levels. Variables not treated in deriving the SDL continue to be entered at their most adverse allowable levels.

Generic uncertainty allowances included in the SCD methodology for the B&W 177-FA plants are described in reference 62. Plant-specific verification of these allowances or determination of new allowances to be used with this method is performed for each application.

The SDL, defined in reference 62, provides 95% protection at a 95% confidence level against hot pin DNB. The corresponding core-wide protection on a pin-by-pin basis using real peaking distributions is greater than 99.9%. Thus, adequate core DNB protection is assured and quantified.

The SDL approved for the conditions described in reference 62 is [        ]. This value is based on Appendix F of that topical report. Appendix F of reference 62 describes determination of an SDL that is conservative for all axial power shapes, including axial power distributions that cause the minimum DNBR to be located at or near the core exit (core exit-limited cases). AREVA determined that a hot pin SDL of [        ] bounds all cases, including core exit-limited cases, and provides a limiting hot pin 95% protection at a 95% confidence level against DNB for the uncertainties in Tables 3-5 and 3-6 of reference 62. Plant-specific SDL values are determined using the approved methodology of reference 62 to address changes in uncertainties and fuel designs.

The thermal design Limit (TDL) defined in Appendix F of reference 62 represents a retained DNB margin. The retained margin is available to offset penalties, such as transition core effects, or deviations in uncertainty values from those incorporated in the SDL, or to provide flexibility in the fuel cycle design.

Section 6.6 describes the development and generation of MAP limits. MAP limits provide linkage between the DNBR analyses, which use design peaking distributions, and the core power distribution analysis described in Section 5.3. The MAP limits are used in DNB peaking margin calculations that determine the core protective and operating limits. SCD-based MAP limits are calculated with the methodology described, however, their generation is based on equivalence to the TDL, i.e., the SDL plus retained margin, instead of equivalence to the base CHF correlation limit. The calculation and application of SCD-based MAP limits in licensing evaluations will remain as described in this report. When DNB peaking margins are calculated, specific allowances will continue to be made for those factors not included in the SDL/TDL limit.

### **6.3      *Fuel Assembly Hydraulics***

#### **6.3.1    Fuel Assembly Lift**

In order to preclude fuel assembly liftoff during normal operation, the maximum predicted uplift force on the most limiting assembly must be demonstrated to be less than the minimum fuel assembly hold down capability during limiting operating conditions.

Fuel assembly lift calculations are typically performed in a reference analysis since the hydraulic lift forces are functions of the fuel assembly design and of reactor characteristics that are not dependent on the design of reload fuel cycles. A reference analysis is performed for each fuel assembly design and incorporates the anticipated mixed core combinations for the introduction of new or modified fuel assembly designs. Deterministic and statistical fuel assembly hold down methodologies are discussed below.

##### **6.3.1.1    Deterministic Fuel Assembly Hold Down Methodology**



Significant parameters that are evaluated for each reload core to ensure the applicability of the reference fuel assembly hydraulic analyses include the RCS flow rate, the core bypass flow fraction, and the fuel assembly pressure drop, as characterized by hydraulic form-loss coefficients.

#### **6.3.1.2 Statistical Fuel Hold Down Methodology**

BAW-10243P-A (reference 82) describes a statistical methodology to calculate net fuel assembly hold down force. The statistical methodology employs a probabilistic (Monte-Carlo) propagation of uncertainties to demonstrate that the fuel assembly design provides sufficient net downward force to counteract the vertical hydraulic lift force created by the core flow rate so that the fuel assembly remains in a seated position during normal operation and anticipated transients. The application of the methodology ensures that the worst-case hydraulic loads for normal operation will not exceed the hold down capability of the fuel assembly (either gravity or hold down springs) with a 95/95 percent level of protection and confidence.

The fundamental governing equations for calculating net hold down force using the statistical method are identical to those employed for deterministic methodology; the difference in application is the propagation of uncertainties through the equations. The fundamental equation contains all the axial forces acting on the fuel assembly.




During application of the statistical methodology, statepoints for evaluation are defined that cover a wide range of plant operating conditions at different burnup steps in order to identify the limiting statepoint. When the core is composed of different fuel designs, the limiting fuel assembly for each fuel design is determined for each of the statepoints. Then, the nominal value and uncertainty distribution for each of the variables are quantified and the uncertainties are propagated. A hydraulic evaluation of the core using an NRC-approved thermal-hydraulic code is then prepared using the plant-specific fuel cycle core configuration, including the inlet flow distribution applicable to the plant design of interest to obtain the pressure drop across the various fuel assemblies in the core. Finally, the propagation model is used to determine the net hold down force for each fuel assembly design at each of the statepoints. From these calculated values, the minimum net hold down value with the statistical protection at the 95% level with 95% protection is selected.


### **6.3.2 Core Pressure Drop**

Core pressure drop is not evaluated for reload applications unless significant fuel design changes are introduced. In evaluating potential design changes, the criterion used is that changes in pressure drop shall not adversely affect the ability of the RCS to remove heat from the core.

Average core pressure drop is calculated with CHATA (reference 63), LYNX1, or LYNXT in a reference analysis. A comparison of core pressure drop calculations performed with the CHATA and LYNX1 codes (presented in reference 48) shows that the results are identical when crossflow is minimal. In reference 50 the core average pressure drop predictions for LYNX1 and LYNXT are essentially identical for the typical crossflow situation in core analyses. For the reference analysis a best-estimate calculation is performed for a nominal, 100% RTP, operating condition. Fuel assembly pressure loss characteristics are represented by the use of analytical factors (form-loss coefficients) derived from tests in which pressure drop is measured as a function of flow rate.

### **6.3.3 Hydraulic Compatibility**





#### **6.4      *Reactor Coolant System DNB Safety Limits***


The RCS DNB safety limits are established to prevent overheating of the fuel and consequent cladding failure that would lead to the release of fission products to the coolant. Overheating of the fuel cladding is prevented by restricting fuel operation to within the nucleate boiling regime, where the heat transfer coefficient is large and the cladding surface temperature is maintained at a level slightly above the coolant saturation temperature. Restriction of operation to within the nucleate boiling regime is accomplished by placing limits on observable (and controllable) parameters, including reactor coolant temperature and pressure, core power, and power peaking, such that the DNBR criterion is met.



## **6.5      *Flux/Flow Protective Limit***

In B&W 177-FA plants, protection against LOCF transients is provided by the power/pump status and power/imbalance/flow trip functions. The power/pump status function trips the reactor if power is lost to two or more pumps. This trip function therefore provides protection against a complete loss of coolant flow and for some partial loss of coolant flow events. For those partial LOCF events where the power/pump status trip is not activated, and for steady-state operation with 3 or 2 pumps, protection is provided by the power/imbalance/flow trip function. The flow-dependent portion of this protection limit is derived for zero imbalance, design peaking conditions, and is commonly known as the power/flow or flux/flow limit. The limit value is developed from transient analysis of a pump coastdown event, with the criterion being that the minimum DNBR must be greater than the DNB analysis limit. The flow transient analyzed is either a 1-pump or a 2-pump coastdown, depending on the degree of redundancy of the pump power monitors for a specific reactor. The pump power monitors provide pump status information.







**6.6      *Maximum Allowable Peaking Limits***






#### **6.6.1 Calculation of Safety Limit MAPs (RPS MAPs)**





## 6.6.2 Calculation of Operating Limit MAPs



### **6.6.3 Verification of Calculated Margins (Physics Check Cases)**

## **6.7 Transient Core Thermal-Hydraulic Analysis**

For Condition II events, the minimum DNBR must be greater than the DNB design limit. The reload safety evaluation is performed to determine whether any changes introduced by the reload core affect the validity of the existing (reference) transient analyses. The key parameters reviewed to assess the need for recalculation of the DNB-limited transients are those shown in Table 6-3. Limiting conditions for operation (LCOs) are established for pressure, temperature, and flow to ensure the continuing validity of these analyses during plant operation. Criteria for determining the LCOs on DNB parameters are as follows:

1. The LCO on RCS pressure is established such that during normal plant operation the steady-state core exit pressure will be maintained at a level greater than or equal to the value assumed for DNBR analysis of Condition II transients from full power.
2. The LCO on RCS hot leg temperature is established such that during normal plant operation the steady-state RCS hot leg temperature will not be greater than that corresponding to the initial conditions assumed for DNBR analysis of Condition II transients from full power.
3. The LCO on RCS flow rate is established such that during normal plant operation the steady-state RCS flow rate will not be less than the initial condition value assumed for DNBR analysis of Condition II transients initiated from full power.

Transient core thermal-hydraulic analyses are performed with either a single-pass LYNXT model or the closed-channel RADAR code initialized to a LYNXT initial condition DNBR prediction. For full-power transients, the initial conditions modeled are as described in Table 6-2. Transient inputs to the core thermal-hydraulic calculation typically include RCS flow and pressure, core inlet temperature, and neutron power.

## **6.8      *Stainless Steel Replacement Rod Methodology***

BAW-2149-A (reference 23) defines a methodology for the use of stainless steel replacement rods in AREVA fuel designs. Reference 23 addresses the nuclear, thermal-hydraulic, and mechanical aspects of the fuel design that are affected by the use of stainless steel replacement rods.

The NRC concurred in reference 84 that the topical report BAW-2149A is applicable to the use of stainless steel rods in fresh (i.e. unirradiated) fuel assemblies.

NRC approval has been obtained for the methodology for the use of as many as ten stainless steel replacement rods within a single fuel assembly. From a DNB perspective, the impact of the stainless steel rods on the peaking of adjacent heat-producing fuel rods is to be explicitly examined on a cycle-by-cycle basis to ensure continued compliance to the  $F_{\Delta H}^N$  design limit.

The stainless steel replacement rods weigh slightly less than Zircaloy-clad fuel rods, but the effect on fuel assembly weight of up to 10 replacement rods is negligible.

Therefore, the use of stainless steel replacement rods has an insignificant effect on fuel assembly hydraulic lift.

Stainless steel replacement rods are designed and analyzed to ensure that there is no adverse impact on fuel assembly performance. The rods are designed to ensure that adequate performance with respect to differential thermal expansion, irradiation growth, seismic-LOCA response, grid relaxation, and fretting due to vibration will be maintained.

The impact of the stainless steel replacement rods on the LOCA evaluation will be considered on a cycle-specific basis as noted in Section 9.0.

## **6.9      *Reload Safety Evaluation***

The reload safety evaluation is performed to determine whether any changes introduced by the reload core affect the validity of the existing safety limits or reference analyses. The key parameters reviewed to assess the need for recalculation of the DNBR safety limits are those shown in Table 6-3. The same parameters plus the key transient input values are reviewed to determine the need for reanalysis of DNB-limited transients.

Table 6-1 Core Inlet Flow Factors

| Operating Condition | <u>Interior Region</u> |     | <u>Peripheral Region</u> |     |
|---------------------|------------------------|-----|--------------------------|-----|
|                     | Min                    | Max | Min                      | Max |
| Four Pumps          | [                      |     |                          | ]   |
| Three pumps         |                        |     |                          |     |




**Table 6-2 Initial Conditions for Transient DNBR Calculations**


| <b><u>Parameter</u></b>                     | <b><u>Value</u></b>               |
|---|-----------------------------------|
| Reactor Power                               | nominal + power uncertainty       |
| RCS Flow Rate                               | minimum                           |
| Core Bypass Flow Fraction                   | maximum                           |
| Reactor Inlet Temperature                   | nominal + temperature uncertainty |
| Reactor Exit Pressure                       | nominal – pressure uncertainty    |
| Radial * local peaking ( $F_{\Delta H}^N$ ) | 1.800                             |
| Axial power distribution                    | 1.65 chopped cosine               |

**Table 6-3 Significant Parameters - Core Thermal-Hydraulics**


| <b><u>Parameter</u></b>           | <b><u>Limiting Direction</u></b> |
|-----------------------------------|----------------------------------|
| Core power                        | Maximum                          |
| Reactor Coolant Inlet Temperature | Maximum                          |
| Reactor Coolant Pressure          | Minimum                          |
| Reactor Coolant Flow              | Minimum                          |
| Core Bypass Flow                  | Maximum                          |
| Radial Peaking, $F_{\Delta H}^N$  | Maximum                          |
| Axial Peaking, $F_z$              | Maximum                          |
| Engineering Hot Channel Factors   | Maximum                          |

**Figure 6-1 Example of Reactor Core Safety Limits**

**Figure 6-2 Example of Maximum Allowable Radial Peaks**



**Figure 6-3 Example of Maximum Allowable Total Peaks**



## **7.0 REACTOR PROTECTION SYSTEM SETPOINTS**

### **7.1 *High Reactor Coolant System Pressure Trip***

#### **7.1.1 Functional Description**

The pressure input for the high RCS pressure trip function of the RPS is obtained from the hot leg pressure tap. In general terms, the high RCS pressure trip provides protection for the RCS high pressure safety limit defined by the ASME code. The high RCS pressure safety limit is defined as 110% of the RCS design pressure. For the RCS design pressure of 2500 psig, the safety limit is 2750 psig. The reactor trips on high RCS pressure during transients that result in a net increase in heat production versus heat removal, which is accompanied by an increase in the RCS pressure. The reactor trip limits the severity of the heat removal mismatch and hence the stored energy in the primary system.

#### **7.1.2 Analysis Criteria**

The plant systems response analysis (safety analysis) criteria for the high RCS pressure trip are given below. Some of the criteria provide constraints on the assumptions used to determine the setpoint rather than on the setpoint itself.

1. The setpoint shall lie within the detection window of the instrumentation. The RPS pressure instrumentation has a range of 1700 to 2500 psig.
2. The setpoint shall assure a reactor trip 95% of the time at a 95% confidence level, including instrumentation uncertainties. This criterion provides a constraint on the instrumentation error uncertainties from the qualification program and on the combination of the module uncertainties used to determine the total string uncertainty. The instrumentation errors are calculated by a methodology that considers a square root of the sum of the squares of the random terms, to which the bias or correlated terms are then added.

3. The setpoint shall preclude steady-state operation at or above the pressurizer code safety valve setpoints. This criterion is intended to avoid a situation in which a reactor trip on high RCS pressure could be prevented by the lifting of the pressurizer safety valves.
4. The setpoint shall ensure that peak RCS pressure during Condition I and Condition II events remains below the high RCS pressure safety limit. This is an acceptance criterion that applies to the safety analyses that use this trip for reactor protection, rather than being applicable to the trip setpoint itself.

### **7.1.3 Analysis Trip Setpoint Calculations**

The high RCS pressure trip is used for steady state and transient protection of the reactor. The RPS trip setpoint is based on the pressure at the hot leg pressure tap. The SAR transient analyses for which the high RCS pressure trip is used are: control rod withdrawal at startup, rod withdrawal accident at rated power, moderator dilution event, feedwater line break, control rod ejection, and loss of main feedwater. The setpoints used in the analysis are provided in each plant's SAR.

#### **7.1.4 Delay Times**

In addition to the errors discussed above, the accident analyses also assume a delay time that corresponds to the time response characteristics of the equipment associated with the trip. This equipment includes the modules in the instrumentation string as well as the trip breakers and the control rod drive mechanism (CRDM). The actual delay time is the sum of the time responses of each component, from the time the trip condition occurs until the time the control rods are released and begin to insert into the core. The actual delay time is based on equipment testing and bounds the range of parameter changes for which the equipment is assumed to respond. The actual delay time is represented in the analyses as a single value.



## **7.2      *Low Reactor Coolant System Pressure Trip***

### **7.2.1      Functional Description**

The pressure input for the low RCS pressure trip function of the RPS is obtained from the hot leg pressure tap. In general terms, the low RCS pressure trip provides protection against DNB during steady-state and transient operation. By initiating a reactor trip during decreasing pressure events, the low RCS pressure trip provides protection for the fuel cladding, fuel, reactor building, and, ultimately, the environment. The DNBR safety limit describes a locus of points for core conditions that mark the transition in heat transfer regimes from nucleate boiling to film boiling along the fuel pins, as determined analytically. The point at which the heat transfer changes from nucleate boiling to film boiling is termed DNB. At this point, the heat transfer from the fuel pin declines due to the insulation of the fuel cladding surface by the steam film. The heat flux necessary to cause the transition from nucleate boiling to film boiling is termed the CHF. The decrease in heat transfer associated with entering film boiling leads to fuel cladding temperature increases. The DNBR is the ratio of the critical heat flux to the actual calculated heat flux.

### **7.2.2      Analysis Criteria**

The analysis criteria for the low RCS pressure trip are given below. Some of the criteria provide constraints on the assumptions used in determining the setpoint rather than on the setpoint itself.

1. The setpoint shall lie within the detection window of the instrumentation. The RPS pressure instrumentation has a range of 1700 to 2500 psig.

2. The setpoint shall assure a reactor trip 95% of the time at a 95% confidence level, including instrumentation uncertainties. This criterion provides a constraint on the instrumentation error uncertainties from the qualification program and the combination of the module uncertainties into the total string uncertainty. The instrumentation errors are calculated by a methodology that considers a square root of the sum of the squares of the random terms, to which the bias or correlated terms are then added.
3. The setpoint shall be approximately 250 psi greater than the emergency core cooling system bypass setpoint. This setup provides sufficient margin following a reactor trip for the operators to bypass the safety injection systems, if desired.
4. The setpoint in conjunction with the high-temperature and variable-low- pressure trip shall prevent the core from exceeding the steady-state DNBR safety limit.

### **7.2.3 Analysis Trip Setpoint Calculations**

The low RCS pressure trip is used for steady-state and transient protection of the reactor. The RPS trip setpoint is based on the pressure at the hot leg pressure tap.

SAR transients for which the low RCS pressure trip is credited result in an RCS pressure decrease and include the SBLOCA, steam generator tube rupture (SGTR) and steam line break. Although not credited in the SAR analyses for LBLOCA, the low RCS pressure trip also provides reactor protection for LBLOCA. In this case, the setpoint is a low parameter setpoint, and the safety limit is defined in terms of DNBR and not strictly pressure.



#### **7.2.4 Delay Times**

The concept and methodology for determining the analysis values of the delay times associated with the low RCS pressure trip are the same as those for the high RCS pressure trip, as is discussed in Section 7.1.4.

### **7.3 *Power/Imbalance/Flow Trip***

#### **7.3.1 Functional Description**

A complete description of the protection provided by this trip is included in Section 5.3.1. The function of this trip is to develop an allowed maximum power level for the current flow and axial power imbalance conditions in the plant. The process can be explained in the following way: The reactor coolant (RC) flow is measured and multiplied by the flux/flow setpoint to arrive at a maximum allowed power with no imbalance. The function generator uses this power level to assess a power penalty based on the measured imbalance conditions. This final allowed power is then compared to total measured power to determine whether a trip condition exists. Figure 7-2 shows the general shape of the power/imbalance/flow trip envelope. The plant can safely operate within this envelope, but once power and imbalance values exceed those of the trip envelope, the reactor is placed in a trip condition. At lower power levels, imbalance protection is not required. However, due to current RPS hardware limitations, a trip setpoint is still defined for the lower power levels.

### 7.3.2 Analysis Criteria

The analysis criteria for the power/imbalance/flow trip are listed below.

1. The setpoint shall prevent violation of the power-imbalance protective limit and the power/flow protective limit.
2. The setpoint shall be chosen such that the trip condition can be measured by the out-of-core neutron detectors. This criterion ensures that the core condition can be measured at the point where a trip is desired.
3. The setpoint shall assure a reactor trip 95% of the time at a 95% confidence level, including instrumentation uncertainties. This criterion provides a constraint on the instrumentation error uncertainties from the qualification program and the combination of the module uncertainties into the total string uncertainty. The instrumentation errors are calculated by a methodology that considers a square root of the sum of the squares of the random terms, to which the bias or correlated terms are then added.
4. The RC flow noise at the plant shall be less than that assumed in the setpoint calculations. A typical value of flow noise is between 1.5% and 2.4% of full flow. The flow noise may be minimized through mechanical or electronic filtering.
5. The RC flow input to the RPS shall be calibrated to indicate 100% full flow, or less, when the plant is at full power with four pumps operating. This requirement ensures that the assumptions of the accident analysis are maintained in the plant system calibration.


### 7.3.3 Analysis Trip Setpoint Calculations

The value of the power/imbalance/flow trip setpoint is a fuel cycle-specific envelope that is dependent upon the cycle core peaking. The flux/flow limit value ( $S_m$ ) is generated with a reference design peaking distribution (Section 6.2.2) during the analysis of loss of RCS flow events for each cycle. The peaking for each cycle is used to generate the power-offset limits.  $S_m$  is used with the power-offset limits to determine the power/imbalance/flow setpoint.


### **7.3.3.1 Flux/Flow Setpoint Error Adjustment**


#### **7.3.3.2 Power Imbalance Envelope Determination**














### **7.3.4 Delay Times**

The only delay time of interest for the power/imbalance/flow trip is associated with the flow measurement. Since the other functions of the trip are not considered in the analyses, their delays do not significantly affect the analyses that rely on the power/imbalance/flow trip. The delay time for the flow string is determined by adding the response characteristics of the different modules to arrive at the total string delay time. The trip breaker and CRDM release times are included in the total delay.

## **7.4 High Flux Trip**

### **7.4.1 Functional Description**

The neutron flux input for the RPS high flux (nuclear overpower) trip function of the RPS is obtained from the out-of-core power range neutron detectors. In general terms, the high flux trip provides protection for the DNBR, TCS and CFM limits. By initiating a reactor trip during increasing reactivity events, the nuclear overpower trip also provides some protection for the pressure boundary and the reactor building.

### **7.4.2 Analysis Criteria**

The analysis criteria for the high flux trip are listed below.


1. The setpoint shall assure a reactor trip 95% of the time at a 95% confidence level, including instrumentation uncertainties. This criterion provides a constraint on the instrumentation error uncertainties from the qualification program and the combination of the module uncertainties into the total string uncertainty. The instrumentation errors are calculated by a methodology that considers a square root of the sum of the squares of the random terms, to which the bias or correlated terms are then added.
2. The setpoint shall be chosen such that the trip condition can be measured by the out-of-core neutron detectors. This criterion ensures that the core condition can be measured by the trip string at the point chosen to keep thermal power less than design overpower.

### **7.4.3 Analysis Trip Setpoint Calculations**

The nuclear overpower trip provides protection during steady-state and transient conditions. The accidents for which the nuclear overpower trip provides protection are the startup accident, the rod withdrawal accident, the rod ejection accident, and the steam line break accident. A reactor trip on high flux provides direct protection of the DNBR, TCS and CFM safety limits.

The nuclear overpower trip value used in the original licensing systems response analyses was 114 %FP. Additional studies performed in the early 1970's utilized better predictions of the performance of fuel in reactors than were available for the original analyses. The results of the later analyses led to changes in the assumptions of the physical properties of the fuel following irradiation. The effect noted at that time, and evaluated for each plant, is fuel densification. This effect causes the fuel pin heat transfer to change, thus affecting various DNB and CFM calculations. The fuel densification reports for each plant describe the evaluation performed for the safety analysis and fuel cycle design parameters. Application of a densification power spike penalty is no longer required for thermal-hydraulic analyses (see Section 6.2.7). As a result of the later studies, the peak power considered in subsequent analyses was reduced to a power level which corresponds to the design power limit for the B&W 177-FA plants (typically 112 %FP).

Additional analyses have been performed to verify the acceptable core response to overcooling conditions when the nuclear overpower trip string errors are effectively increased due to shielding of the out-of-core neutron detectors by the cooler reactor vessel downcomer fluid. The evaluations provided assurance that sufficient margin exists for both DNBR and kW/ft conditions even when the actual core power exceeds the design power limit.



#### **7.4.4 Delay Times**

The delay time is based on equipment testing and bounds the range of rates of parameter changes to which the nuclear overpower string is assumed to respond. The delay time is composed of the time constants of the various modules contained in the trip string. The total trip delay time used in systems response analyses also includes contributions from the trip breakers and the CRDM. The individual component delay times are summed to arrive at the total trip delay time accounted for in the analyses.

## **7.5      *High Reactor Coolant Outlet Temperature Trip***

### **7.5.1      Functional Description**

The temperature for the RPS high RCS Outlet Temperature trip function is obtained from the temperature sensors in the hot legs. The high RCS outlet temperature trip establishes an absolute upper limit on RCS outlet temperature. In doing so, the limit restricts the range over which the RPS variable low reactor coolant pressure trip (VLPT) function must provide protection. This trip provides backup protection for RCS overheating events. The trip is not used as the primary trip function for any SAR accident systems response analyses.

### **7.5.2      Analysis Criteria**

The analysis criteria for the high reactor coolant outlet temperature trip are given below.

1. The setpoint shall ensure a reactor trip 95% of the time at a 95% confidence level, including instrumentation uncertainties. This criterion provides a constraint on the instrumentation error uncertainties from the qualification program and the combination of the module uncertainties into the total string uncertainty. The instrumentation errors are calculated by a methodology that considers a square root of the sum of the squares of the random terms, to which the bias or correlated terms are then added.
2. The setpoint in conjunction with the low-pressure and variable-low- pressure trip shall prevent the core from exceeding the steady-state DNB safety limit.
3. The setpoint shall lie within the detection window of the instrumentation. The RPS temperature instrumentation has a range of 520 to 620°F.



### **7.5.3 Analysis Trip Setpoint Calculations**

Since the high RCS outlet temperature trip is not required to meet any acceptance criteria of any transient considered in accident analysis, the accident analysis setpoint is assumed to be at the upper limit of the temperature measurement instrumentation. This value (620°F) is used in steady-state calculations in which the high-temperature trip is used for limiting the temperature range of the variable-low-pressure trip.

### **7.5.4 Delay Times**

The delay time for this trip is determined from the summation of the time constants of each module. The delay time itself, however, is not limited by the accident analysis since the high RCS outlet temperature trip is not assumed to terminate any events. The limitation on the total allowed string delay time is based on engineering judgment and guidance provided by the NRC in various regulatory documents including Regulatory Guides and Generic Letters. Currently, a delay time of 6 seconds on the temperature string is considered conservative and appropriate for the safety functions that this string performs.

## **7.6      *Variable Low RC Pressure Trip***

### **7.6.1      Functional Description**

The VLPT provides primary steady state DNBR protection. This protection is accomplished by tripping the reactor before system parameters reach a P-T combination that could lead to DNB in the core, assuming conservative core power and peaking conditions. The protection provided by this trip amounts to a "floating" low pressure trip that is dependent upon the measured core outlet temperature.


### **7.6.2      Analysis Criteria**

The analysis criteria for the VLPT are given below.

1. The setpoint shall ensure a reactor trip 95% of the time at a 95% confidence level, including instrumentation uncertainties. This criterion provides a constraint on the instrumentation error uncertainties from the qualification program and the combination of the module uncertainties into the total string uncertainty. The instrumentation errors are calculated by a methodology that considers a square root of the sum of the squares of the random terms, to which the bias or correlated terms are then added.
2. The setpoint, in conjunction with the low-pressure and high-temperature trips, shall prevent the core from exceeding the steady-state DNBR safety limit.
3. The setpoint shall lie within the capabilities of the instrumentation. This criterion places a limitation on the slope of the VLPT setpoint.

### 7.6.3 Analysis Trip Setpoint Calculations

The accident analysis value for this trip is actually an adjusted P-T limit that is specified by DNB analysis. The DNB limits are evaluated for each allowed reactor coolant pump status at the maximum allowed steady state power level for a particular pump combination. The four-pump limit is the design overpower value, typically 112 %FP. The three- and two-pump limits are evaluated at the maximum power level, as determined using the flux/flow setpoint and assuming the worst case instrument errors. Additional assumptions on design power peaking in the core are used in determining these power limits.



#### **7.6.4 Delay Times**

The delay time can be calculated for both pressure and temperature changes by summing the time constants of each module. The signal converter and the temperature sensor are not included as part of the pressure delay, since the pressure is assumed to move toward a setpoint that is remaining constant. The pressure transmitter is excluded from the temperature delay since the temperature portion of the setpoint moves toward the fixed pressure value. As with the other instrumentation strings, the contribution of the trip breakers and the CRDM release are included in the total delay time.

### **7.7 High Reactor Building Pressure Trip**

#### **7.7.1 Functional Description**

The high reactor building pressure trip initiates a reactor trip whenever the building pressure increases beyond the pressure setpoint. These conditions indicate that a high energy line break is present. This trip is expected to be the primary trip for small breaks in high-energy lines inside containment, such as LOCAs, steam line breaks, and feedwater line breaks. Although this would be the primary trip that provides protection for the plant, this trip is not directly credited in the accident analyses.

#### **7.7.2 Analysis Criteria**

The analysis criteria for the high reactor building pressure trip are given below.

1. The setpoint shall ensure a reactor trip 95% of the time at a 95% confidence level, including instrumentation uncertainties. This criterion provides a constraint on the instrumentation error uncertainties from the qualification program and the combination of the module uncertainties into the total string uncertainty. The instrumentation errors are calculated by a methodology that considers a square root of the sum of the squares of the random terms, to which the bias or correlated terms are then added.
2. The setpoint shall lie within the measurement range of the instrumentation.

### **7.7.3 Analysis Trip Setpoint Calculations**

This trip is not used in the NSSS systems response analyses. Both the LOCA and non LOCA analyses use either the low RCS pressure trip or the high flux trip for transients where the high reactor building pressure trip would be expected to provide primary core protection. Therefore, this trip remains as a backup to the other RPS trip functions for the systems response analyses. The high reactor building pressure trip is used for containment pressure and temperature analyses. The nominal trip setpoint for the containment analyses is taken as 4 psig, but varies from plant to plant.

### **7.7.4 Delay Times**

The delay time for this trip is determined from the various time delays of the different components. As with the other instrumentation strings, the contribution of the trip breakers and the CRDM release are included in the total delay time.

## **7.8      *Power/Pump Monitors Trip***

### **7.8.1      Functional Description**

The power to pump monitors trip ensures a reactor trip when no reactor coolant pumps are operating in one steam generator loop (0/0, 1/0, 0/1, 2/0 or 0/2 operation). This trip also provides the primary protection for the following events:

1. Multiple reactor coolant pump coastdowns.
2. Single reactor coolant pump coastdown from partial pump operation.
3. Reactor coolant pump coastdowns resulting in the loss of both pumps in either loop.

The trip is designed to operate in a nearly binary manner: power operation allowed or power operation not allowed. The determination is based on the comparison of the measured neutron power to the allowed power for the pump combination operating. The pump monitor in the trip string rapidly determines allowed power level for the pump combination and the bistable then determines the need for trip.

### **7.8.2      Analysis Criteria**

The analysis criteria for the power-to-pump monitors trip are given below.

1. The setpoint shall ensure a reactor trip 95% of the time at a 95% confidence level, including instrumentation uncertainties. This criterion provides a constraint on the instrumentation error uncertainties from the qualification program and the combination of the module uncertainties into the total string uncertainty. The instrumentation errors are calculated by a methodology that considers a square root of the sum of the squares of the random terms, to which the bias or correlated terms are then added.
2. The setpoint shall lie within the measurement range of the instrumentation.
3. The trip shall prevent operation with an idle steam generator loop. Initial calculations and testing indicated the need to preclude idle loop power operation, and this trip function has been used to ensure that the condition is met.

### 7.8.3 Accident Analysis Trip Setpoint Calculations


The reactor coolant pump power monitor trip is used for steady state and transient protection of the reactor. The SAR transient applicable for the trip is the LOCF event, which is initiated by a reduction in or loss of forced flow through the RCS. The reduction in flow may be due to a mechanical failure in the reactor coolant pumps or a loss of electrical power to the reactor coolant pump motors. With the reactor at power, the result is an increase in the RCS temperature and a reduction in the heat removal capability of the reactor coolant. These two conditions could result in DNB in the core.


As modeled in the accident analyses, the power/pump monitor trip is a digital type trip. If the accident analyses assume a loss of primary flow from a reactor coolant pump trip, the trip condition is based on the initial core power. If the core power is found to be greater than the allowed final pump status power level, a trip condition exists and a reactor trip is initiated. Since the consequences of this transient are more severe at high power levels, a specific analysis setpoint has not been defined by the analyses. For all idle loop conditions, the allowed power level is 0 %FP. For the condition of only one pump operating in each loop, the setpoint is either 55 %FP or 0 %FP, depending on whether or not the plant is licensed to operate in this configuration.




#### **7.8.4 Delay Times**

The accident analyses assume a response time characteristic for this instrumentation, i.e., the delay time. The delay time is a single number that accounts for the response of the modules in the string as well as the delay time contributions from the breakers and the CRDM. The delay time is based on equipment testing and bounds the range of parameter changes to which the reactor coolant pump power monitor trip string is assumed to respond. The delay time is composed of the time constants of the various modules. A simple sum is taken to arrive at the total trip delay time. A typical delay time assumed for this trip is 0.620 second, although plant-specific evaluations have been performed to allow a longer delay time.


**Figure 7-1 General Setpoint Philosophy**


**Figure 7-2 Power/Imbalance/Flow Trip Setpoint**

**Figure 7-3 Power/Imbalance/Flow Detectability Envelope**



**Figure 7-4 Power/Imbalance/Flow Trip Setpoints for Four, Three and Two Pump Operation**



**Figure 7-5 Variable Low Pressure Trip Setpoint**

**Figure 7-6 Variable Low Pressure Setpoint Slope Rotation**



## **8.0 NON-LOCA ACCIDENT EVALUATION**

### **8.1 *Systems Response Analyses***

Systems response analyses have been performed for the events discussed in the plant SARs. The assumptions used in the SAR analyses must be shown to bound the corresponding cycle-specific parameters in order to avoid a re-evaluation of the accidents for each fuel cycle. Therefore, the general requirement is that the predicted parameter values of a reload fuel cycle lie within the current licensing base of the plant. A discussion follows on how each of the key parameters is evaluated for each fuel cycle against the licensing analysis for each plant.

#### **8.1.1 Moderator and Doppler Coefficients**

The Doppler and moderator coefficients are a measure of the reactivity change resulting from changes to the fuel and moderator temperatures, respectively. The cycle-specific moderator and Doppler reactivity coefficients shall lie within the analyzed range considered in the SAR accident analyses. This requirement ensures that the core power response, were an accident to occur during the fuel cycle, would be bounded by a response that has been shown to meet the applicable acceptance criteria in the accident analyses. Depending on the event being considered, the moderator and Doppler coefficients are evaluated either individually or on a combined-effects basis.

##### **8.1.1.1 BOC Conditions**

The beginning-of-cycle (BOC) Doppler and moderator coefficients are used in the systems response analysis of BOC-limited events, i.e., events that result in an increase to the fuel and RCS fluid temperatures. Examples of heatup events include:

1. Moderator Dilution Event
2. Rod Withdrawal from Rated Power
3. Startup Event
4. Loss of Main Feedwater



5. Feedwater Line Break
6. Rod Ejection
7. Loss-of-Coolant Flow
8. Loss of Electric Power

For heatup events, a less-negative reactivity coefficient results in less negative reactivity addition to the reactor core. Consequently, more power is generated in the core and more heat is added to the RCS, thereby producing more severe results. The combined effects of the cycle-specific BOC Doppler and moderator coefficients must provide a smaller positive reactivity addition during heatup events than was calculated in the accident analyses. If this condition is met, the cycle-specific BOC reactivity coefficients are deemed acceptable.

#### **8.1.1.2 EOC Conditions**

The EOC Doppler and moderator coefficients are used in the systems response analyses of EOC-limited events, i.e., events that result in a decrease to the fuel and RCS fluid temperatures. Examples of cooldown events include:

1. Steam Line Breaks
2. Cold Water Event (Pump Restart)

The EOC Doppler and moderator coefficients are more negative than their BOC counterparts. The negative Doppler and moderator coefficients, combined with a fuel and moderator temperature decrease, result in positive reactivity insertion into the core. The more negative the coefficients, the greater the positive reactivity insertion. Maximizing the post-trip positive reactivity insertion is conservative for the overcooling events. The combined effects of the cycle-specific EOC Doppler and moderator coefficients must provide less positive reactivity during cooldown events than was calculated in the accident analyses. If this condition is met, the cycle-specific EOC reactivity coefficients are deemed acceptable.

### **8.1.2 BOC Soluble Boron Concentration**

The initial (BOC) boron concentration is of importance to the moderator dilution event analysis. The reactivity insertion rate for this event depends on the total reactivity worth of the boron in the system. The total boron worth is determined by dividing the initial boron concentration, in units of ppm, by the inverse boron worth, in units of ppm/% reactivity. The result is the total reactivity held by the boron that is dissolved in the reactor coolant, i.e., the boron worth. During a boron dilution event, this ratio provides a means of determining the rate of reactivity addition as the boron concentration is diluted. The greater the cycle-specific boron worth, the more rapid the reactivity insertion as the dilution accident proceeds. Thus, the cycle-specific values must yield a lower boron worth than that assumed in the accident analysis. If this criterion is met, the boron worth is deemed acceptable.

### **8.1.3 Dropped Control Rod Worth**

The dropped rod worth is used in the systems response analyses of a dropped or stuck rod (CRA). The consequences of the dropped rod accident bound those of the stuck-in or stuck-out rod events. The higher the dropped rod worth, the greater the resultant power suppression will be. The power suppression results in a coolant temperature decrease, which coupled with negative reactivity coefficients causes a positive reactivity insertion. The analyses have shown acceptable results for a range of dropped rod worths and reactivity coefficients that represent fuel burnup conditions from BOC through EOC. Therefore, in order to be acceptable, the maximum cycle-specific dropped rod worth must lie within the range of the rod worth values considered in the analyses.

#### **8.1.4 Ejected Rod Worth**

The ejected rod worth is used in the systems response analysis of the rod ejection accident. For this event, a larger ejected rod worth results in more severe reactivity insertion and subsequent power excursion. The analyses have shown acceptable results for a range of ejected rod worths. Therefore, in order to be acceptable, the maximum cycle-specific ejected rod worth must be less than the maximum rod worth considered in the analyses.

#### **8.1.5 Single and All-Control-Rod-Group Worth**

The all-rod-group worth at HZP is used in the systems response analysis of the startup event. The higher the rod worth, the higher the rate of positive reactivity insertion into the core during the event. The analyses have shown acceptable results for a range of rod worths and corresponding reactivity insertion rates. Therefore, in order to be acceptable, the maximum cycle-specific all-rod-group worth must lie within the range of the reactivity insertion rates considered in the analyses of the startup event.

The analyses of the rod withdrawal accident at rated power were based on reactivity insertion rates independent of actual group worths. Spectrum studies of rod worth included reactivity insertion rates ranging from that corresponding to less than a single rod to that equivalent to withdrawing all the rods at once. The spectrum study demonstrated the acceptability of all reactivity insertion rates considered. Within the SARs, reference points were provided to give the reader a gauge as to what reactivity insertion rates approximately corresponded to a single control rod, a single group, and an all-group condition. These worths were intended to serve as typical values based on the original core designs. As long as the cycle-specific all-rod-group worth falls within the range that corresponds to the reactivity insertion rates considered in the analyses, the cycle-specific all-rod-group worth is deemed acceptable.

### **8.1.6 Delayed Neutron Fraction ( $\beta_{\text{eff}}$ )**

The effective delayed neutron fraction is another kinetics parameter that is used in the systems response analyses. However,  $\beta_{\text{eff}}$  is not a significant factor in the systems response to a postulated transient. Accordingly, a nominal or representative value, corresponding to the time-in-life that is being analyzed, is used as analysis input. The accident analysis philosophy is based on performing overall-conservative analyses, which incorporate bounding values for the significant parameters, rather than bounding every parameter. To that end, the conservatism that is built into the analyses is a result of the use of bounding values for moderator and Doppler coefficients, and includes conservative boundary conditions that are imposed on the RCS and secondary plant systems. Therefore, a rigorous check of the cycle-specific  $\beta_{\text{eff}}$  values is not required.

### **8.1.7 Additional Cycle-Specific Evaluations**

In conjunction with the fuel reloads, changes to the fuel design may be made that are not typically evaluated in the systems response analyses. Examples include:

1. Modifications to the fuel assembly hold-down springs,
2. Addition of debris filters,
3. Improvements to the fuel assembly that facilitate recaging,
4. Plugging or sleeving of additional steam generator tubes,
5. Replacement of damaged fuel pins in reinserted fuel assemblies with stainless steel replacement rods, or
6. Modification of the fuel spacer grids or fuel cladding to improve thermal and wear performance.

Typically, these changes do not have a significant effect on the overall system response. Nevertheless, limits have been established, such as the allowable number of plugged or sleeved SG tubes or the number and location of inserted stainless steel rods, which govern the extent and consequences of these changes. Evaluations are performed each cycle to ensure that the appropriate limits are not violated and the overall conservatism of the boundary conditions and key input parameters used in the analyses is maintained. If these evaluations determine that systems response analyses of one or more of the SAR accidents is warranted because of a design change, then the appropriate analyses are performed.

#### **8.1.8 EOC Average Reactor Coolant Temperature Reduction**

Fuel cycle designs frequently include provisions for EOC maneuvers to ensure that cycle operation is maintained for the entire designed length. These EOC maneuvers typically include an EOC  $T_{avg}$  reduction. The effects of such EOC  $T_{avg}$  decreases on the systems response analyses have been evaluated, and allowable values for the  $T_{avg}$  reduction have been defined. As long as the specified cycle-specific maximum EOC  $T_{avg}$  reduction is within the defined limit, with measurement uncertainty accounted for, the analyses of record will remain applicable for the cycle.

### **8.2 Accident Evaluation**

The process of accident evaluations for a given plant is recurrent and on-going during its years of operation, as plant modifications and additional regulatory issues have arisen. To ensure a consistent set of analyses, common acceptance criteria have been used for determining the acceptability of the consequences of a given accident. As long as it can be shown that the acceptance criteria are met for each reload fuel cycle, the cycle design is considered acceptable. Many of the criteria are related to the parameters discussed in Sections 5.0, 6.0 and 8.1, although some are dependent on other non-fuel-cycle-dependent parameters.

The acceptance criteria are aimed at measuring the performance of the radiation barriers both during and after an accident. The barriers between the fuel radioactivity and the environment are described in the Code of Federal Regulations as the fuel cladding, the RCS pressure boundary, and the reactor building.

Some of the acceptance criteria are event-specific and reflect the approach to risk as a combination of the event consequences and the probability that the event can occur. In general, the risk to the public can be described by a multiplication of these two factors, with units chosen as desired to create common units across all events. Thus, a given level of risk can be achieved by either a high probability event with low consequences, or a low probability event with high consequences. The criteria are set to provide this type of risk management for the various events. For each acceptance criterion, the basis for its use and how it is applied to a fuel reload evaluation will be discussed.

1. Condition I and Condition II events shall not lead to fuel failure, thus maintaining offsite doses at the level consistent with normal steady-state operation.

The Condition I and II events include normal operation and events with an expected frequency of  $10^{-1}$  events per year. Since these conditions could reasonably be expected to occur during the fuel cycle, the consequences must be small to assure minimum risk to the public. The choice of no fuel cladding failure, as a consequence of normal operation or moderate frequency events, addresses the performance of the first barrier between the radioactivity contained in the fuel and the environment. By precluding fuel cladding failures during these conditions, no additional radioactivity beyond that found under normal conditions will be released to the RCS. Consequently, the resulting radiation releases to the environment are no higher than normal conditions allow.

An accident is considered to meet this acceptance criterion if the DNBR and TCS remain within limits, and the LHR for CFM is not exceeded. The accident analyses demonstrate the ability of the plant configuration and fuel cycle design to meet these requirements.

2. The ejection of the maximum worth rod shall result in a peak fuel enthalpy less than or equal to 280 cal/gm, the threshold for gross fuel failure.

The rod ejection accident results from a postulated rapid ejection of a single CRA from the core region during operation. The CRA ejection is driven by the pressure differential between the RCS and the containment. This pressure differential acts on the control rod following a postulated breach of the RCS pressure boundary in the control rod drive housing. The ejection is assumed to occur in less than 0.20 second. As the rod is ejected, positive reactivity is added to the core. The amount of positive reactivity addition is based on the worth of the ejected rod. The neutron power rise is extremely rapid, resulting in a near-adiabatic fuel temperature increase. The Doppler feedback limits the power increase prior to a reactor trip. The rapid increase in core power and fuel temperature could lead to fuel failures.

There are three modes by which the fuel can fail due to a rod ejection. The first is associated with low worth rod ejections and leads to very little fuel fragmentation internal to the cladding. Localized cladding degradation due to fuel pin pressure increases is insufficient to rupture the cladding outright, but could weaken it so that DNB could lead to failure. The second fuel failure mode is linked to higher reactivity insertion rates, which lead to significant fuel melting in the ejected rod region. This failure mode includes rupture of the cladding and dispersion of the fuel and cladding into the coolant. In the third and most serious failure mode, the fuel quickly vaporizes. The result is a rapid pressurization in the fuel pin, which can lead to cladding failures without elevated cladding temperatures.

Investigations into the fuel failure modes have been made with the transient test reactor TREAT to determine the conditions for fuel failures (reference 66). The onset of fragmentation of the fuel is marked by a fuel enthalpy of 280 cal/gm. Between 400 and 500 cal/gm, the transition from the second failure mode to the third mode occurs. The transition is a result of pressure pulses that are not evident below ~400 cal/gm.

The acceptance criterion of 280 cal/gm is established at the fuel enthalpy associated with the beginning of fuel fragmentation, but much lower than the +400 cal/gm associated with the rapid change in phase from solid to vapor. Core designs are restricted to those that do not lead to excessive fuel enthalpies, in order to avoid gross fuel failure.

This acceptance criterion is met each fuel cycle by limiting the ejected rod worth to less than that shown to be acceptable in the analysis. This topic was also discussed in Section 8.1.4.

3. The peak fuel cladding temperature during a LOCA shall not exceed 2200°F based on an approved evaluation model (EM) analysis that incorporates 10CFR50 Appendix K models.

Discussions of LOCA acceptance criteria and evaluations are provided in Section 9.0.

4. The peak reactor building pressure during high energy line breaks shall not exceed the design pressure.

Since the reactor building provides the third and ultimate barrier between the fuel radioactivity and the environment, its continued performance during all accidents must be demonstrated. Of utmost importance is the structural integrity of the containment under those accident conditions that could result in fuel failures. The accidents that provide the largest challenge to the reactor building structural integrity are the high energy line breaks, which release a significant quantity of mass and energy to the reactor building. Examples of this type of accident are the LOCA, steam line break, and feedwater line break accidents.



Analyses of these events demonstrate that the LOCA provides the largest mass and energy release to the reactor building, and as such provides the greatest challenge to its structural integrity. Mass and energy releases from conservative LOCA analyses have been evaluated for each plant and shown to provide acceptable reactor building pressures. Each cycle, the key parameters related to the reactor building pressurization analyses are reviewed to ensure that the licensing analyses are still bounding. This review may occur at either the utility or AREVA during the normal cycle review process.

Sensitivity studies have shown that the largest factor in the reactor building pressure analysis is the set of initial RCS conditions, which defines the average enthalpy released over the first 20 to 30 seconds of a LBLOCA. Since this is the case, any control changes affecting the RCS initial conditions are reviewed for impact on the mass and energy releases to the reactor building.

5. The reactor shall not return to criticality following a reactor trip during a steam line break event.

During a steam line break, the RCS is cooled as the secondary system is depressurized and cooled by the fluid discharge through the break. This event is EOC-limited because the more-negative moderator reactivity coefficient values at EOC, combined with the decrease in the moderator temperature, cause a positive reactivity addition. For an extended RCS cooldown resulting from a large steam line break, the negative moderator reactivity coefficient could more than offset the negative reactivity inserted by the control rods after reactor trip. As required by the GDC contained in Appendix A of 10CFR50, a redundant means of reactivity control must be provided. The B&W-designed NSSS uses soluble boron in the fluid injected by the high pressure injection (HPI) system. The injected boron will ensure long-term reactivity control. In the short-term, however, the reactor could return to criticality if other constraints were not placed on the core and plant design.

The potential return to criticality does not necessarily lead to fuel failure. However, the confirmatory analytical effort involves using three-dimensional models and is extensive and complex. Therefore, a design constraint has been placed on the steam line break analyses that the core must remain subcritical throughout the event.

Immediately following the reactor trip, the delayed neutron precursors continue to provide an additional source of neutrons that can cause fission. This source of neutrons decreases based on the half-life of each species. However, while significant numbers of delayed neutrons are still being emitted, the core will experience subcritical multiplication. During subcritical multiplication, power production is occurring but the reaction is not self-sustaining. Analyses have shown that this condition is acceptable and will not lead to fuel failures. Consequently, post-trip power production due to subcritical multiplication is allowed. However, continued power production in a self-sustaining reaction, i.e., a critical condition, is not allowed.

Each cycle, the acceptability of the core design with respect to steam line breaks is determined by a review of the moderator and Doppler reactivity coefficients, as described in Section 8.1.1. Key plant parameters that can significantly affect the outcome of the steam line break analysis are also reviewed to ensure that the values incorporated into the analysis remain bounding. These parameters are the initial secondary steam generator inventories and the main and emergency feedwater system performance.

6. The peak primary system pressure shall not exceed the 2750 psig safety limit, except for ATWS events.

The RCS pressure boundary is the second barrier between the fuel radioactivity and the environment. As such, a breach of this boundary can lead to higher radioactivity releases to the environment. The plant is designed to the applicable requirements of the ASME Code and ANSI standards, which define a safety limit of 110% of the design pressure. For an RCS design pressure of 2500 psig, the safety limit is defined as 2750 psig. By maintaining pressures below the safety limit, the design margins in the stress calculations ensure that the pressure boundary will remain intact and the radioactivity releases to the environment will be limited. The plant setpoints and system performance characteristics are reviewed for each cycle to ensure that the licensing analysis assumptions remain bounding.

The ATWS events are exempt from the 2750 psig safety limit because they define a set of accidents that assume a non-mechanistic failure of the RPS, a safety-grade system, to trip the reactor. The nature of the failure assumptions associated with an ATWS event allow the maximum RCS pressure acceptance criterion to be increased. With the addition of DSS and AMSAC functions at each plant, the failure of the RPS should not result in peak pressures greater than 3250 psig. This limit is considered to be conservative for the expected frequency of an ATWS event.

7. The peak secondary system pressure shall not exceed 110% of the design pressure.

The secondary system has also been designed in accordance with the applicable sections of the ASME Code and ANSI standards. For a secondary system design pressure of 1050 psig, the safety limit is 110% of this pressure, or 1155 psig. The main steam safety valves, in conjunction with the RPS, provide the over-pressure protection for the secondary system pressure boundary. By maintaining the secondary pressure less than the safety limit, the failure of the secondary system can be prevented and the heat removal capability through the steam generators can be maintained.

The limiting event with respect to secondary system over-pressurization is a turbine trip event from full power. The major parameters that affect the peak secondary system pressure for this and other events are reviewed each cycle to ensure that the assumptions used in the licensing analysis remain bounding. The major parameters that can affect the secondary system pressure response are the nominal main steam safety valve lift setpoints, allowed lift setpoint tolerances and flow capacities, the RPS high pressure trip setpoint and the core power level.

8. Doses for Condition III and Condition IV events shall be less than the 10CFR100 limits.

The common parameter used to assess the risk to the public is the calculated offsite dose. The cycle-specific dose calculations account for the performance of each of the barriers between the radioactivity source (the fuel) and the environment. The calculations also consider other factors, such as meteorological conditions, that can affect the dose calculations. As required by 10CFR50, the predicted doses for all Condition III and IV events must be less than the limits provided in 10CFR100. The predicted doses for the events evaluated in the plant SARs are well below the allowed limits, with conservative assumptions applied in the evaluations. The assessment is consistent with NSAC-125.

## **9.0 LOSS-OF-COOLANT ACCIDENT EVALUATION**

LOCAs are hypothetical accidents that result from the loss of reactor coolant at a rate in excess of the capability of the reactor coolant makeup system. The RCS pipe breaks considered range in size from the smallest breaks that exceed the makeup capacity up to and including a break equivalent in size to the double-ended rupture of the largest pipe in the RCS. Analyses for a given plant consider applicable fuel assembly designs, plant boundary conditions and modifications, and additional regulatory issues that may arise.

In general, the most likely change in a fuel reload that could impact the LOCA analysis is a change in the peaking, which can affect the initial core power distribution. This change is controlled within a set of maximum allowed LOCA kW/ft limits, defined to represent initial condition requirements for the LOCA analysis. (These should not be confused with kW/ft limits based on CFM or transient strain criteria used in the determination of the RPS setpoints.) The LOCA limits thus defined are used as input to the reload safety evaluation, which ultimately determines the allowed rod position and axial power imbalance limits for plant operation. Thus, by definition, the LOCA limits are accounted for in the core design.

LOCA analyses are performed based on an approved EM developed according to Appendix K of 10CFR50. The analyses are performed within all limitations and restrictions imposed via the SERs on the EM and its associated computer codes.

### **9.1 Analysis Criteria**

The results of the LOCA analyses are compared against the criteria listed in 10CFR50.46 to define the maximum allowable LHR limit as a function of axial core elevation. The five criteria of 10CFR50.46 are listed below.

1. The calculated maximum fuel element cladding temperature shall not exceed 2200°F.

2. The calculated total oxidation of the cladding shall nowhere exceed 0.17 times the total cladding thickness before oxidation.
3. The calculated total amount of hydrogen generated from the chemical reaction of the cladding with water or steam shall not exceed 0.01 times the hypothetical amount that would be generated if all of the metal in the cladding cylinders surrounding the fuel, excluding the cladding surrounding the plenum volume, were to react.
4. Calculated changes in core geometry shall be such that the core remains amenable to cooling.
5. After any successful initial operation of the ECCS, the calculated core temperature shall be maintained at an acceptably low value and decay heat shall be removed for the extended period of time required by the long-lived radioactivity remaining in the core.

## **9.2      *Analysis Methods***

There are currently two approved EMs that may be used for licensing application to B&W-designed plants. The original LBLOCA and SBLOCA licensing analyses for the B&W plants were based on blowdown analyses performed with the CRAFT2-based EM, described in references 67 and 68. More recent LBLOCA and SBLOCA licensing analyses for the B&W-designed plants have been performed based on the RELAP5/MOD2-B&W (RELAP5)-based EM documented in reference 69, including modifications described in Section 9.2.2. The RELAP5-based LOCA EM (reference 69) is further modified by the supplement provided in reference 83, which addresses the methodology changes to adequately account for burnup-dependent fuel thermal conductivity degradation (TCD).

All currently operating B&W-designed plants have converted their licensing basis for the LOCA LHR limits used to define the core operating limits to the RELAP5-based EM discussed in Section 9.2.2. However, previous sensitivity studies and results of the CRAFT2-based EM (described in Section 9.2.1) licensing cases may be used to define input or plant containment and equipment qualifications, long-term core cooling, and the bases for emergency operator procedure guidance. Additionally, some historical CRAFT2 sensitivity studies have been applied in the definition of the RELAP5-based EM methods used. Therefore, continued reference to this approved EM may be made for justification of certain licensing applications not directly related to defining the LOCA LHR limits.

#### **9.2.1 CRAFT2 EM**

The analysis methodology of the CRAFT2-based EM is described in reference 67 for LBLOCA and reference 68 for SBLOCA analyses. The CRAFT2-based EM utilizes a suite of computer codes in order to predict the LOCA consequences. Steady-state fuel data for  $\text{UO}_2$  and gadolinia fuel is provided to the CRAFT2-based EM by approved fuel codes, which are discussed in Section 9.2.3.

For LBLOCA analyses, the CRAFT2 code (reference 70) calculates the system hydrodynamics and core power generation during blowdown. The REFLOD3 code (reference 71) is used to determine the length of the RV lower plenum refill period and the flooding rates during reflood. The CONTEMPT code (reference 72) analyzes reactor building pressure. Finally, THETA1-B (reference 73) is used with output from CRAFT2, REFLOD3 and CONTEMPT to determine the PCT response.

For SBLOCA analyses, the CRAFT2 code is used to predict the hydrodynamic behavior of the RCS. If CRAFT2 predicts that the core will be covered with liquid throughout the transient, no core heat-up is predicted; and, therefore, no thermal analysis is required and compliance with 10CFR50.46 is ensured. Otherwise the FOAM2 computer program (reference 74) is used to determine the mixture height within the reactor core and the thermal response of the hottest fuel pin is calculated using the THETA1-B computer program.

LOCA licensing calculations for older fuel batches, currently located in the spent fuel pool, may have been performed with the CRAFT2-based EM. In the event that an assembly in this category is reinserted into a new core design being licensed based on the RELAP5-based EM, additional evaluations and/or analyses are performed if necessary to demonstrate acceptability of the allowed LOCA LHR limits with respect to the new EM and current or existing plant boundary conditions. These evaluations are typically based on sensitivity studies that consider important boundary conditions, such as tube plugging, power level, ECCS capacity, etc., in order to determine an applicable PCT or LHR limit penalty.

### **9.2.2 RELAP5 EM**

The original NRC-approved analysis methodology of the RELAP5-based EM (reference 69) centers on the RELAP5/MOD2-B&W computer code (reference 75, revision 3). However, several other computer codes are also used to provide input to RELAP5 in order to obtain the prediction of the PCT. Steady-state fuel data for  $\text{UO}_2$  and gadolinia fuel is provided to the RELAP5-based EM by approved fuel codes, which are discussed in Section 9.2.3. The first three 10CFR50.46 criteria are evaluated explicitly by the EM on a fuel-specific basis. The coolable geometry is evaluated with a combination of generic and fuel-specific analyses as described in Section 4.0. The long-term core cooling is a combination of generic and plant specific analyses and evaluations that rely on operator actions based on the plant-specific EOPs. Some coolable geometry and long-term cooling analyses use extended EM analyses while others may use supplemental calculations.



The relationships between the computer codes for evaluation of the LBLOCA and SBLOCA transients are discussed in detail in the RELAP5-based LOCA EM (reference 69 as modified by reference 83), and are summarized here to provide reference to the individual codes that make up the EM. The CONTEMPT (reference 72) computer code defines the containment pressure response during the LBLOCA transient based on the limiting ECCS injection conditions. This response, which is determined via iteration with the RELAP5 and REFLOD3B codes, is input to the RELAP5 and REFLOD3B analyses for evaluation of the LBLOCA transient. This code is generally not used for SBLOCA evaluations because the break remains choked and the results are independent of the containment pressure response. In these cases, a maximum containment pressure is used. Larger break sizes could allow the break flow to unchoke. Under these conditions, the SBLOCA containment pressure can be computed by CONTEMPT or set to a lower value when conservative. The RELAP5 computer code (reference 75) calculates the system thermal-hydraulics, core power generation, and cladding temperature response during the blowdown portion of the LBLOCA transient, and for the entire SBLOCA transient. The initial conditions input to the REFLOD3B refill and reflood system thermal-hydraulic computer code (reference 76) represent the end of blowdown conditions from the RELAP5 analysis of the LBLOCA transient. REFLOD3B determines the core inlet fluid temperature and the core reflooding rate. Finally, the BEACH computer code (reference 77), which is equivalent to the RELAP5 code with the fine mesh rezoning option activated, determines the cladding temperature response during the reflood period with input from REFLOD3B.

Modifications to the RELAP5-based LOCA EM and the associated computer codes have been made since the EM was originally approved. These changes include, but are not limited to, NRC-approved modifications that support analysis of the M5<sup>®</sup> cladding material described in reference 18 and revision 4 of the RELAP5 code topical report (reference 75). An NRC-approved revision was made to the RELAP5 code topical (reference 75) to include the HTP CHF correlation for Mark-B-HTP fuel analyses as required by the EM. In addition, the application ranges for the BEACH code topical were modified and approved by the NRC as described in reference 77. Approval for the SBLOCA reactor coolant pump utilized when simulating an operator action is contained in references 79 and 80. These methods are also modified as described in the supplement (reference 83) to the RELAP5-based LOCA EM to address the burnup-dependent fuel TCD.

All LOCA analyses are performed in accordance with the limitations and restrictions placed on the EM and the individual codes, and this is verified during the execution and documentation of the analyses. This includes any approvals and limitations on the LOCA EM that may be included in associated topical reports. Additionally, any EM error corrections or changes made through the reporting requirements of 10CFR50.46 Section (a)(3)(ii) and/or through resolution of Preliminary Safety Concerns (PSCs) are considered or included in all licensing cases used to define the LOCA LHR limits that validate the core operating limits. In general, any EM corrections and changes made through the 10CFR50.46 process add conservatism to the analyses.

### 9.2.3 Steady-State Fuel Data Input to LOCA EMs

Steady-state fuel rod data, such as local volumetric fuel temperature as a function of LHR, fuel rod internal gas pressure, gap gas composition, and fuel rod dimensions and characteristics, are determined by an NRC-approved steady-state fuel rod computer code. The TACO3 (reference 24) fuel rod design code is one of the codes that may be utilized to provide steady-state fuel rod input data for UO<sub>2</sub> fuel with either Zircaloy-4 or M5<sup>®</sup> cladding. The TACO3 predicted best-estimate fuel temperatures are adjusted by an uncertainty factor to ensure that a 95%/95% upper bound tolerance on the volume average temperature is used in the LOCA applications. The EM and steady-state fuel code provide information used to define the uncertainty factors that are applied, since the value of the 95%/95% uncertainty factor is dependent on the bundle or pin that is modeled. The GDTACO (reference 28) fuel rod design code also predicts best-estimate fuel temperatures that are augmented by a 95%/95% upper bound tolerance factor for use in LOCA applications. GDTACO may be utilized for analysis of gadolinia fuel with either Zircaloy-4 or M5<sup>®</sup> cladding.

The TACO3 or GDTACO fuel performance codes do not explicitly model TCD with burnup. These codes are adequate for beginning-of-life applications, but the methodology outlined in reference 83 was developed to replace the reference 9 methods to adequately account for fuel TCD at burnups greater than 1 GWd/mtU. This revised methodology modifies the 95%/95% volume-average fuel temperature (VAFT) uncertainty calculated by TACO3 and GDTACO based on the COPENIC fuel performance code (reference 25) which explicitly accounts for fuel TCD as a function of burnup. Application of the methodology defined in reference 83 results in a TACO3 or GDTACO VAFT adjustment that assures the VAFT input into the RELAP5-based LOCA analyses is greater than or equal to the 95%/95% VAFT computed by COPENIC. The methodology changes defined in reference 83 adequately address burnup-dependent TCD effects on the LOCA LHR limits.

COPERNIC limits the maximum rod-average fuel burnup for gadolinia fuel to 55 GWd/mtU. This maximum gadolinia burnup limit is applied to the end-of-life gadolinia LOCA analyses and LHR limits as described in reference 83. The UO<sub>2</sub> LOCA analyses and associated LHR limits are restricted to a maximum rod-average burnup of 62 GWd/mtU.

### **9.3      *Generic LOCA Evaluations***

LOCA analyses are generally performed based on a full-core simulation of a single fuel assembly design with UO<sub>2</sub> fuel and result in the definition of an envelope of allowed LOCA LHR limits as a function of core elevation and time-in-life (TIL). For those plants that utilize different fuel assembly types, each assembly type has its own set of full-core LOCA LHR limits. The 10CFR50.46 criteria summarized above have been used for determining the acceptability of the consequences of a given accident for each assembly type. However, possible combinations of fuel assembly types are also evaluated by performing a mixed-core analysis, if necessary, due to hydraulic resistance differences.

The mixed-core analysis determines any LHR limit or PCT penalty that must be applied to the results of the full-core analysis. A penalty may be necessary due to the flow redistribution during the transient arising from differing fuel assembly hydraulic designs; including, but not restricted to, differing grid or end-fitting resistances as well as different fuel rod geometries. Mixed-core analyses specifically for fuel rod material changes (specifically Zircaloy-4 to M5<sup>®</sup>) are not necessary as described in the approved M5<sup>®</sup> cladding topical report (reference 18). Mixed-core LOCA analyses are primarily necessary for flow dominated transients such as the LBLOCA. The SBLOCA transient evolves much slower and core flow is relatively stagnant during the core uncovering phase. Therefore, mixed-core SBLOCA analyses are not typically needed because there is no flow diversion potential. Nonetheless, AREVA will evaluate mixed-core conditions for SBLOCAs if there are significant future evolutionary fuel assembly design changes that could potentially cause flow diversion during SBLOCA transients.

LOCA analyses for gadolinia fuel pins are also performed to determine the reduction in allowable LHR limit necessary to account for the decrease in the fuel thermal conductivity compared with a  $\text{UO}_2$  fuel rod of the same design. These evaluations are typically performed only at those elevations that have the limiting LOCA margin in the core power distribution analyses. Therefore, analyses that model the gadolinia fuel steady-state data are generally performed with axial peaking at the core inlet and sometimes for the core exit elevations. All burnup ranges and corresponding fuel thermal conductivity input are supplied to RELAP5, based on the methods described in the supplement to the RELAP5-based LOCA EM (reference 83) which accounts for burnup-dependent TCD when performing LOCA LHR limit analyses for the gadolinia pins. Analyses may be performed for each gadolinium concentration, or results obtained for a higher concentration may be conservatively applied to a lower concentration of gadolinium. The gadolinia fuel LHR limit reduction is applied to the  $\text{UO}_2$  LOCA LHR limits in order to define the envelope of maximum allowed LOCA LHR limit versus axial elevation and TIL for each analyzed gadolinium concentration.

Additional generic analyses and/or evaluations are performed as necessary to consider changes in plant operating conditions, such as degraded plant ECCS injection capacity. The analyses are performed according to the methods described in Section 9.2 and may define new LOCA LHR limits, or may impose penalties (LHR limit or PCT increase) on the results of a previous set of analyses.

Finally, special assembly conditions are evaluated as those conditions are identified. In some cases, generic studies may be performed that may define checks that must be validated on a cycle-specific basis. In other cases, cycle-specific evaluations are performed to justify operation for a single cycle. Examples include, but are not limited to, stainless steel replacement rods (approved in reference 23), slipped grids, loose rods, and LTAs.

#### **9.4      *Application of Generic Evaluations to Cycle-Specific Plant Conditions***

The plant design and core arrangement are evaluated each fuel cycle to ensure that the results of the licensing LOCA analyses remain bounding for the cycle-specific plant conditions. This includes the consideration of LHR or PCT penalties associated with a mixed-core configuration, or other special considerations or plant changes.

Fuel manufacturing changes in a given design are evaluated for each fresh batch of fuel to assure that the generic LOCA analyses remain applicable. This evaluation includes the examination of initial pin pressures, plenum volumes and fuel densities, and the calculated fuel-pin pressures and temperatures over the life of the fuel assembly. In each case, the predicted fuel-pin pressure and temperature response to burnup is compared with the boundary conditions used in the generic LOCA analysis to determine the acceptability of the fuel. Since the dynamics of the fuel during LOCAs involve both the internal pin pressure and temperature, these two parameters are evaluated together. Thus, variations in the pin pressure and fuel temperature are used to demonstrate the acceptability of the combination of the two. This approach uses existing sensitivity studies that define the relationships between these parameters. Based on these analyses, the acceptability of a given combination of pressures and temperatures is determined. A fuel design that leads to conditions not bounded by existing analyses requires new analyses or evaluations (either cycle-specific or generic) to be generated in order to define a new maximum LOCA LHR limit or to determine PCT penalties that are applied to previous analyses.

In addition to defining the maximum allowable LOCA LHR limit for each fuel design, cycle-specific checks are performed to assure that the results of the generic analyses remain applicable. The checks are related to resolutions for LOCA-related PSCs, and other cycle-specific conditions, such as any planned EOC RCS average temperature reduction maneuver, LTAs, etc. Specific limitations related to the approval of use of stainless steel replacement rods (reference 23) have been generically dispositioned and checks are made on a cycle-specific basis to ensure the applicability of the generic results.

As long as the acceptance criteria can be met for the combination of fuel assembly types for each reload fuel cycle, the cycle design is considered acceptable. Power distributions for the reload core design are evaluated at the limits of normal operation as described in Section 5.3 to ensure that the maximum LHR does not exceed the limits established by LOCA analyses performed to demonstrate compliance with the 10CFR50.46 criteria.

## **10.0 LIMITED SCOPE HIGH BURNUP LEAD TEST ASSEMBLIES**

### **10.1 *Use of Lead Test Assemblies***

WCAP-15604-NP, Revision 2-A (reference 78) provides generic guidelines for the irradiation of a limited number of Lead Test Assemblies (LTAs) to rod burnups greater than the current licensed lead rod average burnup limit. The NRC staff has reviewed this report and all conclusions apply to the entire commercial nuclear power industry, i.e., all pressurized water reactors (PWRs) and boiling water reactors (BWRs). The generic LTA guidelines will ensure uniformity in data collection, make the evaluation of new fuel properties or limits more predictable, ensure a structured process for data feedback to the NRC, and provide to fuel vendors and licensees a uniform process for implementing LTA programs. The inclusion of WCAP-15604-NP, Revision 2-A into BAW-10179 satisfies the requirement to incorporate this WCAP report explicitly into the licensee's Technical Specifications by virtue of its reference in BAW-10179.

### **10.2 *Definition of a Lead Test Assembly***

A limited scope LTA is a fuel assembly that is based on a currently available design and is capable of reaching higher burnups than currently used. The fuel cladding material is an NRC-approved cladding material. The assembly will receive pre-characterization prior to undergoing exposure in the "test" cycle that would permit the assembly to exceed current burnup limits. The fuel assembly shall be evaluated against and must meet all current design criteria even though the current analytical methodologies may not be approved for use at the higher burnups.

### **10.3 *Conditions for Limited Scope High Burnup LTA Program***

The following conditions for a limited scope high burnup LTA program must be met per the NRC Safety Evaluation (SE) referenced in WCAP-15604-NP, Revision 2-A:



1. If the COLR analytical methods listed in the licensee's Technical Specifications were approved up to a specified burnup limit, a license amendment is required to add this topical report to that list in order for the licensees to be able to use WCAP-15604-NP, Revision 2-A.
2. The number of fuel assemblies with fuel rods exceeding the current lead rod average burnup shall be limited to a total of nine in PWRs. No fuel rods shall exceed peak rod burnups greater than 75 GWd/mtU.
3. The fuel shall be typical production fuel and be pre-characterized before operation above the current lead rod average burnup limit. The fuel may also be an LTA that was characterized during fabrication and was designed to test aspects of the fuel assembly but was not initially identified as a high burnup LTA. The latter fuel shall be pre-characterized before operation above the current lead rod average burnup limit. The fuel clad material is a NRC-approved clad material.
4. The pre-characterization of the fuel shall consist of at least the following examinations: clad oxidation, rod/assembly growth, and visual examinations for PWRs.
5. The post-irradiation examinations of the fuel shall consist of at least the following examinations: clad oxidation, rod/assembly growth, and visual examinations for PWRs. Current or modified fuel performance methods and codes shall be used.
6. The fuel shall be evaluated against and must meet all current design criteria even though the current analytical methodologies may not be approved for use at the higher burnups.
7. For all fuel rods in the LTAs, the predicted oxidation shall be less than 100 microns on a best-estimate basis with prediction of no blistering or spallation based on current data.
8. A licensee using the limited scope high burnup LTA program shall submit two reports to the NRC for information.

The first report shall be a notification of intent to irradiate LTAs above the current maximum burnup limit. It shall contain at least the following information:

- Licensee name
- Plant name
- Cycle and date when the LTA shall be inserted
- Number of LTAs
- Location of the LTAs
- Anticipated pre- and post-cycle burnups for each LTA
- Purpose of the LTAs
- Estimated dates for pre- and post-irradiation characterizations or the results of the pre-characterization and an estimation of the date for the post-irradiation characterization
- Estimated date of the second report
- Statement that the LTAs will not be irradiated if Conditions 6 and 7 are not met or if the pre-characterization examinations show anomalous results

The second report shall give the results of the pre- and post-irradiation examinations. It shall consist of at least the following information:

- Licensee name
- Plant name
- Assembly identification number
- Specific measurements – actual data and predictions
- Comment section

## **10.4     *Nuclear Design and Safety Analysis Considerations***

### **10.4.1     Core Loading Pattern Development**

As cited in Condition 2 above, the maximum number of LTAs per cycle per core will be limited to nine assemblies. However, the NRC has recognized that to determine if an LTA meets the need for which it was designed, it must experience the same limiting conditions as other fuel in the reactor and should not be restricted in power or core location except as needed to meet design criteria. The unique aspect of the LTAs is that they are normal production fuel assemblies that will fall into two general categories. The LTAs will either be fuel assemblies that are reinserted for additional exposure after achieving a burnup instead of being discharged or fuel assemblies that have normal in-core residence times, but are positioned in-core so that the power level results in the highest current burnup limit being exceeded. The maximum lead rod average burnup that these limited scope LTAs would experience is 75 GWd/mtU.

### **10.4.2     Safety Analysis**

The inclusion of WCAP-15604-NP, Revision 2-A into BAW-10179 satisfies the requirement to incorporate this WCAP report explicitly into the licensee's Technical Specifications by virtue of its being referenced in BAW-10179. BAW-10179 defines the safety criteria and methodologies used for reload safety analyses. These same safety criteria and methodologies will be used to analyze a core containing high burnup LTAs. Hence, the inclusion of WCAP-15604-NP, Revision 2-A in BAW-10179 will preclude the submittal of a License Amendment Request by the licensee to use high burnup LTAs as long as the conditions defined in Section 10.0 are met.

As part of the safety analysis, an assessment must be made of the models that have been reviewed and approved by the NRC for the purpose of evaluating the performance of the LTAs beyond current burnup limits. The analytical models used to evaluate the performance of the LTAs beyond current burnup limits may need to be modified versions of the models reviewed and approved by the NRC. In some cases, conservatism may be added, as appropriate. If available data indicates that the approved models are appropriate, then no modifications to the approved models will be necessary. The revised models would be used only for the limited scope high burnup LTAs and not for any other assemblies in the core. The justification of the model revisions will be documented and available for NRC review in accordance with the 10 CFR 50.59 criteria.

#### **10.5      *Evaluation of Limited Scope High Burnup LTAs***

Section 10.0 summarizes the requirements for a limited scope high burnup LTA program. Sections 1.0 through 9.0 of this topical report describe the methods and models used to evaluate core and fuel assembly performance up to the current burnup limits. These same methods and models delineated in Sections 1.0 through 9.0 will be used to evaluate core and LTA fuel assembly performance in a limited scope high burnup LTA program. All model revisions made to show satisfactory LTA performance must meet the requirements discussed in Section 10.4.2.

## 11.0 REFERENCES

1. Memorandum for Jose A. Calvo from David C. Fischer, Subject: Minutes of Meeting with the B&W Owners Group (BWOOG) on the Technical Basis and Scope of the BWOOG Core Operating Limits Report, July 19, 1989.
2. Title 10 Code of Federal Regulations (10CFR), Part 100, Reactor Site Criteria.
3. Title 10 Code of Federal Regulations (10CFR), Part 50, Licensing of Production and Utilization Facilities:
  - a. Appendix A, General Design Criterion 10, Reactor Design.
  - b. Part 50.46, Acceptance Criteria for Emergency Core Cooling Systems for Light Water Nuclear Power Reactors.
  - c. Appendix A, General Design Criterion 28, Reactivity Limits.
  - d. Appendix A, General Design Criterion 26, Reactivity Control System Redundancy and Capability.
  - e. Part 50.36, Technical Specifications.
  - f. Appendix A, General Design Criterion 12, Suppression of Reactor Power Oscillations.
4. BAW-10241P-A, Revision 1, "BHTP DNB Correlation Applied With LYNXT", July 2005.
5. BAW-10229P-A, "Mark-B11 Fuel Assembly Design Topical Report," April 2000.
6. ASME Code Section III, "Nuclear Power Plant Components," 1992 Edition.
7. BAW-1781P, "Rancho Seco Cycle 7 Reload Report - Volume 1- Mark BZ Fuel Assembly Design Report," April 1983.
8. Standard Review Plan, Section 4.2, NUREG-0800, Revision 2, U.S. Nuclear Regulatory Commission, July 1981.
9. BAW-10186P-A, Revision 2, "Extended Burnup Evaluation," June 2003.

10. BAW-10147P-A, Revision 1, "Fuel Rod Bowing in Babcock & Wilcox Fuel Designs," May 1983.
11. BAW-10133P-A, Revision 1, "Mark-C Fuel Assembly LOCA-Seismic Analyses," June 1986.
12. BAW-10133P-A, Revision 1, Addendum 1 and Addendum 2, "Mark-C Fuel Assembly LOCA-Seismic Analyses," October 2000.
13. BAW-1847, Revision 1, "Leak-Before-Break Evaluation of Margin against Full Break for RCS Primary Piping of B&W Designed NSS," September 1985.
14. BAW-1889P, "Piping Material Properties for Leak-Before-Break Analysis," October 1985.
15. BAW-1999, "TMI-1 Nuclear Power Plant Leak-Before-Break Evaluation of Margins Against Full Break for RCS Primary Piping," April 1987.
16. BAW-2292, "Framatome Mark-B Fuel Assembly Spacer Grid Deformation in B&W Designed 177 Fuel Assembly Plants," February 1997 and supplemented by NRC letter dated August 20, 1997 ("Safety Evaluation of the Babcock & Wilcox Owners Group Submittal Relating to Assumptions in the B&W ECCS Analysis," TAC# M95480).
17. NPGD-TM 596, Revision 6, ANSYS Engineering Analysis System, User's Manual (R4 ANSYS), February 1984.
18. BAW-10227P-A, Revision 1, "Evaluation of Advanced Cladding and Structural Material (M5) in PWR Reactor Fuel," June 2003.
19. BAW-10153P-A, "Extended-Burnup Evaluation," April 1986.
20. Letter from J. H. Taylor to NRC Document Control Desk, Application of BAW-10186P, JHT/97-7, January 23, 1997.
21. Letter from J. H. Taylor to NRC Document Control Desk, Application of BAW-10186P-A, Extended Burnup Evaluation, JHT/97-39, October 28, 1997.

22. Letter from J. H. Taylor to R. C. Jones, Response to Question 13, JHT/95-88, August 22, 1995.
23. BAW-2149-A, "Evaluation of Replacement Rods in BWFC Fuel Assemblies," September 1993.
24. BAW-10162P-A, "TACO3 - Fuel Pin Thermal Analysis Computer Code," October 1989.
25. BAW-10231P-A, Revision 1, "COPERNIC Fuel Rod Design Computer Code," January 2004.
26. BAW-10084PA, Revision 3, "Program to Determine In-Reactor Performance of BWFC Fuel Cladding Creep Collapse," July 1995.
27. O'Donnell, W.J. and B.F. Langer, "Fatigue Basis for Zircaloy Components," Nuclear Science and Engineering , Volume 20, 1964.
28. BAW-10184P-A, "GDTACO, Urania-Gadolinia Fuel Pin Thermal Analysis Code," February 1995.
29. Letter from R. C. Jones (NRC) to J. H. Taylor, Extending Burnup Limit for TACO3, January 11, 1996.
30. Letter from R. C. Jones (NRC) to J. H. Taylor, Concerning Fuel Rod Power History Uncertainty with TACO3, October 18, 1995.
31. BAW-10183P-A, "Fuel Rod Gas Pressure Criterion (FRGPC)," July 1995.
32. BAW-10180-A, Revision 1, "NEMO – Nodal Expansion Method Optimized," March 1993.
33. STUDSVIK/NFA-89/3, "CASMO-3 – A Fuel Assembly Burnup Program," Studsvik Energiteknik AB, November 1989.
34. BAW-10221P-A, "NEMO-K A Kinetics Solution in NEMO," September 1998.
35. BAW-10122A, Revision 1, "Normal Operating Controls," May 1984.
36. BAW-10118A, "Core Calculational Techniques and Procedures," December 1979.

37. BAW-10054, Revision 2, "Fuel Densification Report", May 1973.
38. Letter from D.M. Crutchfield (NRC) to J.H. Taylor (B&W), Subject: Acceptance for Referencing of a Special Licensing Report, December 5, 1986.
39. Letter from Roger Powers (BWOOG) to L.S. Rubenstein (NRC), Subject: Discussion of NRC Question on Extended Low Power Operation, July 11, 1984.
40. Letter from J.H. Taylor (B&W) to J.A. Norberg (NRC), Subject: Extended Lifetime Incore Detector Error Allowances, April 21, 1988.
41. Letter from R.C. Jones to J.H. Taylor Accepting Revised Measurement Uncertainty for Control Rod Worth Calculations, January 26, 1996.
42. ANSI/ANS-19.6.1-1997 (or latest revision), "Reload Startup Physics Tests for Pressurized Water Reactors", American Nuclear Society.
43. BAW-10120P-A, "Comparison of Core Physics Calculations with Measurements," March, 1978.
44. BAW-10000-A, "Correlation of Critical Heat Flux in a Bundle Cooled by Pressurized Water," May 1976.
45. BAW-10143P-A, "BWC Correlation of Critical Heat Flux," April 1985.
46. BAW-10199P-A, "The BWU Critical Heat Flux Correlations," August 1996.
47. BAW-10021, "TEMP - Thermal Energy Mixing Programs," May 1970.
48. BAW-10129-A, "LYNX-1 - Reactor Fuel Assembly Thermal-Hydraulic Analysis," July 1985.
49. BAW-10130-A, "LYNX-2 - Subchannel Thermal-Hydraulic Analysis Program," July 1985.
50. BAW-10156P-A, Revision 1, "LYNXT Core Transient Thermal-Hydraulic Program," August 1993.
51. BAW-10199P-A, Addendum 1, "The BWU Critical Heat Flux Correlations," December 2000.



52. BAW-10199P-A, Addendum 2, "The BWU Critical Heat Flux Correlations," June 2002.
53. BAW-1829, "Thermal-Hydraulic Crossflow Applications," April 1984.
54. BAW-10141PA, Revision 1, "TACO2 Fuel Pin Performance Analysis," June 1983.
55. Letter, K. E. Suhrke (B&W) to Mr. S. A. Varga (NRC), December 6, 1976.
56. Letter, S. A. Varga to J. H. Taylor, Update of BAW-10055, "Fuel Densification Report," December 5, 1977.
57. BAW-10037, Revision 1, "Reactor Vessel Model Flow Tests," November 1972.
58. BAW-1532-8, "Development of an Extended-burnup Mark B Design, Eighth Progress Report: July 1982 - June 1983," March 1984 (DOE/34213-11).
59. BAW-1546-4, "Qualification of the B&W Mark B Fuel Assembly for High Burnup, Fourth Semi-Annual Progress Report: January-June 1980," Sept 1980 (DOE/ET/34212-28).
60. BAW-1874, "The Hot Cell Examination of Oconee 1 Fuel Rods After Five Cycles of Irradiation," October 1986 (DOE/ET/34212-50).
61. EPRI Report NP-3966-CCM, "CEPAN Method of Analyzing Creep Collapse of Oval Cladding, Volume 5: Evaluation of Interpellet Gap Formation and Clad Collapse in Modern PWR Fuel Rods," Combustion Engineering, Inc., April 1985.
62. BAW-10187P-A, "Statistical Core Design for B&W Designed 177 FA Plants," March 1994.
63. BAW-10110A, Revision 2, "CHATA - Core Hydraulics and Thermal Analysis," October, 1983.
64. BAW-10069A, Revision 1, "RADAR Reactor Thermal-Hydraulic Analysis During Reactor Flow Coastdown," October 1974.
65. BAW-10193P-A, "RELAP5/MOD2-B&W For Safety Analysis of B&W-Designed Pressurized Water Reactors," January 2000.

66. ANL-7225, Argonne National Laboratory Chemical Engineering Division Semi-Annual Report, "Studies in TREAT of Zircaloy-2 Clad  $\text{UO}_2$ -Core Simulated Fuel Elements," R.C. Liimatainen and F.J. Testa, January-June 1966.
67. BAW-10104P-A, Revision 5, "B&W ECCS Evaluation Model," November 1986.
68. BAW-10154-A, "B&W's Small-Break LOCA ECCS Evaluation Model," July 1985.
69. BAW-10192P-A, "BWNT LOCA – BWNT Loss-of-Coolant Accident Evaluation Model for Once-Through Steam Generator Plants," June 1998.
70. BAW-10092-A, Revision 3, "CRAFT2 -- Fortran Program for Digital Simulation of a Multinode Reactor Plant During Loss of Coolant," July 1985.
71. BAW-10148-A, "REFLOD3 -- Model for Multinode Core Reflooding Analysis," September 1987.
72. BAW-10095-A, Revision 1, "CONTEMPT – Computer Program for Predicting Containment Pressure-Temperature Response to a LOCA," April 1978.
73. BAW-10094-A, Revision 3, "Babcock & Wilcox Revisions to THETA1-B, a Computer Code for Nuclear Reactor Core Thermal Analysis (IN-1445)," June 1986.
74. BAW-10155-A, "FOAM2 – Computer Program to Calculate Core Swell Level and Mass Flow Rate During Small-Break LOCA," October 1987.
75. BAW-10164P-A, Revision 6, "RELAP5/MOD2-B&W – An Advanced Computer Program for Light Water Reactor LOCA and Non-LOCA Transient Analysis," June 2007.
76. BAW-10171P-A, Revision 3, "REFLOD3B – Model for Multinode Core Reflooding Analysis," December 1995.
77. BAW-10166P-A, Revision 5, "BEACH – A computer Program for Reflood Heat Transfer During LOCA," November 2003.
78. WCAP-15604-NP, Revision 2-A, "Limited Scope High Burnup Lead Test Assemblies," September 2003.

79. Letter from H. N. Berkow (NRC) to J. F. Mallay (Framatome ANP), Subject: Evaluation of Framatome ANP Preliminary Safety Concern (PSC) 2-00 Relating to Core Flood Line Break and Operator Action Time, April 10, 2003.
80. Letter from R. A. Gramm (NRC) to J. S. Holm (Framatome ANP), Subject: Request for Amendment of Safety Evaluation for "Report of Preliminary Safety Concern (PSC) 2-00 Related to Core Flood Line Break with 2-Minute Operator Action Time, January 10, 2005.
81. BAW-10242-A, "ZPPT Modifications for B&W Designed Reactors," November 2003.
82. BAW-10243P-A, "Statistical Fuel Assembly Hold Down Methodology," September 2005.
83. BAW-10192PA Revision 0 Supplement 1P-A Revision 0, "BWNT LOCA – BWNT Loss-of-Coolant Accident Evaluation Model for Once-Through Steam Generator Plants," November 2017.
84. Letter from Kevin Hsueh (NRC) to Gary Peters (AREVA Inc.), "Request for U.S. Nuclear Regulatory Commission Concurrence Regarding the Applicability of Topical Report BWR-2149A, 'Evaluation of Replacement Rods in BWFC Fuel Assemblies' to Cores Containing Fresh Fuel Assemblies with Stainless Steel Rods," February 1, 2017.

Original Pages for BAW-10179NP-A, Revision 9,

- Page ii
- Page xiv
- Page 1-3
- Page 1-5
- Page 4-3
- Page 4-16
- Page 4-20
- Page 5-28
- Page 6-30
- Page 11-7

| <b>Item</b> | <b>Section(s) or Page(s)</b>  | <b>Description and Justification</b>  |
|-------------|---|---|
| 9           | Section 4.2.9.1<br>Fuel Temperature<br>(Centerline Fuel<br>Melt) Limit Analysis<br>Criteria | Updated to correct and clarify criteria for application to predicted maximum fuel temperature of UO <sub>2</sub> and gadolinia fuel types.  |
| 10          | Section 4.2.9.2<br>Fuel Temperature<br>(Centerline Fuel<br>Melt) Limit Analysis<br>Method   | Updated to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPERNIC applications, and to clarify application of burnup-dependent fuel melt limits in analyses.  |
| 11          | Section 6.1<br>Core Thermal-<br>Hydraulics Design<br>Criteria                               | Revised for consistency with approved response to RAI Question #6 of BAW-10179P Revision 0  |
| 12          | Section 9.0<br>Loss-of-Coolant<br>Accident<br>Evaluation                                    | Revised to address analysis methodology changes for the fuel initialization codes and adjustments to the fuel pin input and steady-state initialization process for the LOCA transient codes to account for burnup-dependent fuel thermal conductivity degradation (TCD) as described in the supplement to BAW-10192P-A Revision 0. |
| 13          | Section 11.0<br>References  | a) Updated Reference 75 to refer to BAW-10164P-A Revision 6, consistent with BAW-10179P-A Revision 8.<br>b) Added Reference 83 to BAW-10179P.   |
| 14          | Throughout  | Updated report format to conform to AREVA's current topical report style guide; updated Company name; and corrected misspelled words and symbols.   |

(Section 9.0).

- Update the methodology for fuel assembly stress analysis criteria (Section 4.1.2.1), fuel assembly grid strength definition (Section 4.1.9.2), and fuel rod stress analysis criteria (Section 4.2.5.1) to be consistent with the response to RAI Question 13 issued during the review of BAW-10179P Revision 0.
- Update the fuel assembly hold down analysis criteria (Section 4.1.3.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Update the transient cladding strain analysis description (Section 4.2.6.2) to correct and clarify differences in transient cladding strain definitions used in approved TACO3, GDTACO, and COPERNIC applications.
- Update the fuel rod pressure analysis description (Section 4.2.8.2) to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPERNIC applications.
- Update the fuel temperature (centerline fuel melt) limit analysis criteria (Section 4.2.9.1) and analysis method description (Section 4.2.9.2) to correct and clarify application to  $\text{UO}_2$  and gadolinia fuel types, and to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPERNIC applications.
- Update the core thermal-hydraulics design criteria (Section 6.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Correct misspelled words and symbols, as appropriate, throughout the report.

(Section 9.0).

- Update the methodology for fuel assembly stress analysis criteria (Section 4.1.2.1), fuel assembly grid strength definition (Section 4.1.9.2), and fuel rod stress analysis criteria (Section 4.2.5.1) to be consistent with the response to RAI Question 13 issued during the review of BAW-10179P Revision 0.
- Update the fuel assembly hold down analysis criteria (Section 4.1.3.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Update the transient cladding strain analysis description (Section 4.2.6.2) to correct and clarify differences in transient cladding strain definitions used in approved TACO3, GDTACO, and COPENIC applications.
- Update the fuel rod pressure analysis description (Section 4.2.8.2) to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications.
- Update the fuel temperature (centerline fuel melt) limit analysis criteria (Section 4.2.9.1) and analysis method description (Section 4.2.9.2) to correct and clarify application to UO<sub>2</sub> and gadolinia fuel types, and to correct and clarify differences in approved fuel rod average burnup limits for TACO3, GDTACO, and COPENIC applications.
- Update the core thermal-hydraulics design criteria (Section 6.1) for consistency with the approved response to RAI Question #6 of BAW-10179P Revision 0.
- Correct misspelled words and symbols, as appropriate, throughout the report.

AREVA has developed criteria for determining when a design change must be submitted to the NRC for review and approval. The criteria are:

1. The change meets any of the eight criteria specified in paragraph (c)(2) of 10CFR50.59.
2. A change to the plant technical specifications is required.
3. The applicability of NRC-approved design/analysis evaluation methods is affected.

This report describes the entire spectrum of methodologies that are applicable to the reload fuel currently supplied by AREVA for the B&W 177-FA plants. An overview of the design considerations addressed in these methods is provided in Section 2.0. A brief description of the Mark-B fuel design is provided in Section 3.0. The mechanical design methods are described in Section 4.0. The nuclear design methods are described in Section 5.0, which also includes the radiological evaluation parameters. The thermal-hydraulics methods are described in Section 6.0. Section 7.0 includes the methods for determining reactor protection system (RPS) trip setpoints. Section 8.0 describes the non-LOCA accident evaluation methods, and Section 9.0 presents the LOCA accident evaluation methods. Figure 1-1 provides an overview on how the different analytical disciplines interact to complete a reload evaluation. Section 10.0 provides generic guidelines on the use of limited scope high burnup lead test assemblies.

The methodology described in this report is constantly evolving to include improvements and enhancements to analytical techniques. This will result in a succession of updates to BAW-10179P-A. To facilitate these updates AREVA will implement the following procedure:

1. For revisions to NRC-approved topical reports already referenced in BAW-10179P-A, such revisions will be incorporated by referencing the latest approved revision in the COLR.
2. For new methodology topical reports, AREVA will prepare a corresponding revision to BAW-10179P-A and include it with the submittal. The revision to BAW-10179P-A will include an appendix that provides a brief summary of the methodology topical and its range of applicability. When the NRC completes its review of the methodology topical, a single SER will be issued which approves both the methodology topical and the revision to BAW-10179P-A. Accepted versions of both topical reports will then be prepared and the latest revision of BAW-10179P-A will be available for referencing in the plant COLR. Any NRC conditions or limitations on the methodology will be included in the accepted version of BAW-10179P-A.



where

$P_m$  = general primary membrane stress intensity,

$P_l$  = local primary membrane stress intensity,

$P_b$  = primary bending stress intensity,

$Q$  = secondary stress,

$S_m$  = allowable membrane stress intensity which is equal to the lowest of following:

For Zircaloy and M5<sup>®</sup> components:

$S_m = 2/3 S_y$  or  $1/3 S_u$ , whichever is less at room temperature, or

$S_m = 2/3 S_y$  or  $1/3 S_u$  at operating temperature.

(For conservative purposes, the unirradiated material properties are used to define the stress limits. Room temperature values are the minimum specified.)

For stainless steel and Inconel components:

$S_m = 2/3 S_y$  or  $1/3 S_u$  at room temperature,

$S_m = 1/3 S_u$  or  $0.9 S_y$  at operating temperature.

(For conservative purposes, the stainless steel unirradiated material properties are used to define the stress limits. Room temperature values are the minimum specified.)

$S_y$  = minimum yield stress,

$S_u$  = ultimate stress.

#### **4.1.13 Stainless Steel Replacement Rod Methodology**

The in-field repair of irradiated fuel assemblies with leaking rods involves the replacement of defective fuel rods with heat producing and/or non-heat producing rods. BAW-2149-A (reference 23) provides justification for the use of replacement rods without imposing unnecessary power peaking restrictions on the repaired fuel assemblies. This report addresses the nuclear, thermal-hydraulic, and mechanical aspects of the design that are affected by repair operations. The use of replacement rods for AREVA supplied fuel assemblies is determined to be acceptable by the NRC per the SER included in BAW-2149-A.

The stainless steel replacement rods weigh slightly less than Zircaloy-clad fuel rods, but the effect on fuel assembly weight of up to 10 replacement rods is negligible. Therefore, the use of stainless steel replacement rods has an insignificant effect on fuel assembly hydraulic lift.

Stainless steel replacement rods are designed and analyzed to ensure that there is no adverse impact on fuel assembly performance. The rods are designed to ensure that adequate performance with respect to differential thermal expansion, irradiation growth, seismic-LOCA response, grid relaxation, and fretting due to vibration will be maintained. The replacement rods can be installed in any fuel rod location in the fuel assembly.

#### **4.2 Fuel Rod Design**

The design of the fuel rod must ensure that the integrity of the cladding is maintained under all Condition I and II events. The integrity of the cladding is maintained by requiring that the fuel rod design meet the constraints discussed below.

Analysis criteria and methods are applicable to both Zircaloy-4 and M5<sup>®</sup> cladding types as noted. The M5<sup>®</sup> cladding is approved for use in AREVA fuel in reference 18.

#### **4.2.5 Stress**

##### **4.2.5.1 Analysis Criteria**

### **5.4.1 Transient Neutronic Parameters**

The safety analysis evaluations performed for the accidents in the SAR assumed values for the neutronic parameters related to the reactivity coefficients and worths, control system reactivity, kinetics, and transient power peaking. When the accidents were analyzed, parametric cases were evaluated to determine the combination of conditions and the key neutronic parameters that would produce the most severe transients. The resulting limiting conditions, and bounding values of the key neutronic parameters, are the ones that must be analyzed for each reload cycle. The methodology used for the reload analysis must consequently ensure that the calculations of the key neutronic parameters are performed with the appropriate limiting conditions. The results are then reviewed using the methods described in Section 8.0 to ensure that the values are bounded by those used in the safety analyses. If the reload calculations contain the proper conditions, and the results are within the bounds of the reference safety analysis, then the SAR results will continue to be applicable to each respective reload cycle.

#### **5.4.1.1 Acceptance Criteria**

1. The key neutronic parameters shall be determined using the appropriate limiting conditions. The key neutronic parameters are then reviewed using the methods described in Section 8.0 to ensure that the values are bounded by those used in the safety analysis.
2. Design changes shall be reviewed with respect to the accident scenarios in the safety analyses to ensure that the change does not affect the scenario for defining the appropriate limiting conditions for calculating the neutronic parameters.

1. The LCO on RCS pressure is established such that during normal plant operation the steady-state core exit pressure will be maintained at a level greater than or equal to the value assumed for DNBR analysis of Condition II transients from full power.
2. The LCO on RCS hot leg temperature is established such that during normal plant operation the steady-state RCS hot leg temperature will not be greater than that corresponding to the initial conditions assumed for DNBR analysis of Condition II transients from full power.
3. The LCO on RCS flow rate is established such that during normal plant operation the steady-state RCS flow rate will not be less than the initial condition value assumed for DNBR analysis of Condition II transients initiated from full power.

Transient core thermal-hydraulic analyses are performed with either a single-pass LYNXT model or the closed-channel RADAR code initialized to a LYNXT initial condition DNBR prediction. For full-power transients, the initial conditions modeled are as described in Table 6-2. Transient inputs to the core thermal-hydraulic calculation typically include RCS flow and pressure, core inlet temperature, and neutron power.

## **6.8      *Stainless Steel Replacement Rod Methodology***

BAW-2149-A (reference 23) defines a methodology for the use of stainless steel replacement rods in AREVA fuel designs. Reference 23 addresses the nuclear, thermal-hydraulic, and mechanical aspects of the fuel design that are affected by the use of stainless steel replacement rods.

NRC approval has been obtained for the methodology for the use of as many as ten stainless steel replacement rods within a single fuel assembly. From a DNB perspective, the impact of the stainless steel rods on the peaking of adjacent heat-producing fuel rods is to be explicitly examined on a cycle-by-cycle basis to ensure continued compliance to the  $F_{\Delta H}^N$  design limit.

79. Letter from H. N. Berkow (NRC) to J. F. Mallay (Framatome ANP), Subject: Evaluation of Framatome ANP Preliminary Safety Concern (PSC) 2-00 Relating to Core Flood Line Break and Operator Action Time, April 10, 2003.
80. Letter from R. A. Gramm (NRC) to J. S. Holm (Framatome ANP), Subject: Request for Amendment of Safety Evaluation for "Report of Preliminary Safety Concern (PSC) 2-00 Related to Core Flood Line Break with 2-Minute Operator Action Time, January 10, 2005.
81. BAW-10242-A, "ZPPT Modifications for B&W Designed Reactors," November 2003.
82. BAW-10243P-A, "Statistical Fuel Assembly Hold Down Methodology," September 2005.
83. BAW-10192P-A, Revision 0, Supplement 1P, Revision 0, "BWNT LOCA – BWNT Loss-of-Coolant Accident Evaluation Model for Once-Through Steam Generator Plants," November 2015.