

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8704150313 DOC. DATE: 87/04/10 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 WOODY, C. O. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Mar 1987 progress summary for select sys assessment.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD2-2 LA | 1 0 | PD2-2 PD | 5 5 |
| | McDONALD, D | 1 1 | | |
| INTERNAL: | ARM/A&F/LFMB | 1 0 | NRR/DEST/ADE | 1 1 |
| | NRR/DEST/ADS | 1 1 | NRR/DLPQ/HFB | 1 1 |
| | NRR/DOEA/TSB | 1 1 | NRR/PMAS/ILRB | 1 1 |
| | OGC/HDS2 | 1 0 | REG FILE 01 | 1 1 |
| EXTERNAL: | EG&G BRUSKE, S | 1 1 | LPDR | 1 1 |
| | NRC PDR | 1 1 | NSIC | 1 1 |



APRIL 10 1987

L-87-163

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Select System Assessment Progress Summary

Attached please find the March 1987 progress summary of the Select System Assessment.

If you have any questions regarding this information, please contact us.

Very truly yours,

C.O. Woody
Group Vice President
Nuclear Energy


COW/RG/gp

Attachment

cc: Dr. J. Nelson Grace, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

8704150313 870410
PDR ADDCK 05000250
R PDR

Adol



SELECT SYSTEM REVIEW
MARCH 1987, PROGRESS

Reconstitution of Design Basis

Development of design verification procedures and criteria is continuing.

Walkdowns

Two hundred and seven (207) small piping and tubing walkdowns are complete.

One hundred and fifty-two (152) breaker list walkdowns are complete.

One hundred and twenty (120) P&ID walkdowns are complete.

Other Significant Progress

- Closed various Non-Conformance Reports (NCRs) on the Component Cooling Water System
- Closed various NCRs on the Intake Cooling Water System
- Reviewed effect of PC/M 76-14 modifications to the Main Steam Isolation Valves (MSIV's) on the vendor's original seismic analysis. The original analysis was not affected and the PC/M was closed out
- Confirmed FSAR start time for Emergency Diesel Generators (EDG) and corrected Operating Procedure
- Collected EPRI/NSAC data for station blackout study.
- Issued EDG electrical preventive maintenance procedure
- Evaluated manual loading of CRDM coolers against 10CFR21 criteria
- Revised diesel procedure to check temperature of lube oil versus immersion heaters
- Revised various EDG procedures for consistency