

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8803250093 DOC.DATE: 88/03/18 NOTARIZED: NO DOCKET #
FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
AUTH.NAME AUTHOR AFFILIATION
CONWAY,W.F. Florida Power & Light Co.
RECIP.NAME RECIPIENT AFFILIATION
GRACE,J.N. Region 2, Ofc of the Director

SUBJECT: Responds to NRC Bulletin 88-002, "Rapidly Propagating
Fatigue Cracks in Steam Generator Tubes."

DISTRIBUTION CODE: IE11D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2
TITLE: Bulletin Response (50 DKT)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-2 LA	1 0	PD2-2 PD	1 1
EDISON,G	1 1		
INTERNAL: AEOD/DOA	1 1	AEOD/DSP	1 1
AEOD/DSP/TPAB	1 1	NRR/DEST/ADE8H3	1 1
NRR/DEST/ADS7E4	1 1	NRR/DEST/MEB9H3	1 1
NRR/DOEA/EAB11E	1 1	NRR/DOEA/GCB11A	1 1
NRR/DREP/EPB10D	1 1	NRR/PMAS/ILRB12	1 1
REG FILE 02	1 1	RES/DE/EIB	1 1
RGN2 FILE 01	1 1		
EXTERNAL: LPDR	1 1	NRC PDR	1 1
NSIC	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 18

FPL

- 3:39:39

MARCH 18 1988

L-88-123

Dr. J. Nelson Grace
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta St., N.W., Suite 2900
Atlanta, GA 30323

Dear Dr. Grace:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
NRC Bulletin 88-02: Rapidly Propagating
Fatigue Cracks in Steam Generator Tubes

NRC Bulletin 88-02 "Rapidly Propagating Fatigue Cracks in Steam Generator Tubes," requested predefined actions for holders of operating licenses or construction permits for Westinghouse designed nuclear power plants with steam generators having carbon steel support plates. The replacement steam generators installed in the Turkey Point Units 3 and 4 were fabricated with 405 stainless steel support plates and thus are not subject to these predefined actions. Florida Power & Light Company will continue to monitor the condition of the steam generators by periodic inspections per our Technical Specification requirements.

Very truly yours,


W. F. Conway
Acting Group Vice President
Nuclear Energy

WFC/SDF/gp

cc: Document Control Desk, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

SDF123.BUL

8803250093 880318
PDR ADOCK 05000250
Q DCD

an FPL Group company


11.5611

STATE OF FLORIDA)
) ss.
COUNTY OF PALM BEACH)

W. F. Conway being first duly sworn, deposes and says:

That he is an Acting Group Vice President of Florida Power & Light Company,
the Licensee herein;


That he has executed the foregoing document; that the statements made in this
document are true and correct to the best of his knowledge, information, and
belief, and that he is authorized to execute the document on behalf of said
Licensee.



W. F. Conway

Subscribed and sworn to before me this

18 day of MARCH, 1988.



Cheryl Z. Friedrich

NOTARY PUBLIC, in and for the County
of Palm Beach, State of Florida

My Commission expires: _____

NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXP. OCT.30,1991
BONDED THRU GENERAL INS. UND.