

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

SESSION NBR: 8903010086 DOC. DATE: 89/02/21 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME: CONWAY, W.F. AUTHOR AFFILIATION: Florida Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Responds to violations noted in Insp Repts 50-250/88-37 & 50-251/88-37.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	PD2-2	PD	1	1		EDISON, G	1	1	
INTERNAL:	AEOD		1	1		AEOD/DEIIB	1	1	
	DEDRO		1	1		NRR SHANKMAN, S	1	1	
	NRR/DEST DIR		1	1		NRR/DLPQ/PEB 11	1	1	
	NRR/DLPQ/QAB 10		1	1		NRR/DOEA DIR 11	1	1	
	NRR/DREP/EPB 10		1	1		NRR/DREP/RPB 10	2	2	
	NRR/DRIS DIR 9A		1	1		NRR/PMAS/ILRB12	1	1	
	NUDOCS-ABSTRACT		1	1		OE LIEBERMAN, J	1	1	
	OGC/HDS2		1	1		<u>REG FILE 02</u>	1	1	
	RGN2 FILE 01		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR	1	1	
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 23

R
I
D
S
/
A
D
D
S
/
A
D
D
S





FPL

P.O. Box 14000, Juno Beach, FL 33408-0420

FEBRUARY 21 1989

L-89-34
10 CFR 2.201

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Reply to Notice of Violation
Inspection Report 88-37

Florida Power & Light Company has reviewed the subject inspection report and pursuant to 10 CFR 2.201 the response is attached.

Very truly yours,



W. F. Conway
Senior Vice President - Nuclear

WFC/RHF/gp

Attachment

cc: Malcolm L. Ernst, Acting Regional Administrator,
Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

8903010086 89022:
PDR ADOCK 05000250
Q PDC



ATTACHMENT

RE: TURKEY POINT UNITS 3 AND 4
DOCKET NOS. 50-250 AND 50-251
IE INSPECTION REPORT 250-88-37 & 251-88-37

VIOLATION

Turkey Point Technical Specification 6.8 states written procedures and administrative policies shall be established and implemented for the Facility Fire Protection Program. Fire Protection Program Procedure O-ADM-016.2, Fire Brigade Program, Section 5.3.1 requires that any fire brigade member not attending the required training be removed from active status and not be assigned to fire brigade duty. The procedure requires each fire brigade member to attend planned meetings every three months.

Contrary to the above, four fire brigade members failed to attend the required planned meeting in second quarter 1988 and were not removed from active status. Consequently, at least one of these four members was assigned for fire brigade duty on twenty shifts during the month of July 1988 when they were ineligible per procedure. In addition, three other brigade members failed to attend their planned meeting within the required three month interval.

RESPONSE:

- 1) Florida Power and Light accepts the violation.
- 2) The reason for the violation was a failure to review the qualification status of prospective fire brigade members prior to placing them on active status.
- 3) The qualifications of the fire brigade members on the active roster were reviewed. This review identified additional fire brigade members who did not meet all qualification requirements. The unqualified members were determined to be ineligible for fire brigade assignment until their qualifications were brought up to date.
- 4) The fire protection program requires each fire brigade member to attend planned meetings every three months in order to qualify them for duty during the following three months. If this training is missed, but all other requirements are met, the fire brigade member continues to be eligible for duty for the remainder of the current month, but is ineligible for duty during the following month. An assignment sheet of eligible brigade members is prepared and forwarded to the Operations Department, by the Fire Protection Group, on a monthly basis. The Operations Department selects the on-duty fire brigade members from this assignment sheet.



In order to prevent ineligible personnel from being placed on the active fire brigade roster, procedure 0-ADM-16.2, Fire Brigade Program, has been revised to require monthly verification of eligibility for fire brigade members.

- 5)
 - a) The ineligible fire brigade members were not included on the February 1989 assignment sheet, which became effective on February 1, 1989.
 - b) Procedure 0-ADM-16.2 was revised on January 26, 1989.

