

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8908140260 DOC.DATE: 89/08/07 NOTARIZED: NO DOCKET #
 FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH.NAME AUTHOR AFFILIATION
 WOODY,C.O. Florida Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Special rept:on 890613-30,breached fire barriers & other
 fire protection sys impairments.

DISTRIBUTION CODE: IE22D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 1	PD2-2 PD	1 1
	EDISON,G	1 1		
INTERNAL:	ACRS MICHELSON	1 1	ACRS MOELLER	2 2
	ACRS WYLIE	1 1	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	AEOD/ROAB/DSP	2 2
	DEDRO	1 1	IRM/DCTS/DAB	1 1
	NRR/DEST/CEB 8H	1 1	NRR/DEST/ESB 8D	1 1
	NRR/DEST/ICSB 7	1 1	NRR/DEST/MEB 9H	1 1
	NRR/DEST/MTB 9H	1 1	NRR/DEST/PSB 8D	1 1
	NRR/DEST/RSB 8E	1 1	NRR/DEST/SGB 8D	1 1
	NRR/DLPQ/HFB 10	1 1	NRR/DLPQ/PEB 10	1 1
	NRR/DOEA/EAB 11	1 1	NRR/DREP/RPB 10	2 2
	NUDOCS-ABSTRACT	1 1	REG FILE 02	1 1
	RES/DSIR/EIB	1 1	RES/DSR/PRAB	1 1
	RGN2 FILE 01	1 1		
EXTERNAL:	EG&G WILLIAMS,S	4 4	FORD BLDG HOY,A	1 1
	L ST LOBBY WARD	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC MAYS,G	1 1
	NSIC MURPHY,G.A	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 41 ENCL 41

I/A-2
cut

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



FPL

P.O. Box 14000, Juno Beach, FL 33408-0420

AUGUST 7 1989

L-89-285

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Special Report - Breached Fire Barriers and
Other Fire Protection System Impairments

In accordance with Technical Specification 6.9.3.c, the attached Special Report is provided for your information.

Should there be any questions on this information, please contact us.

Very truly yours,

C. O. Woody
Acting Senior Vice President - Nuclear

COW/JRH/cm

Attachment

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

8908140240 890807
PDR ADOCK 05000250
S PDC

IE22
1/1

Attachment:

SPECIAL REPORT

FIRE PROTECTION SYSTEM IMPAIRMENTS REQUIRING NRC NOTIFICATION

PURPOSE:

Technical Specification (TS) 3.14.5.b requires the submission of a report to the NRC if a non-functional fire barrier penetration is not returned to functional status within 7 days. TS 3.14 also states that certain other conditions require NRC notification. In accordance with the above requirements, this special report is being submitted in order to notify the NRC.

EVENT:

See the attached list for Fire Protection Impairments being reported.

CAUSE AND CORRECTIVE ACTIONS:

FPI 2566 was for the installation of a conduit and the work is now complete. The rest of the FPIs were issued as a result of fire protection surveillances currently being performed. The impairments are being evaluated, and work on corrections is in progress. The plant continues to implement the compensatory measures as applicable.

STATUS UPDATE:

See the attached list for Fire Protection Impairments previously reported which have been closed.

SPECIAL REPORT

FIRE PROTECTION SYSTEM IMPAIRMENTS OPENED SINCE LAST REPORT
WHICH HAVE BEEN OPEN FOR LONGER THAN TECH SPEC LIMITSPage No. 1
07/07/89

FPI #	FEATURE TYPE	OPENED	CLOSED
2515	BARRIER THERMOLAG 3K1326	06/13/89	/ /
2519	BARRIER THERMOLAG 4K1431	06/14/89	06/22/89
2523	BARRIER THERMOLAG 3K1761	06/19/89	/ /
2524	BARRIER THERMOLAG 3K1785	06/19/89	/ /
2525	BARRIER THERMOLAG 3K1759	06/19/89	/ /
2529	PENETRATION 011S-M014	06/20/89	/ /
2534	MANHOLE 311	06/22/89	/ /
2537	BARRIER THERMOLAG PB3900	06/22/89	/ /
2538	BARRIER THERMOLAG 3K1811	06/22/89	/ /
2540	BARRIER THERMOLAG 3K1746	06/22/89	/ /
2541	PENETRATION 012W-M004	06/22/89	/ /
2544	PENETRATION 019S-E005	06/22/89	/ /
2548	PENETRATION 014N-M017	06/22/89	/ /
2551	BARRIER THERMOLAG 3A1388	06/22/89	/ /
2552	BARRIER 061N	06/23/89	/ /
2553	STRUCTURAL STEEL 103	06/23/89	/ /
2554	BARRIER THERMOLAG 3A1354	06/22/89	/ /
2556	BARRIER THERMOLAG 3A1352	06/22/89	/ /
2557	BARRIER THERMOLAG PB3895	06/22/89	/ /
2558	BARRIER THERMOLAG 3K1600	06/22/89	/ /
2559	BARRIER THERMOLAG 3K1739	06/22/89	/ /
2561	BARRIER THERMOLAG 3A1324	06/22/89	/ /
2566	BARRIER 058E	06/26/89	07/07/89

FPI #	FEATURE TYPE	OPENED	CLOSED
2569	STURCTRUAL STEEL 068	06/26/89	/ /
2570	BARRIER 061N	06/26/89	/ /
2574	BARRIER THERMOLAG 3A452	06/27/89	/ /
2575	PENETRATION 003E-M003	06/22/89	/ /
2579	BARRIER THERMOLAG 4J1760	06/23/89	/ /
2580	STRUCTRUAL STEEL 071	06/27/89	/ /
2582	BARRIER THERMOLAG 4J1761	06/23/89	/ /
2583	BARRIER THERMOLAG PB4877	06/28/89	/ /
2585	STRUCTRUAL STEEL 093	06/28/89	/ /
2586	STRUCTRUAL STEEL 095	06/28/89	/ /

STATUS UPDATE ON PREVIOUSLY REPORTED FIRE PROTECTION IMPAIRMENTS

<u>FPI No.</u>	<u>Reported Open</u>	<u>FPL Letter</u>	<u>Date Closed</u>
1525	05/06/88	L-88-203	06/29/89
1902	10/31/88	L-88-471	06/30/89
2254	02/23/89	L-89-058	06/30/89
2396	04/21/89	L-89-154	06/30/89
2406	04/21/89	L-89-154	06/30/89
2419	04/21/89	L-89-154	06/30/89
2425	04/21/89	L-89-154	06/30/89
2433	04/21/89	L-89-154	06/30/89
2426	04/21/89	L-89-154	06/25/89

