

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8910240212 DOC. DATE: 89/10/13 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 HARRIS, K.N. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Special rept re breached fire barriers & fire protection sys
 impairments opened longer than Tech Spec limits.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA EDISON, G	1 1 1 1	PD2-2 PD	1 1
INTERNAL:	ACRS MICHELSON	1 1	ACRS MOELLER	2 2
	ACRS WYLIE	1 1	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	AEOD/ROAB/DSP	2 2
	DEDRO	1 1	NRR/DEST/ESB 8D	1 1
	NRR/DEST/ICSB 7	1 1	NRR/DEST/MEB 9H	1 1
	NRR/DEST/MTB 9H	1 1	NRR/DEST/PSB 8D	1 1
	NRR/DEST/RSB 8E	1 1	NRR/DEST/SGB 8D	1 1
	NRR/DLPQ/HFB 10	1 1	NRR/DLPQ/PEB 10	1 1
	NRR/DOEA/EAB 11	1 1	NRR/DREP/RPB 10	2 2
	NUDOCS-ABSTRACT	1 1	REG FILE 02	1 1
	RES/DSIR/EIB	1 1	RGN2 FILE 01	1 1
EXTERNAL:	EG&G WILLIAMS, S	4 4	L ST LOBBY WARD	1 1
	LPDR	1 1	NRC PDR	1 1
	NSIC MAYS, G	1 1	NSIC MURPHY, G.A	1 1
	NUDOCS FULL TXT	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 38 ENCL 38



FPL

P. O. Box 3088, Florida City, FL 33034

L-89-364

OCT 13 1989

U: S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Special Report - Breached Fire Barriers and
Other Fire Protection System Impairments

The accordance with Technical Specification 6.9.3.c, the attached Special Report is provided for your information.

Should there be any questions on this information, please contact us.

Very truly yours,

K. N. Harris - Vice President
Turkey Point Plant Nuclear

KNH/JEC/VAK/DRP/DWH

Attachment

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

8910240212 891013
PDR ADOCK 05000250
S PNU

an FPL Group company

TE22
11

SPECIAL REPORT

FIRE PROTECTION SYSTEM IMPAIRMENTS REQUIRING NRC NOTIFICATION

PURPOSE:

Technical Specification (TS) 3.14.5.b requires the submission of a report to the NRC if a non-functional fire barrier penetration is not returned to functional status within 7 days. TS 3.14 also states that certain other conditions require NRC notification. In accordance with the above requirements, this special report is being submitted in order to notify the NRC.

EVENT:

See the attached list for Fire Protection Impairments (FPIs) being reported.

CAUSE AND CORRECTIVE ACTIONS:

The FPIs were issued as a result of Fire Protection surveillances being performed. The plant continues to implement the compensatory measures as applicable.

STATUS UPDATE:

See the attached list for Fire Protection Impairments that were previously reported and are now closed.

SPECIAL REPORT
FIRE PROTECTION SYSTEM IMPAIRMENTS OPENED SINCE LAST REPORT
WHICH HAVE BEEN OPEN FOR LONGER THAN TECH SPEC LIMITS

FPI #	FEATURE TYPE	OPENED	CLOSED
2717	BARRIER THERMOLAG 3K1785	08/15/89	08/29/89
2718	BARRIER THERMOLAG 3K1759	08/15/89	08/29/89
2719	BARRIER THERMOLAG 3K1811	08/15/89	08/29/89
2720	BARRIER THERMOLAG 3K1746	08/15/89	08/29/89
2734	BARRIER 028N	08/18/89	
2746	BARRIER 045W2	08/21/89	09/08/89
2747	BARRIER 040-S	08/21/89	
2748	BARRIER 038-F	08/21/89	
2749	BARRIER 045F	08/22/89	
2752	DOOR 67-1	08/23/89	
2753	DOOR 68-1	08/23/89	
2754	BARRIER 040F	08/24/89	
2755	BARRIER 055E	08/24/89	
2758	BARRIER 055S1	08/25/89	
2761	BARRIER 040C	08/25/89	
2762	BARRIER 004N	08/25/89	
2779	BARRIER 055N	08/28/89	
2784	BARRIER 040N	08/28/89	
2789	BARRIER 097E	08/30/89	
2790	BARRIER 097F	08/30/89	
2792	BARRIER 094W	08/31/89	
2795	BARRIER 096F	09/06/89	
2798	BARRIER 095F	09/07/89	
2799	BARRIER 132S	09/07/89	
2804	BARRIER 103F	09/07/89	
2805	BARRIER 104F	09/07/89	

FIRE PROTECTION SYSTEM IMPAIRMENTS PREVIOUSLY
NOT REPORTED CLOSED

FPI #	FEATURE TYPE	CLOSED	FPL LETTER & DATE	
2523	BARRIER THERMOLAG 3K1761	08/25/89	L-89-285	08/07/89
2524	BARRIER THERMOLAG 3K1785	08/31/89	L-89-285	08/07/89
2525	BARRIER THERMOLAG 3K1759	08/31/89	L-89-285	08/07/89
2529	PENETRATION 011S-M014	09/07/89	L-89-285	08/07/89
2538	BARRIER THERMOLAG 3K1811	08/31/89	L-89-285	08/07/89
2540	BARRIER THERMOLAG 3K1746	08/31/89	L-89-285	08/07/89
2541	PENETRATION 012W-M004	08/28/89	L-89-285	08/07/89
2557	BARRIER THERMOLAG PB3895	08/25/89	L-89-285	08/07/89
2602	BARRIER THERMOLAG 3K1796	09/14/89	L-89-301	08/16/89
2610	PENETRATION 020W-E051	09/07/89	L-89-301	08/16/89
2645	PENETRATION 055F-M016	08/28/89	L-89-301	08/16/89
2661	PENETRATION 045F-M006	08/28/89	L-89-333	09/14/89
2667	PENETRATION 004W2-M008	09/06/89	L-89-333	09/14/89
2672	PENETRATION 070S-M007	09/14/89	L-89-333	09/14/89
2673	PENETRATION 070S-M009	09/14/89	L-89-333	09/14/89
2687	BARRIER 013S	08/29/89	L-89-333	09/14/89
2713	BARRIER 022S2	08/25/89	L-89-333	09/14/89
2714	PENETRATION 108AF-E005	08/31/89	L-89-333	09/14/89