

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8911150250 DOC. DATE: 89/11/07 NOTARIZED: YES DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 GOLDBERG, J.H. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Provides addl items found not to meet criteria of position 7
 of Suppl 1 to NRC Bulletin 88-010.

DISTRIBUTION CODE: IE21D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: Bulletin Response 88-10 - Nonconforming Molded Case Circuit Breakers.

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL	
	PD2-2 LA		1	0		PD2-2 PD		1	1	
	EDISON, G		1	1						
INTERNAL:	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1	
	NRR DOEA/GCB 11		1	1		NRR GILL, A.S.		1	1	
	NRR GUILLEN, J		1	1		NRR POTAPOUS, U		1	1	
	NRR STONE, J.C.		1	1		NRR/DEST/ADS 7E		1	1	
	NRR/DEST/MEB 9H		1	1		NRR/DOEA/EAB 11		1	1	
	NRR/DOEA/GCB 11		1	1		NRR/DREP/EPB 10		1	1	
	NRR/PMAS/ILRB12		1	1		NUDOCS-ABSTRACT		1	1	
	REG FILE 02		1	1		RES/DSIR/EIB		1	1	
	RGN2 FILE 01		1	1						
EXTERNAL:	LPDR		1	1		NRC PDR		1	1	
	NSIC		1	1						

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM PI-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 22

AC-1



NOVEMBER 07 1989

L-89-394

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
NRC Bulletin No. 88-10
NONCONFORMING MOLDED-CASE CIRCUIT BREAKERS

NRC Bulletin No. 88-10, "Nonconforming Molded-Case Circuit Breakers," issued November 22, 1988, requested that licensees take actions to provide reasonable assurance that molded-case circuit breakers (CBs), including CBs issued with motor controllers, purchased for use in safety-related applications without verifiable traceability to the CB manufacturer perform their safety function. Florida Power & Light Company provided a response to that bulletin for Turkey Point Units 3 and 4 by letter (FPL letter No. L-89-119) dated April 3, 1989.

On August 3, 1989 the NRC issued Supplement 1 to NRC Bulletin 88-10. This supplement provided specific examples of common deficiencies identified by the NRC during their preliminary review of responses to the bulletin. In addition, it also provided the NRC position on issues that were not specifically addressed by the bulletin.

FPL has reviewed its April 3, 1989 submittal in accordance with NRC Bulletin 88-10, Supplement 1. Based on additional investigation with suppliers, the following additional items were found not to meet the criteria of position 7 of Supplement 1 to NRC Bulletin 88-10.

<u>Number</u>	<u>Item</u>	<u>Purchase Order</u>	<u>Supplier</u>
4	Model Q0230 Square D circuit breakers	#88655-90064 Turkey Point	Atlas Electric 1111 West 22nd Street Hialeah, FL 33010

8911150250 891107
PDR ADOCK 05000250
Q PDC

IEA
11

L-89-394

Page 2

The above breakers were traced from the supplier (Atlas Electric to Electrical Supplies, Inc. (ESI), Miami, FL (ESI invoice No. 235563 dated January 8, 1988). Efforts to trace ESI's documentation to the original manufacturer have not been successful.

The current status of these four breakers is as follows. One breaker is in use in a nonsafety-related application. One breaker is in stores and its use has been restricted. The location of the other two breakers has not been determined. FPL is continuing its efforts to locate these breakers, and will provide an update to this response by December 7, 1989.

This information supplements that provided in our April 3, 1989 response. The other actions required by the original bulletin will be completed as previously stated in our April 3, 1989 submittal.

Should you have any questions, please contact us.

Very truly yours,



J. H. Goldberg
Executive Vice President

JHG/TCG/gmp

cc: Stewart D. Ebnetter, Regional Administrator, Region II,
USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

STATE OF FLORIDA)
) ss.
COUNTY OF PALM BEACH)

R. J. Acosta being first duly sworn, deposes and says:

That he is an Acting Vice President Nuclear Energy, of Florida Power and Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.

R. J. Acosta
R. J. Acosta

Subscribed and sworn to before me this

7TH day of NOVEMBER, 1989.

Cheryl Z. Fredrick

NOTARY PUBLIC, in and for the County of
Palm Beach, State of Florida

My Commission expires _____
NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXP. OCT. 30, 1991
CONF. G THRU GENERAL INS. UND.