

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9001190248 DOC. DATE: 90/01/12 NOTARIZED: NO DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME AUTHOR AFFILIATION  
 HARRIS, K.N. Florida Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Special rept, breached fire barriers & other fire protection  
 sys impairments.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3  
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 1	PD2-2 PD	1 1
	EDISON, G	1 1		
INTERNAL:	ACRS MICHELSON	1 1	ACRS MOELLER	2 2
	ACRS WYLIE	1 1	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	AEOD/ROAB/DSP	2 2
	DEDRO	1 1	NRR/DET/ECMB 9H	1 1
	NRR/DET/EMEB9H3	1 1	NRR/DET/ESGB 8D	1 1
	NRR/DLPQ/LHFB11	1 1	NRR/DLPQ/LPEB10	1 1
	NRR/DOEA/OEAB11	1 1	NRR/DREP/PRPB11	2 2
	NRR/DST/SELB 8D	1 1	NRR/DST/SICB 7E	1 1
	NRR/DST/SPLB8D1	1 1	NRR/DST/SRXB 8E	1 1
	NUDOCS-ABSTRACT	1 1	<del>REG. FILE 02</del>	1 1
	RES/DSIR/EIB	1 1	RGN2 FILE 01	1 1
EXTERNAL:	EG&G WILLIAMS, S	4 4	L ST LOBBY WARD	1 1
	LPDR	1 1	NRC PDR	1 1
	NSIC MAYS, G	1 1	NSIC MURPHY, G.A	1 1
	NUDOCS FULL TXT	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 38 ENCL 38

IA



FPL

P.O. Box 14000, Juno Beach, FL 33408-0420

JAN 12 1990

L-90-17

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555


Gentlemen:

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Special Report - Breached Fire Barriers and  
Other Fire Protection Systems Impairments

In accordance with Technical Specification 6.9.3.c, the  
attached Special Report is provided for your information.

Should There be any questions on this information please  
contact us.

Very truly yours,

  
K. N. Harris  
Vice President  
Turkey Point Plant Nuclear

KNH/DRP/DWH/rat

Attachment

cc: Stewart D. Ebnetter, Regional Administrator, Region II,  
USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

9001190248 900112  
PDR ADOCK 05000250  
S PDC

TE22  
11



i

j

## SPECIAL REPORT

### FIRE PROTECTION SYSTEM IMPAIRMENTS REQUIRING NRC NOTIFICATION

#### PURPOSE:

Technical Specification (TS) 3.14.5.b requires the submission of a report to the NRC if a non-functional fire barrier penetration is not returned to functional status within 7 days. TS 3.14 also states that certain other conditions require NRC notification. In accordance with the above requirements, this special report is being generated in order to notify the NRC.

#### EVENT:

See attached list for Fire Protection Impairments (FPI) being reported.

#### CAUSE AND CORRECTIVE ACTIONS:

FPI 3017 was issued for the installation of a conduit in a barrier. FPI 3008 was issued for the repair of a penetration seal. The remaining FPI's were issued for access to areas where work is currently being performed. The plant continues to implement the compensatory measures as applicable.

#### STATUS UPDATE:

See attached list for Fire Protection Impairments that were previously reported and are now closed.



SPECIAL REPORT

FIRE PROTECTION SYSTEM IMPAIRMENTS OPENED SINCE LAST REPORT  
WHICH HAVE BEEN OPEN LONGER THAN TECH. SPEC. LIMITS

<u>FPI #</u>	<u>FEATURE TYPE</u>	<u>OPENED</u>	<u>CLOSED</u>
3008	Barrier 097E Penetration	11/29/89	
3011	Barrier 058C Hatch	11/30/89	
3012	Barrier 106F Penetration	12/02/89	
3017	Barrier 025E Penetration	12/05/89	12/19/89
3046	Barrier 054F Plug	12/13/89	01/02/90
3049	Barrier 047F Plug	12/14/89	

FIRE PROTECTION SYSTEM IMPAIRMENTS PREVIOUSLY  
NOT REPORTED CLOSED

<u>FPI #</u>	<u>FEATURE TYPE</u>	<u>CLOSED</u>	<u>FPL LETTER &amp; DATE</u>
2386	Door 63-2	12/13/89	L-89-154 04/21/89
2391	Door 74-1	12/12/89	L-89-154 04/21/89
2548	Penetration 014N-M017	12/07/89	L-89-285 08/07/89
2733	Door 19-1	12/07/89	L-89-333 09/14/89
2779	Barrier 055N	12/08/89	L-89-364 10/13/89
2872	Door 98-1	12/07/89	L-89-375 10/30/89
2876	Door 101-1	12/08/89	L-89-375 10/30/89
2916	Door 70-2	12/13/89	L-89-404 11/16/89
2970	Barrier 106-F	12/11/89	L-89-459 12/19/89