



FirstEnergy Nuclear Operating Company

Perry Nuclear Power Plant
P.O. Box 97
10 Center Road
Perry, Ohio 44081

David B. Hamilton
Vice President

440-280-5382

December 13, 2017
L-17-353

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

SUBJECT:
Perry Nuclear Power Plant
Docket No. 50-440, License No. NPF-58
No Active Safety Function Anchor Darling Double Disc Gate Valves

In Reference 1, the Nuclear Energy Institute (NEI) provided the Nuclear Regulatory Commission (NRC) a resolution plan for the U.S. Nuclear Industry to address the known Anchor Darling Double Disk Gate Valve (DDGV) issues. Reference 2 indicated each utility will provide a listing of their Anchor Darling DDGV population with active safety functions along with relevant valve information, including the results of susceptibility evaluations, repair status, and a repair schedule for each susceptible valve not yet repaired. Reference 2 also stated that utilities or sites without active safety function Anchor Darling DDGVs would also provide a response.

This letter serves to confirm that Perry Nuclear Power Plant does not use Anchor Darling DDGVs to support any active safety function.

There are no regulatory commitments contained in this submittal. If there are any questions or if additional information is required, please contact Mr. Thomas A. Lentz, Manager – Fleet Licensing, at 330-315-6810.

Respectfully,

A handwritten signature in black ink, appearing to read "D. Hamilton", is written over a horizontal line.

David B. Hamilton

Perry Nuclear Power Plant
L-17-353
Page 2

References:

1. Letter from Greg Krueger (NEI) to John Lubinski (NRC), Anchor Darling Double Disc Gate Valve Industry Resolution Plan Update (Project 689), dated August 4, 2017.
2. Letter from Joseph Pollock (NEI) to Brian Holian (NRC), NSIAC Concurrence on Anchor Darling Double Disc Gate Valve Industry Response Actions (Project 689), dated October 26, 2017.

cc: NRC Region III Administrator
NRC Resident Inspector
NRR Project Manager