

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9007060151 DOC. DATE: 90/07/03 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME: HARRIS, K.N. AUTHOR AFFILIATION: Florida Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Confirms util intentions not to operate beyond refueling outage that represents last outage re NRC Bulletin 89-001.

DISTRIBUTION CODE: IE31D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Bulletin Response 89-01 re Failure of Westinghouse Steam Gen. Mech. T

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1	PD2-2 PD	1
	EDISON, G	1		
INTERNAL:	AEOD/DOA	1	AEOD/DSP/TPAB	1
	NRR/DET/EMCB 9H	1	NRR/DET/EMEB9H3	1
	NRR/DOEA/OEAB11	1	NRR/DOEA/OGCB11	1
	NRR/DREP/PEPB9D	1	NRR/DST 8E2	1
	NRR/PMAS/ILRB12	1	REG FILE 02	1
	RES/DSIR/EIB	1	RGN2 FILE 01	1
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 18-0

AD-1
 sub



FPL

P.O. Box 14000, Juno Beach, FL 33408-0420

JUL 03 1990

L-90-240

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
NRC Bulletin 89-01
Westinghouse Steam Generator Tube Plugs

By letter dated May 23, 1990, you requested further clarification of item 2.b in Bulletin 89-01. This letter is to confirm our intentions not to operate beyond a refueling outage that represents the last outage before any plug exhausts its predicted lifetime. This statement applies only to those Westinghouse mechanical steam generator plugs fabricated from material heats specified in WCAP-12244 Rev. 3, November, 1989.

Should there be any questions, please contact us.

Very truly yours,

K. N. Harris
Vice President
Turkey Point Plant Nuclear

KNH/JEK/jk

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

07060151 900703
ADOCK 05000250
PDC

