

## ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9010120093      DOC. DATE: 90/09/28      NOTARIZED: NO      DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C      05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C      05000251

AUTH. NAME      AUTHOR AFFILIATION  
 HARRIS, K.N.      Florida Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                  Document Control Branch (Document Control Desk)

SUBJECT: Changes start dates of third inservice insp period to begin  
 when dual-unit outage commences.

DISTRIBUTION CODE: A047D      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

## NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 0	PD2-2 PD	1 1
	EDISON, G	2 2		
INTERNAL:	AEOD/DSP/TPAB	1 1	NRR/DET/ECMB 9H	1 1
	NRR/DET/EMEB 7E	1 1	NUDOCS-ABSTRACT	1 1
	OC/LEMB	1 0	OGC/HDS2	1 0
	<u>REG FILE</u> 01	1 1	RES/DSIR/EIB	1 1
EXTERNAL:	EG&G BROWN, B	1 1	EG&G RANSOME, C	1 1
	NRC PDR	1 1	NSIC	1 1

## NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM PI-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 16 ENCL 0

MAH  
 wh





SEP 28 1990

L-90-346  
10 CFR 50.55

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4  
Docket No. 50-250 and 50-251  
Change of Inservice Inspection Period

This letter is to notify the NRC that Florida Power & Light is changing the start dates of the third Inservice Inspection (ISI) period for Turkey Point Units 3 and 4.

Presently, the third ISI period is scheduled to begin in February 1991 for Unit 3, and in April 1991 for Unit 4. Turkey Point is scheduled to commence a dual unit outage in November 1990, primarily to implement the Emergency Power System upgrade. This outage will begin approximately 4 months prior to the third period start date for Unit 3 and 6 months prior to the third period start date for Unit 4. The ASME Boiler and Pressure Vessel Code, Section XI Section IWB-2412(a), establishes the dates of the ISI periods. Section IWB-2412(b) states that "the inspection period specified in (a) above may be decreased or extended by as much as 1 year to enable an inspection to coincide with a plant outage, within the limitations of IWA-2400(c)." IWA-2400(c) discusses changes to the ISI interval. As only the ISI periods and not the intervals are being changed, Turkey Point remains in compliance with the limitations of IWA-2400(c). Using the flexibility permitted by Section IWB-2412(b), FPL is decreasing the second inspection period by changing the start date for the third inspection period, to begin when the dual unit outage commences.

Should there be any questions, please contact us.

Very truly yours,

K. N. Harris  
Vice President  
Turkey Point Plant Nuclear

KNH/GS

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

9010120093 900928  
PDR ADOCK 05000250  
Q PDC

A047  
1/0

201.8 1.10.00