

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9011300041 DOC. DATE: 90/11/21 NOTARIZED: NO DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME AUTHOR AFFILIATION  
 BOHLKE, W.H. Florida Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-31 & DPR-41, changing  
 TS 3/4.5.1 re accumulator vol operating band.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2 + 11  
 TITLE: OR Submittal: General Distribution

### NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME	LTTR	ENCL		
	PD2-2 LA	1	1		
	EDISON, G	2	2		
INTERNAL:	NRR/DET/ECMB 9H	1	1	NRR/DET/ESGB	1 1
	NRR/DOEA/OTSB11	1	1	NRR/DST 8E2	1 1
	NRR/DST/SELB 8D	1	1	NRR/DST/SICB 7E	1 1
	NRR/DST/SRXB 8E	1	1	NUDOCS-ABSTRACT	1 1
	OC/LEMB	1	0	OGC/HDS2	1 0
	<u>REG FILE</u> <u>01</u>	1	1	RES/DSIR/EIB	1 1
EXTERNAL:	NRC PDR	1	1	NSIC	1 1

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16

AN 2  
 WIP





NOV 21 1990

L-90-335

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Proposed License Amendment  
Accumulators, Limiting Condition for Operation

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) requests that Appendix A of Facility Operating Licenses DPR-31 and DPR-41 be amended to modify the Turkey Point Units 3 and 4 Technical Specification 3/4.5.1, "Accumulators, Limiting Condition for Operation". The proposed amendment increases the indicated accumulator volume operating band from: 6545 gallons to 6665 gallons, to: 6520 gallons to 6820 gallons. This change provides additional margin in the allowable accumulator water volume.


FPL has determined that the proposed amendment does not involve a significant hazard pursuant to 10 CFR 50.92. The proposed revised technical specification change is shown in Attachment 1. A description of the amendment request and the supporting safety evaluation which forms the basis for a no significant hazards determination is provided in Attachment 2. Attachment 3 provides the no significant hazards determination in support of the proposed Technical Specification change.

In accordance with 10 CFR 50.91(b) (1), a copy of this Proposed License Amendment is being forwarded to the State Designee for the State of Florida.

The proposed amendment has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the FPL Company Nuclear Review Board.

Should there be any questions on this request, please contact us.

Very truly yours,

  
W. H. Bohlke  
Vice President  
Nuclear Engineering and Licensing

WHB/OIH/oih

Attachment

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant  
Mr. Jacob Daniel Nash, Florida Department of Health and  
Rehabilitative Services

9011300041 901121  
PDR ADQCK 05000250  
PDC

*Handwritten signature/initials*



STATE OF FLORIDA                   )  
COUNTY OF ST. LUCIE         ) ss.

W.H. Bohlke, being first duly sworn, deposes and says:

That he is Vice President - Nuclear Engineering and Licensing of Florida Power and Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.

W.H. Bohlke

Subscribed and sworn to before me this

21<sup>ST</sup> day of NOVEMBER, 1990.

Kaye Morton

NOTARY PUBLIC, in and for the County of St. Lucie,  
State of Florida.

Notary Public State of Florida  
My Commission exp. 11 - 12 - 91  
Bonded thru Troy Fain Ins., Inc.

My Commission expires \_\_\_\_\_

RECEIVED  
JAN 10 1964  
U.S. AIR FORCE  
HEADQUARTERS  
WASHINGTON, D.C.  
100-100000-100000