

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9012030042 DOC. DATE: 90/11/27 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME AUTHOR AFFILIATION
 PLUNKETT, T.F. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: NPDES noncompliance notification: on 900906, discovered that
 rainwater pumped from sump to Biscayne Bay.

DISTRIBUTION CODE: IE23D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: Environmental Event Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	3 3	PD2-2 PD	1 1
	EDISON, G	1 1		
INTERNAL:	AEOD/DSP/TPAB	1 1	AEOD/PTB	1 1
	NRR/DREP/PEPB9D	1 1	NRR/PMAS/ILRB12	1 1
	OGC/HDS2	1 1	REG FILE 01	1 1
	RGN2	1 1	RGN2/DRSS/EPRPB	1 1
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 15 ENCL 15

*Environ 1
 just*



FPL

P.O. Box 14000, Juno Beach, FL 33408-0420

NOV 27 1990

L-90-391

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Unit 3 & 4
Dockets No. 50-250 and 50-251
Environmental Protection Plan Report -
National Pollutant Discharge
Elimination System (NPDES) Reportable Event

In accordance with Section 3.2.1. of the Turkey Point Units 3 and 4 Environmental Protection Plan (Appendix B of Plant Licenses), attached is a copy of the Discharge Monitoring Report (DMR) required by the Turkey Point Plant NPDES Permit with respect to a reportable event (attachment 1). Additionally, a description of the event is enclosed (attachment 2).

Should you have any questions, please contact us.

Very truly yours,

T. F. Plunkett
Vice President
Turkey Point Nuclear

TFP/DPS/ds

enclosure

cc: Stewart D. Ebnetter, Regional Administrator, Region II,
USNRC,
Senior Resident Inspector, USNRC, Turkey Point Plant

9012030042 901127
PDR ADOCK 05000250
S PDC

1987 5 5 10:10

ATTACHMENT 2 TO LETTER L-90-391

The Turkey Point Fossil Power Plant is currently in the process of regrading the fuel oil storage tank area to direct rainwater runoff toward a sump with an emergency overflow to the cooling canal system. This project has been permitted by Dade County's Department of Environmental Resources Management (DERM) and is being constructed by a local contractor.

On September 6, 1990, the contractor was discovered pumping rainwater from the sump to the turning basin which is in Biscayne Bay. Plant personnel directed the contractor to cease pumping water immediately. After further investigation, FPL was informed that a six inch pump was used to pump the rainwater at a rate of approximately 1100 gallons per minute for 15 minutes. Thus a total of 16,500 gallons of rainwater was pumped to the turning basin. No sheen or any other adverse environmental impacts were observed.

The contractor has been advised that all dewatering activities require proper permitting and that discharges without proper permits to waters of the United States are not allowed at Turkey Point. The general specification for contractors and the FPL General Terms and Conditions, parts 13 and 16 require contractors to obtain their own permits and to abide by state and Federal requirements.

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location (if different)

NAME FL PWR & LT - TURKEY POINT
 ADDRESS ENVIRONMENTAL AFFAIRS DEPT.
PO BOX 14000
JUNO BEACH FL 33408
 FACILITY FL PWR & LT - TURKEY POINT
 LOCATION MIAMI T.R. FAIR FL 33101
 ATTN: W-SAMUEL TUCKER, ENVIRON. MGR

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

FL0001562

PERMIT NUMBER

001 1

DISCHARGE NUMBER

F - FINAL

CLOSED CYCLE COOLING CANAL SYS.

MONITORING PERIOD

FROM YEAR 90 MO 09 DAY 01 TO YEAR 90 MO 09 DAY 30
 (20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

MAJOR (SUBR WP)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	QUANTITY OR LOADING (54-61)			QUALITY OR CONCENTRATION (46-53)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (54-61)	MINIMUM (46-53)	AVERAGE (46-53)	MAXIMUM (54-61)	UNITS (54-61)			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE		*****			*****	*****	*****		*		
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	*****	50050.0 DAILY MX	MGD	*****	*****	*****	****		CONTINUOUS RECORDING	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

W. H. Brunetti
Executive Vice President

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

W. H. Brunetti

TELEPHONE

305 246-6172

DATE

90 10 01

AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NO DISCHARGE ALLOWED. IF DISCHARGE OCCURS, REPORT FLOW AND ATTACH LETTER OF EXPLANATION (INCLUDE LENGTH OF THE DISCHARGE AND REASON FOR THE DISCHARGE). IN LIEU OF CONTINUOUS RECORDING, HOURLY FLOW MEASUREMENTS MAY BE SUBMITTED FOR EACH DAY OF THE DISCHARGE.