

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9012260282 DOC. DATE: 90/12/18 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME AUTHORITY AFFILIATION
 PLUNKETT, T.F. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Special Rept: on 901109, 13, 27, 29 & 30, non-functional fire barrier penetration not returned to functional status within seven days. Caused by damaged door & damaged thermolag. Compensatory measures implemented.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-2 LA	1 1	PD2-2 PD	1 1
AULUCK, R	1 1		
INTERNAL: ACNW	2 2	AEOD/DOA	1 1
AEOD/DSP/TPAB	1 1	AEOD/ROAB/DSP	2 2
NRR/DET/ECMB 9H	1 1	NRR/DET/EMEB 7E	1 1
NRR/DLPQ/LHFB11	1 1	NRR/DLPQ/LPEB10	1 1
NRR/DOEA/OEAB	1 1	NRR/DREP/PRPB11	2 2
NRR/DST/SELB 8D	1 1	NRR/DST/SICB 7E	1 1
NRR/DST/SPLB8D1	1 1	NRR/DST/SRXB 8E	1 1
REG FILE 02	1 1	RES/DSIR/EIB	1 1
RGN2 FILE 01	1 1		
EXTERNAL: EG&G BRYCE, J.H	3 3	L ST LOBBY WARD	1 1
NRC PDR	1 1	NSIC MAYS, G	1 1
NSIC MURPHY, G.A	1 1	NUDOCS FULL TXT	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 31 ENCL 31

Handwritten signature/initials



FPL

P.O. Box 029100, Miami, FL, 33102-9100

DEC 18 1990

L-90-439

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket No. 50-250 and 50-251
Special Report - Breached Fire Barriers
and Other Fire Protection Systems Impairments

In accordance with Technical Specification 6.9.3.c, the attached Special Report is provided for your information.

Should there be any questions on this information please contact us.

Very truly yours,

T. F. Plunkett
Site Vice President
Turkey Point Nuclear

TFP/TB/cl

attachment

cc: Stewart D. Ebner, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

9012260282 901218
PDR ADOCK 05000250
S PDR

TE22
1/1

SPECIAL REPORT

FIRE PROTECTION SYSTEM IMPAIRMENTS REQUIRING NRC NOTIFICATION.

PURPOSE:

Technical Specification (TS) 3.14.5.b requires the submission of a report to the NRC if a non-functional fire barrier penetration is not returned to functional status within 7 days. TS 3.14 also states that certain other conditions require NRC notification. In accordance with the above requirements, this special report is being generated in order to notify the NRC.

EVENT:

Please refer to the attached list for Fire Protection Impairments (FPI) being reported.

CAUSE:

FPI 3634, damaged fire door and FPI 3632, damaged thermolag, were found on routine inspections. FPI's 3609, 3613, and 3629 were issued for the support of backfit construction work. The plant continues to implement the compensatory measures as applicable.

STATUS UPDATE:

Please refer to the attached list for Fire Protection Impairments that were previously reported and are now closed.

SPECIAL REPORT

FIRE PROTECTION SYSTEM IMPAIRMENTS OPENED SINCE LAST REPORT
WHICH HAVE BEEN OPEN FOR LONGER THAN TECH SPEC LIMITS.

<u>FPI #</u>	<u>FEATURE TYPE</u>	<u>OPENED</u>	<u>CLOSED</u>
3609	Barrier 025W	11/09/90	
3613	Detector Alarm PT 26	11/13/90	11/28/90
3629	Barrier 072S	11/27/90	
3632	Barrier Thermolag 3K1600	11/29/90	
3634	Door 58-2	11/30/90	

FIRE PROTECTION SYSTEM IMPAIRMENTS PREVIOUSLY
NOT REPORTED CLOSED.

<u>FPI #</u>	<u>FEATURE TYPE</u>	<u>CLOSED</u>	<u>FPL LETTER & DATE</u>
1526	Barrier 058F	11/09/90	L-88-203 05/06/88
3568	Barrier Thermolag	11/20/90	L-90-405 11/15/90
3591	Barrier Thermolag 3A1325	11/09/90	L-90-405 11/15/90
3597	Barrier 071N	11/12/90	L-90-405 11/15/90

