

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9110080419 DOC. DATE: 91/09/30 NOTARIZED: NO DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME PLUNKETT, T.F. AUTHOR AFFILIATION Florida Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC concerns noted in Insp Repts 50-250/91-35 & 50-251/91-35 on 910826-30. Corrective actions: environ documentation packages will be updated to reflect installed configuration of all known periodic update items by 911231.

DISTRIBUTION CODE: C001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: Licensing Submittal: Environmental Rept Amdt & Related Correspondence

### NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL	
	PD2-2 LA		3	3		PD2-2 PD		1	1	
	AULUCK, R		1	1						
INTERNAL:	NRR/DET/ESGB 8D		1	1		OC/LEMB		1	0	
	OGC/HDS3		1	0		REG FILE 0-1		1	1	
	RGN2 DRSS/RPB		1	1						
INTERNAL:	EG&G SIMPSON, F		2	2		NRC PDR		1	1	
	NSIC		1	1						

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 12

14





SEP 30 1991

L-91-246  
10 CFR 50.49

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Environmental Qualification Documentation

During inspection 91-35 held August 26 - 30 1991, the NRC noted that Florida Power and Light (FPL) Company needed to be more expeditious in the updating of Environmental Qualification (EQ) Documentation Packages. Florida Power and Light Company provides the following in response to this concern:

- (1) The EQ Documentation Packages will be updated to reflect the installed configuration of all known periodic update items by December 31, 1991.
- (2) All outstanding approved design changes which have been implemented and accepted by the plant prior to November 1, 1991, will have the EQ Documentation Packages updated to reflect the installed configuration by December 31, 1991.
- (3) Following completion of the Safety Related Drawing Update Program, EQ Documentation Packages will be revised to reflect the installed configuration within 60 days of plant acceptance of a completed modification. The Safety Related Drawing Update Program is presently scheduled for completion on March 31, 1992.
- (4) EQ list information is available in the Total Equipment Data Base, within 30 days of plant acceptance of the completed modification.
- (5) The EQ Documentation Packages will be revised by December 31, 1991, to include an explanation of the vendor model number change for Limitorque Motor Operated Valves MOV-3-1404 and MOV-4-1404, Steam Stop Valves to Auxiliary Feedwater Pumps.

Should there be any questions concerning this response, please contact us.

Very truly yours,

T. F. Plunkett  
Vice President  
Turkey Point Nuclear

TFP/RJT/rjt

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

9110080419 910930  
PDR ADOCK 05000250  
PDR

an FPL Group company

COOL  
1/0

1942

2



1942