

ATTACHMENT 3

PROPOSED TECHNICAL SPECIFICATION

Marked-up Technical Specification Page,

3/4 2-1

Table 4.3-1 (pages 3/4 3-8 and 3/4 3-11 (reference only))

3/4.2 POWER DISTRIBUTION LIMITS

3/4.2.1 AXIAL FLUX DIFFERENCE

LIMITING CONDITION FOR OPERATION

3.2.1 The indicated AXIAL FLUX DIFFERENCE (AFD) shall be maintained within a $\pm 5\%$ target band (flux difference units) about the target flux difference.

The indicated AFD may deviate outside the above required target band at greater than or equal to 50% but less than 90% of RATED THERMAL POWER provided the indicated AFD is within the Acceptable Operation Limits of Figure 3.2-1 and the cumulative penalty deviation time does not exceed 1 hour during the previous 24 hours.

The indicated AFD may deviate outside the above required target band at greater than 15% but less than 50% of RATED THERMAL POWER provided the cumulative penalty deviation time does not exceed 1 hour during the previous 24 hours.

APPLICABILITY: MODE 1, above 15% of RATED THERMAL POWER.*

#

↑
ADD

ACTION:

- a. With the indicated AFD outside of the above required target band and with THERMAL POWER greater than or equal to 90% of RATED THERMAL POWER, within 15 minutes either:
 1. Restore the indicated AFD to within the target band limits, or
 2. Reduce THERMAL POWER to less than 90% of RATED THERMAL POWER.
- b. With the indicated AFD outside of the above required target band for more than 1 hour of cumulative penalty deviation time during the previous 24 hours or outside the Acceptable Operation Limits of Figure 3.2-1 and with THERMAL POWER less than 90% but equal to or greater than 50% of RATED THERMAL POWER:
 1. Reduce THERMAL POWER to less than 50% of RATED THERMAL POWER within 30 minutes, and
 2. Reduce the Power Range Neutron Flux* ~~***~~ - High Trip Setpoints to less than or equal to 55% of RATED THERMAL POWER within the next 4 hours.
- c. With the indicated AFD outside of the above required target band for more than 1 hour of cumulative penalty deviation time during the previous 24 hours and with THERMAL POWER less than 50% but greater

DELETE

INSERT

(below 90% of RATED THERMAL POWER)

*See Special Test Exceptions Specification 3.10.2.

Surveillance testing of the Power Range Neutron Flux Channels may be performed pursuant to Specification 4.3.1.1 provided the indicated AFD is maintained within the Acceptable Operation Limits of Figure 3.2-1. A total of 16 hours operation may be accumulated with the AFD outside of the above required target band during testing without penalty deviation.

ADD

SECRET

SECRET
(below 40% of water)
SECRET

SECRET

TABLE 4.3-1

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>ANALOG CHANNEL OPERATIONAL TEST</u>	<u>TRIP ACTUATING DEVICE OPERATIONAL TEST</u>	<u>ACTUATION LOGIC TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
1. Manual Reactor Trip	N.A.	N.A.	N.A.	R(11)	N.A.	1, 2, 3*, 4*, 5*
2. Power Range, Neutron Flux						
a. High Setpoint	S	D(2, 4), M(3, 4), Q(4, 6), R(4)	M	N.A.	N.A.	1, 2
b. Low Setpoint	S	R(4)	M	N.A.	N.A.	1***, 2
3. Intermediate Range, Neutron Flux	S	R(4)	S/U(1), M	N.A.	N.A.	1***, 2
4. Source Range, Neutron Flux	S	R(4)	S/U(1), M(9)	N.A.	N.A.	2**, 3, 4, 5
5. Overtemperature ΔT	S	R	Q	N.A.	N.A.	1, 2
6. Overpower ΔT	S	R	Q	N.A.	N.A.	1, 2
7. Pressurizer Pressure--Low	S	R	M	N.A.	N.A.	1
8. Pressurizer Pressure--High	S	R	M	N.A.	N.A.	1, 2
9. Pressurizer Water Level--High	S	R	Q	N.A.	N.A.	1
10. Reactor Coolant Flow--Low	S	R	M	N.A.	N.A.	1
11. Steam Generator Water Level--Low-Low	S	R	M	N.A.	N.A.	1, 2

TABLE 4.3-1 (Continued)

TABLE NOTATIONS

*When the Reactor Trip System breakers are closed and the Control Rod Drive System is capable of rod withdrawal.

**Below P-6 (Intermediate Range Neutron Flux Interlock) Setpoint.

***Below P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.

- (1) If not performed in previous 7 days.
- (2) Comparison of calorimetric to excore power indication above 15% of RATED THERMAL POWER. Adjust excore channel gains consistent with calorimetric power if absolute difference is greater than 2%. The provisions of Specification 4.0.4 are not applicable to entry into MODE 2 or 1.
- (3) Single point comparison of incore to excore AXIAL FLUX DIFFERENCE above 15% of RATED THERMAL POWER. Recalibrate if the absolute difference is greater than or equal to 3%. The provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (4) Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (5) This table Notation number is not used.
- (6) Incore-Excore Calibration, above 75% of RATED THERMAL POWER (RTP). If the quarterly surveillance requirement coincides with sustained operation between 30% and 75% of RTP, calibration shall be performed at this lower power level. The provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (7) Each train shall be tested at least every 62 days on a STAGGERED TEST BASIS.
- (8) With power greater than or equal to the Interlock Setpoint the required ANALOG CHANNEL OPERATIONAL TEST shall consist of verifying that the interlock is in the required state by observing the permissive annunciator window.
- (9) Monthly surveillance in MODES 3*, 4*, and 5* shall also include verification that permissive P-6 and P-10 are in their required state for existing plant conditions by observation of the permissive annunciator window. Monthly surveillance shall include verification of the High Flux at Shutdown Alarm Setpoint of 1/2 decade above the existing count rate.
- (10) Setpoint verification is not applicable.
- (11) The TRIP ACTUATING DEVICE OPERATIONAL TEST shall include independent verification of the OPERABILITY of the undervoltage and shunt trip attachment of the Reactor Trip Breakers.