

## ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9111220177 DOC. DATE: ~~91/10/31~~ NOTARIZED: NO DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251  
 AUTH. NAME AUTHOR AFFILIATION  
 LEONARD, C.M. Florida Power & Light Co.  
 PLUNKETT, T.F. Florida Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Oct 1991 for Turkey Point, Units  
 3 & 4. W/911115 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9  
 TITLE: Monthly Operating Report (per Tech Specs)

## NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	3 3	PD2-2 PD	1 1
	AULUCK, R	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	NRR/DLPQ/LPEB10	1 1	NRR/DOEA/OEAB	1 1
	REG FILE <del>015</del>	1 1	RGN2	1 1
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

MR





NOV 15 1991

L-91-309  
10 CFR 50.36

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

RE: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of NUREG 0020, attached are the October, 1991, Operating Status and Summary of Operating Experience Reports for Turkey Point Units 3 and 4.

Very truly yours,

T. F. Plunkett  
Vice President  
Turkey Point Nuclear

TFP/DRP/CML

attachments

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

9111220177 911031  
PDR ADOCK 05000250  
R PDR

220017

an FPL Group company

*Handwritten note:* 24 1/1



AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250

UNIT Turkey Point #3

DATE November 12, 1991

COMPLETED BY C. M. Leonard

TELEPHONE (305) 246-7103

MONTH October, 1991

AVERAGE DAILY POWER LEVEL

(MWe-Net)

10/01/91	21
10/02/91	68
10/03/91	81
10/04/91	53
10/05/91	293
10/06/91	300
10/07/91	301
10/08/91	277
10/09/91	267
10/10/91	254
10/11/91	246
10/12/91	257
10/13/91	401
10/14/91	544
10/15/91	669
10/16/91	673
10/17/91	675
10/18/91	664
10/19/91	679
10/20/91	678
10/21/91	672
10/22/91	672
10/23/91	676
10/24/91	675
10/25/91	678
10/26/91	677
10/27/91	678
10/28/91	678
10/29/91	677
10/30/91	679
10/31/91	685



# UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250

UNIT NAME Turkey Point #3

DATE November 12, 1991

COMPLETED BY C. M. Leonard

REPORT MONTH October 1991

TELEPHONE (305) 246-7103

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
22	901212	S	16.6	H	1	N/A	EE	Engine	Unit 3 was shutdown for scheduled Upgrades Outage.
01	911002	S	10.3	B	5	N/A	HA	Turbine	Unit 3 taken off line (but remained critical) for scheduled turbine test.
02	911003	F	26.3	A	2	250-91-008-00	HA	Turbine	Manual Reactor and Turbine trip due to mechanical failure of piping nipple in turbine control oil system.

1

F Forced  
S Scheduled

2

Reason  
A - Equipment Failure (Explain)  
B - Maintenance or Test  
C - Refueling  
D - Regulatory Restriction  
E - Operator Training & License Examination  
F - Administrative  
G - Operational Error (Explain)  
H - Other (Explain)

3

Method  
1 - Manual  
2 - Manual Scram  
3 - Automatic Scram  
4 - Continued  
5 - Load Reduction  
9 - Other (Explain)

4

Exhibit G-Instructions  
for Preparation of Data  
Entry Scheets Licensee  
Event Report (LER) File  
(NUREG-0161)

5

Exhibit 1 - Same Source





SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-250

UNIT Turkey Point #3

DATE November 12, 1991

COMPLETED BY C. M. Leonard

TELEPHONE (305) 246-7103

REPORT MONTH October, 1991

Unit 3 was shutdown on December 12, 1990 for a scheduled Upgrades Outage. This outage was completed and Unit 3 was placed on line on October 1, 1991. The unit was taken off line for turbine testing on October 2, 1991, and placed back on line on October 2, 1991. On October 3, 1991, a manual reactor and turbine trip was initiated due to a mechanical failure of a piping nipple in the control oil system. The unit was placed back on line October 4, 1991. Between October 4 through October 14, Unit 3 was maintained at various power levels due to instrumentation and mechanical problems.



# OPERATING DATA REPORT

DOCKET NO 50 - 250  
 DATE 11/13/91  
 COMPLETED BY C. M. LEONARD  
 TELEPHONE 305/246/7103

## OPERATING STATUS

1. UNIT NAME: TURKEY POINT UNIT 3
2. REPORTING PERIOD: OCTOBER 1991
3. LICENSED THERMAL POWER (MWT): 2200
4. NAMEPLATE RATING (GROSS MWE): 760
5. DESIGN ELECTRICAL RATING (NET MWE): 693
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 699
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 666
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: \_\_\_\_\_
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE) \_\_\_\_\_
10. REASONS FOR RESTRICTIONS, IF ANY: \_\_\_\_\_

	MONTHLY	-YTD-	CUMULATIVE
11. HOURS IN REPORT PERIOD:	745	7296	156969.6
12. NUMBER OF HOURS REACTOR WAS CRITICAL	727.2	788.1	99978.3
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	844.4
14. HOURS GENERATOR ON-LINE	691.8	691.8	98546.5
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	121.8
16. GROSS THERMAL ENERGY GENERATED (MWH)	1215537	1215537	204250340
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	379665	379665	65440541
18. NET ELECTRICAL ENERGY GENERATED (MWH)	356960	339482	61856331
19. UNIT SERVICE FACTOR	92.9	9.5	62.8
20. UNIT AVAILABILITY FACTOR	92.9	9.5	62.9
21. CAPACITY FACTOR (USING MDC NET)	71.9	7.0	60.3
22. CAPACITY FACTOR (USING DER NET)	69.1	6.7	56.9
23. UNIT FORCED OUTAGE RATE	3.7	3.7	12.4
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS :			

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: \_\_\_\_\_

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251

UNIT Turkey Point #4

DATE November 12, 1991

COMPLETED BY C. M. Leonard

TELEPHONE (305) 246-7103

MONTH October, 1991

AVERAGE DAILY POWER LEVEL

(MWe-Net)

10/01/91	0
10/02/91	0
10/03/91	0
10/04/91	0
10/05/91	0
10/06/91	0
10/07/91	0
10/08/91	0
10/09/91	0
10/10/91	0
10/11/91	0
10/12/91	0
10/13/91	0
10/14/91	0
10/15/91	0
10/16/91	0
10/17/91	0
10/18/91	0
10/19/91	0
10/20/91	0
10/21/91	0
10/22/91	0
10/23/91	0
10/24/91	0
10/25/91	0
10/26/91	0
10/27/91	0
10/28/91	0
10/29/91	64
10/30/91	222
10/31/91	237

# UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251  
 UNIT NAME Turkey Point #4  
 DATE November 12, 1991  
 COMPLETED BY C. M. Leonard  
 TELEPHONE (305) 246-7103

REPORT MONTH October 1991

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
10	901124	S	677.6	C/H	1	N/A	RC/EB	FuelXX Engine	Unit 4 shutdown for a scheduled Upgrades and Refueling Outage.
1	911029	S	4.7	B	5	N/A	HA	Turbine	Unit 4 taken off line (but remained critical) for scheduled turbine test.

- |                                     |  |   |  |                                     |
|-------------------------------------|--|---|--|-------------------------------------|
| <b>1</b><br>F Forced<br>S Scheduled | <b>2</b><br>Reason<br>A - Equipment Failure (Explain)<br>B - Maintenance or Test<br>C - Refueling<br>D - Regulatory Restriction<br>E - Operator Training & License Examination<br>F - Administrative<br>G - Operational Error (Explain)<br>H - Other (Explain) | <b>3</b><br>Method<br>1 - Manual<br>2 - Manual Scram<br>3 - Automatic Scram<br>4 - Continued<br>5 - Load Reduction<br>9 - Other (Explain) | <b>4</b><br>Exhibit G- Instructions<br>for Preparation of Data<br>Entry Sheets Licensee<br>Event Report (LER) File<br>(NUREG-0161) | <b>5</b><br>Exhibit 1 - Same Source |
|-------------------------------------|--|---|--|-------------------------------------|



SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-251

UNIT Turkey Point #4

DATE November 12, 1991

COMPLETED BY C. M. Leonard

TELEPHONE (305) 246-7103

REPORT MONTH October, 1991

Unit 4 was shutdown for a scheduled Upgrades and Refueling Outage on November 24, 1990. This outage was completed and Unit 4 was placed on line on October 29, 1991. Unit 4 was taken off line on October 29, 1991, for turbine testing. Unit 4 was placed back on line on October 29, 1991.





# OPERATING DATA REPORT

DOCKET NO 50 - 251  
 DATE 11/13/91  
 COMPLETED BY C. M. LEONARD  
 TELEPHONE 305/246/7103

## OPERATING STATUS

1. UNIT NAME: TURKEY POINT UNIT 4
2. REPORTING PERIOD: OCTOBER 1991
3. LICENSED THERMAL POWER (MWT): 2200
4. NAMEPLATE RATING (GROSS MWE): 760
5. DESIGN ELECTRICAL RATING (NET MWE): 693
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 699
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 666
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: \_\_\_\_\_
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE) \_\_\_\_\_
10. REASONS FOR RESTRICTIONS, IF ANY: \_\_\_\_\_

## MONTHLY -YTD- CUMULATIVE

11. HOURS IN REPORT PERIOD:	745	7296	150701.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	144.6	144.6	94528.2
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	166.6
14. HOURS GENERATOR ON-LINE	62.7	62.7	90935.6
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	32.1
16. GROSS THERMAL ENERGY GENERATED (MWH)	55521	55521	191279865
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	14355	14355	61008186
18. NET ELECTRICAL ENERGY GENERATED (MWH)	6695	-3216	57667944
19. UNIT SERVICE FACTOR	8.4	0.9	60.3
20. UNIT AVAILABILITY FACTOR	8.4	0.9	60.4
21. CAPACITY FACTOR (USING MDC NET)	1.3	0.0	58.5
22. CAPACITY FACTOR (USING DER NET)	1.3	0.0	55.2
23. UNIT FORCED OUTAGE RATE	0.0	0.0	11.9
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS :			

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: \_\_\_\_\_