

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9201310191 DOC. DATE: 92/01/27 NOTARIZED: YES DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME AUTHOR AFFILIATION  
 BOHLKE, W.H. Florida Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Responds to Generic Ltr 91-11, "Resolution of Generic Issues  
 48, 'LCOs for Class 1E Vital Buses' & 49, 'Interlocks & LCOs  
 for Class 1E Tie Breakers.'"

DISTRIBUTION CODE: A027D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2  
 TITLE: Generic Ltr 91-11 - Resolutions of Generic Issues 48 & 49

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 1	PD2-2 PD	1 1
	AULUCK, R	2 2		
INTERNAL:	NRR CHOPRA, O	1 1	NRR HOFFMAN, S	1 1
	NRR/DET/ECMB 7D	1 1	NRR/DET/ESGB	1 1
	NRR/DOEA/OTSB11	1 1	NRR/DST 8E2	1 1
	NRR/DST/SELB 7E	1 1	NRR/DST/SICB8H7	1 1
	NRR/DST/SRXB 8E	1 1	NUDOCS-ABSTRACT	1 1
	OC/LFMB	1 0	OGC/HDS3	1 0
	REG-FILE 01	1 1	RES/DSIR/EIB	1 1
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 18

*MA 8/17*





**FPL**

P.O. Box 14000, Juno Beach, FL 33408-0420

L-91-267

JAN 27 1992

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Resolution of Generic Issues 48, "LCOs for  
Class 1E Vital Buses," and 49, "Interlocks  
and LCOs for Class 1E Tie Breakers" -  
Generic Letter 91-11

On August 29, 1991, the NRC issued Generic Letter (GL) 91-11, "Resolution of Generic Issues 48, "LCOs for Class 1E Vital Buses," and 49, "Interlocks and LCOs for Class 1E Tie Breakers." The GL requests each licensee to ensure that the plant procedures fulfill the following:

1. Limit the time that a plant is in possible violation of the single-failure criterion with regard to the Class 1E vital instrument buses and tie breakers,
2. Require surveillances of the components in Item(1), and
3. Ensure that, except for the times covered in Item(1), the plant is operating in an electrical configuration consistent with the regulations and its design bases.

GL 91-11 states that the current Westinghouse Standard Technical Specifications include the requirements contained in this generic letter. The Turkey Point Units 3 and 4 Technical Specifications for the Electrical Power Systems were recently revised to incorporate the Emergency Power System (EPS) upgrade (Amendment Nos. 138 and 133 issued December 28, 1990). This revision followed guidance contained within the current Westinghouse standard technical specifications. Florida Power and Light has reviewed the Turkey Point Units 3 and 4 Technical Specifications and determined that the requirements found within GL 91-11 are currently incorporated in the Turkey Point Technical Specifications and that procedures are in place to ensure the Technical Specification surveillances are met.

Should there be any questions please contact us.

Very truly yours,

W. H. Bohlke  
Vice President  
Nuclear Engineering and Licensing

WHB/OIH

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

9201310191 920127  
PDR ADDCK 05000250  
PDR

310081  
an FPL Group company

ADCK 1/

OFF - STAL

STATE OF FLORIDA       )  
                                  ) ss.  
COUNTY OF PALM BEACH )

W. H. Bohlke being first duly sworn, deposes and says:

That he is Vice President, Nuclear Engineering and Licensing,  
of Florida Power and Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements  
made in this document are true and correct to the best of his  
knowledge, information and belief, and that he is authorized to  
execute the document on behalf of said Licensee.

  
\_\_\_\_\_  
W. H. Bohlke

Subscribed and sworn to before me this

27<sup>th</sup> day of January, 1992.

  
\_\_\_\_\_

NOTARY PUBLIC, in and for the County of  
Palm Beach, State of Florida

My Commission expires Notary Public, State of Florida  
My Comm. Exp. Feb. 18, 1995  
Bonded thru PICHARD Ins. Agency

NOTARY PUBLIC  
JAN 27 1992  
P. 10:00 AM

11-11-11

11-11-11

11-11-11

11-11-11