

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

53

ACCESSION NBR: 9211200163 DOC. DATE: 92/11/12 NOTARIZED: NO DOCKET #
ACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
AUTH. NAME AUTHOR AFFILIATION
PLUNKETT, T.F. Florida Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Forwards corrections to emergency response data sys for
Units 3 & 4.

DISTRIBUTION CODE: A026D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
TITLE: Emergency Response Data System (ERDS)

NOTES: NRR RAGHAVAN, L
NRR RAGHAVAN, L

05000250 S
05000251 /

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
JOLICOEUR, J 01	2 2	PD2-2 LA	1 1
AULUCK, R	1 1		
INTERNAL: AEOD	1 1	AEOD/DOA/IRB	1 1
NRR HICKMAN, J.	1 0	NRR/DREP/PEPB	1 1
OC/LFMB	1 0	RGN2 ERC	1 1
RGN2 FILE	1 1		
EXTERNAL: NRC PDR	1 1		
NOTES:	1 1		

MNB
3206

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 11





FPL

P.O. Box 029100, Miami, FL, 33102-9100

NOV 12 1992

L-92-308
10 CFR 50 Appendix E

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Emergency Response Data System

By letter L-92-182, dated July 31, 1992, Florida Power and Light Company (FPL) submitted the Plant Attribute and Data Point Libraries for the Turkey Point Units 3 and 4 Emergency Response Data System (ERDS). On October 7, 1992, the Factory Acceptance Test for ERDS was successfully completed. During the test five (5) errors in the Data Point Libraries were identified. These corrections are provided in the attachment and cross-referenced to the original transmittal.

Should there be any questions, please contact us.

Very truly yours,

T. F. Plunkett
Vice President
Turkey Point Nuclear

TFP/RJT/rt

Attachment

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

190009

9211200163 921112
PDR ADDCK 05000250
F PDR

an FPL Group company

AC24, /



L-92-308

ATTACHMENT 1

CORRECTIONS TO THE TURKEY POINT UNITS 3 AND 4 DATA POINT LIBRARY.

DOCUMENT AND PAGE	RECORD NUMBER	FIELD NAME	ORIGINAL TEXT	AS CHANGED TEXT
L-92-182 ATTACHMENT 2 PAGE 5 OF 16	55	POINT ID	CTMTAVTMP-3	CTMTHITMP-3
L-92-182 ATTACHMENT 2 PAGE 5 OF 16	55	HOW PROCESSED	AVERAGE	HIGHEST
L-92-182 ATTACHMENT 2 PAGE 16 OF 16	55	UNIQUE SYSTEM DESCRIPTION	the 6th word of the description "AVERAGE"	change 6th word of description to "HIGHEST"
L-92-182 ATTACHMENT 3 PAGE 4 OF 16	43	POINT ID	R14-4	R14-3
L-92-182 ATTACHMENT 2 PAGE 5 OF 16	46	POINT ID	R18-4	R18-3
L-92-182 ATTACHMENT 3 PAGE 5 OF 16	54	POINT ID	CTMTAVTMP-4	CTMTHITMP-4
L-92-182 ATTACHMENT 3 PAGE 5 OF 16	54	HOW PROCESSED	AVERAGE	HIGHEST
L-92-182 ATTACHMENT 3 PAGE 5 OF 16	56	POINT ID	RWST3AVLVL-4	RWST4AVLVL-4
L-92-182 ATTACHMENT 3 PAGE 5 OF 16	56	PLANT SPECIFIC POINT DESCRIPTION	RWST (UNIT 3) AVERAGE LEVEL	RWST (UNIT 4) AVERAGE LEVEL
L-92-182 ATTACHMENT 3 PAGE 15 OF 16	54	UNIQUE SYSTEM DESCRIPTION	the 6th word of the description "AVERAGE"	change 6th word of description to "HIGHEST"

