

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9401240319 DOC. DATE: 94/01/14 NOTARIZED: YES DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 PLUNKETT, T.F. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Forwards proposed revs to License Conditions 3.G & 3.F, in response to NRC telcon RAI re util 930817 application for amends to Licenses DPR-31 & DPR-41 to conform to std fire protection condition as stated in GL 86-10.

DISTRIBUTION CODE: A006D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: OR/Licensing Submittal: Fire Protection

NOTES:

| | RECIPIENT | | COPIES | | | RECIPIENT | | COPIES | | |
|-----------|--------------------|--|--------|------|--|-----------------|--|--------|------|--|
| | ID CODE/NAME | | LTR | ENCL | | ID CODE/NAME | | LTR | ENCL | |
| | PD2-2 LA | | 1 | 0 | | PD2-2 PD | | 1 | 1 | |
| | RAGHAVAN, L | | 2 | 2 | | | | | | |
| INTERNAL: | NRR/DSSA/SPLB | | 1 | 1 | | NUDOCS-ABSTRACT | | 1 | 1 | |
| | OC/LFDCB | | 1 | 0 | | OGC/HDS3 | | 1 | 0 | |
| | <u>REG FILE</u> 01 | | 1 | 1 | | | | | | |
| EXTERNAL: | NRC PDR | | 1 | 1 | | NSIC | | 1 | 1 | |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 11 ENCL 8

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



JAN 14 1994

L-94-003
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Request for Additional Information (RAI) -
Proposed License Amendments
Fire Protection Technical Specifications
(TAC No. M87314/M87315)

By letter L-93-192, dated August 17, 1993, Florida Power and Light Company (FPL) submitted a request to amend Turkey Point Units 3 and 4 Technical Specifications. This amendment request included a revision to License Conditions 3.G and 3.F of Facility Operating Licenses DPR-31 and DPR-41, respectively, to conform to the standard fire protection License Condition as stated in Generic Letter 86-10. In a conference call between the NRC and FPL, the staff requested a revision to FPL's proposed License Conditions. In response to this request the proposed revision is enclosed.

Should there be any questions, please contact us.

Very truly yours,

T. F. Plunkett
Vice President
Turkey Point Nuclear

Enclosure

TFP/RJT/rt

cc: S. D. Ebnetter, Regional Administrator, Region II, USNRC
T. P. Johnson, Sr. Resident Inspector, USNRC, Turkey Point
W. A. Passetti, Florida Department of Health and
Rehabilitative Services

190028

7401240319 740114
PDR ADDOCK 05000250
P PDR

an FPL Group company

A006
111

1945

1945

1945

1945

1945

STATE OF FLORIDA)
) ss.
COUNTY OF DADE)

T. F. Plunkett being first duly sworn, deposes and says:

That he is Vice President, Turkey Point Nuclear Plant, of Florida Power and Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.

T. F. Plunkett

T. F. Plunkett

Subscribed and sworn to before me this

14 day of JAN, 1994.


Cheryl A. Kelly

CHERYL A. KELLY

Name of Notary Public (Type or Print)

NOTARY PUBLIC, in and for the County of
Dade, State of Florida

My Commission expires
Commission No. _____



T. F. Plunkett is personally known to me.

ATTACHMENT

Florida Power and Light Company

Turkey Point Units 3 and 4

Revisions to License Conditions 3.G and 3.F of
DPR 50-250 and 50-251

LICENSE CONDITION 3.G OF DPR 50-250

G. Fire Protection

FPL shall implement and maintain in effect all provisions of the approved Fire Protection Program as described in the Updated Final Safety Analysis Report (UFSAR) for Turkey Point Units 3 and 4 and as approved in the Safety Evaluation Report (SER) dated March 21, 1979 and supplemented by NRC letters dated April 3, 1980, July 9, 1980, December 8, 1980, January 26, 1981, May 10, 1982, March 27, 1984, April 16, 1984 and August 12, 1987 subject to the following provision:

The licensee may make changes to the approved Fire Protection Program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

LICENSE CONDITION 3.F OF DPR 50-251

F. Fire Protection

FPL shall implement and maintain in effect all provisions of the approved Fire Protection Program as described in the Updated Final Safety Analysis Report (UFSAR) for Turkey Point Units 3 and 4 and as approved in the Safety Evaluation Report (SER) dated March 21, 1979 and supplemented by NRC letters dated April 3, 1980, July 9, 1980, December 8, 1980, January 26, 1981, May 10, 1982, March 27, 1984, April 16, 1984 and August 12, 1987 subject to the following provision:

The licensee may make changes to the approved Fire Protection Program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.