

PRIORITY 1
(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9408240340 DOC. DATE: 94/08/15 NOTARIZED: YES DOCKET #
FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light Co 05000250
AUTH. NAME AUTHOR AFFILIATION
PLUNKETT, T.F. Florida Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Confirms completion of all design-basis reviews, analysis, verifications, tests & insps performed to comply w/items a through h of GL 89-10, per GL 89-10 item m.

DISTRIBUTION CODE: A064D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
TITLE: Response to Generic Ltr 89-10, "Safety-Related MOV Testing & Surveillance"

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 PD	1 1	CROTEAU, R	1 1
INTERNAL:	AEOD/SPD/RAB	1 1	AEOD/SPD/RRAB	1 1
	NRR/DE/EMEB	1 1	NRR/DORS/OGCB	1 1
	NRR/PD111-3	1 1	NRR/PMAS/IRCB-E	1 1
	<u>REG FILE</u> 01	1 1	RES/DSIR	1 1
	RES/DSIR/EIB/B	1 1		
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 0

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T

MAF



FPL

AUG 15 1994

L-94-196
10 CFR 50.54(f)

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3
Docket No. 50-250
Safety-Related Motor-Operated Valve
Testing and Surveillance - Generic Letter 89-10

On June 28, 1989, the NRC issued Generic Letter (GL) 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillance," recommending that licensees establish a program to provide for the testing, inspection, and maintenance of safety-related motor-operated valves (MOV's). Florida Power and Light Company's (FPL) plans with respect to the recommendations and scheduler requirements of the generic letter are documented in FPL letters L-89-467, dated December 28, 1989, L-90-233, dated June 28, 1990, and L-94-59, dated April 1, 1994.

FPL developed a comprehensive program for Turkey Point Units 3 and 4, for testing, inspection, and maintenance of safety-related MOV's to provide the necessary assurance that safety-related MOV's will function when subjected to the design-basis conditions during normal operation and abnormal events within the design basis of the plant.

Item m. of GL 89-10 requires licensees to notify the NRC in writing within 30 days of the completion of the actions described in the first paragraph of item i. of the generic letter. Pursuant to GL 89-10, Item m., this letter confirms FPL's completion of all design-basis reviews, analyses, verifications, tests, and inspections performed to comply with items a. through h. of the generic letter, for Turkey Point Unit 3.

Should there be any questions, please contact us.

Very truly yours,

T. F. Plunkett
Vice President
Turkey Point Plant

TFP/OIH

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
T. P. Johnson, Senior Resident Inspector, USNRC, Turkey Point
Plant

9408240340 940815
PDR ADDCK 05000250
P PDR

A064
1/0

STATE OF FLORIDA)
) ss.
COUNTY OF DADE)

T. F. Plunkett being first duly sworn, deposes and says:

That he is Vice President, Turkey Point Plant, of Florida Power and Light Company, the Licensee herein;


That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.



T. F. Plunkett

Subscribed and sworn to before me this

15 day of August, 1994.



CHERYL A. KELLY
Name of Notary Public (Type or Print)

NOTARY PUBLIC, in and for the County of
Dade, State of Florida

My Commission expires _____
Commission No. _____



T. F. Plunkett is personally known to me.