

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9411010123 DOC. DATE: 94/10/24 NOTARIZED: NO DOCKET #
 FACIL: 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 PLUNKETT, T.F. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 EBNETER, S.D. Region 2 (Post 820201)

SUBJECT: Informs that there were no steam generator tubes plugged as result of insp of Turkey Point Unit 4 steam generators from 941014-1017.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 7
 TITLE: OR Submittal: General Distribution

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-2 LA	1 1	PD2-2 PD	1 1
CROTEAU, R	1 1		
INTERNAL: <u>FILE CENTER</u> 01	1 1	NRR/DE/EELB	1 1
NRR/DRCH/HICB	1 1	NRR/DRPW	1 1
NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
NUDOCS-ABSTRACT	1 1	OGC/HDS3	1 1
EXTERNAL: NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 12 0

MA4

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



OCT 24 1994

L-94-267
10 CFR 50.36

Stewart D. Ebnetter
Regional Administrator
U. S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Dear Mr. Ebnetter:

Re: Turkey Point Unit 4
Docket No. 50-251
Steam Generator Tube Plugging

The Turkey Point Unit 4 steam generators were inspected from October 14, 1994 through October 17, 1994. There were no steam generator tubes plugged as a result of this inspection. This letter meets the requirements of notification in accordance with Technical Specification 4.4.5.5.

Should there be any questions, please contact us.

Very truly yours,

T. F. Plunkett
Vice President
Turkey Point Plant

TEP/OIH

cc: USNRC, Document Control Desk, Washington, D.C.
T. P. Johnson, Senior Resident Inspector, USNRC, Turkey
Point Plant

010063

9411010123 941024
PDR ADCK 05000251
PDR

Handwritten: Aool
1/0

