

PRIORITY 1

ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9502220130 DOC. DATE: ~~95/01/31~~ NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 KNORR, J.E. Florida Power & Light Co.
 PLUNKETT, T.F. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Jan 1995 for Turkey Point Units
 1 & 2. W/950214 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 PD	1 1	CROTEAU, R	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER</u> 01	1 1
	NRR/DISP/PIPB	1 1	NRR/DOPS/OECB	1 1
	RGN2	1 1		
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

MR

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



FPL

FEB 14 1995

L-95-051
10 CFR 50.36


U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of NUREG-0020, attached are the January 1995 Operating Status and Summary of Operating Experience Reports for Turkey Point Units 3 and 4.

Very truly yours,


T. F. Blunkett
Vice President
Turkey Point Plant

JEK

Attachments

cc: S. D. Ebnetter, Regional Administrator, Region II, USNRC
T. P. Johnson, Senior Resident Inspector, USNRC, Turkey Point Plant

9502220130 950131
PDR ADDCK 05000250
R PDR

an FPL Group company

IE24
11

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	<u>50-250</u>
UNIT	<u>Turkey Point #3</u>
DATE	<u>February 13, 1995</u>
COMPLETED BY	<u>J. E. Knorr</u>
TELEPHONE	<u>305-246-6757</u>

MONTH January 1995

AVERAGE DAILY POWER LEVEL

(MWe-Net)

1/01/95	694
1/02/95	694
1/03/95	691
1/04/95	690
1/05/95	694
1/06/95	693
1/07/95	695
1/08/95	696
1/09/95	695
1/10/95	702
1/11/95	701
1/12/95	697
1/13/95	698
1/14/95	693
1/15/95	693
1/16/95	697
1/17/95	693
1/18/95	701
1/19/95	696
1/20/95	694
1/21/95	694
1/22/95	699
1/23/95	698
1/24/95	556
1/25/95	699
1/26/95	702
1/27/95	703
1/28/95	697
1/29/95	698
1/30/95	693
1/31/95	690

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250
 UNIT NAME: Turkey Point #3
 DATE: February 13, 1995
 COMPLETED BY: J. E. Knorr
 TELEPHONE: (305) 246-6757

REPORT MONTH JANUARY 1995

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report#	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
N/A									

1

F - Forced
S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error
 (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

4

Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets Licensee
 Event Report (LER) File
 (NUREG-0161)

5

Exhibit 1 - Same Source

OPERATING DATA REPORT

DOCKET NO 50 - 250
DATE 2/11/95
BY J. E. KNÖRR
TELEPHONE 305/246/6757

OPERATING STATUS

1. UNIT NAME: TURKEY POINT UNIT 3
2. REPORTING PERIOD: JANUARY 1995
3. LICENSED THERMAL POWER (MWT): 2200
4. NAMEPLATE RATING (GROSS MWE): 760
5. DESIGN ELECTRICAL RATING (NET MWE): 693
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 699
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 666
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: _____
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE) _____
10. REASONS FOR RESTRICTIONS, IF ANY: _____

MONTHLY -YTD- CUMULATIVE

11. HOURS IN REPORT PERIOD:	744	744	194241.6
12. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	744.0	129722.4
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	844.4
14. HOURS GENERATOR ON-LINE	744.0	744.0	127792.7
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	121.8
16. GROSS THERMAL ENERGY GENERATED (MWH)	1616350	1616350	265782284
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	538805	538805	85300269
18. NET ELECTRICAL ENERGY GENERATED (MWH)	514460	514460	80708887
19. UNIT SERVICE FACTOR	100.0	100.0	65.8
20. UNIT AVAILABILITY FACTOR	100.0	100.0	65.9
21. CAPACITY FACTOR (USING MDC NET)	103.8	103.8	63.4
22. CAPACITY FACTOR (USING DER NET)	99.8	99.8	60.0
23. UNIT FORCED OUTAGE RATE	0.0	0.0	11.2
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS :			
NONE			

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: February 13, 1995
COMPLETED BY: J. E. Knorr
TELEPHONE: (305) 246-6757

REPORT MONTH JANUARY 1995

Unit 3 operated at essentially 100% power for the month of January 1995.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	<u>50-251</u>
UNIT	<u>Turkey Point #4</u>
DATE	<u>February 13, 1995</u>
COMPLETED BY	<u>J. E. Knorr</u>
TELEPHONE	<u>305-246-6757</u>

MONTH JANUARY 1995

AVERAGE DAILY POWER LEVEL

(MWe-Net)

1/01/95	699
1/02/95	693
1/03/95	693
1/04/95	690
1/05/95	697
1/06/95	697
1/07/95	697
1/08/95	697
1/09/95	698
1/10/95	705
1/11/95	703
1/12/95	700
1/13/95	700
1/14/95	697
1/15/95	698
1/16/95	700
1/17/95	701
1/18/95	701
1/19/95	701
1/20/95	699
1/21/95	698
1/22/95	702
1/23/95	703
1/24/95	703
1/25/95	709
1/26/95	710
1/27/95	713
1/28/95	704
1/29/95	701
1/30/95	695
1/31/95	694

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251
 UNIT NAME: Turkey Point #4
 DATE: February 13, 1995
 COMPLETED BY: J. E. Knorr
 TELEPHONE: (305) 246-6757

REPORT MONTH JANUARY 1995

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report#	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
N/A									

1

F - Forced
S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error
 (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

4

Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets Licensee
 Event Report (LER) File
 (NUREG-0161)

5

Exhibit 1 - Same Source

OPERATING DATA REPORT

DOCKET NO 50 - 251
 DATE 2/14/95
 BY J. E. KNORR
 TELEPHONE 305/246/6757

OPERATING STATUS

1. UNIT NAME: TURKEY POINT UNIT 4
2. REPORTING PERIOD: JANUARY 1995
3. LICENSED THERMAL POWER (MWT): 2200
4. NAMEPLATE RATING (GROSS MWE): 760
5. DESIGN ELECTRICAL RATING (NET MWE): 693
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 699
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 666
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE)
10. REASONS FOR RESTRICTIONS, IF ANY:

	MONTHLY	-YTD-	CUMULATIVE
11. HOURS IN REPORT PERIOD:	744	744	187973.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	744.0	125591.7
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	166.6
14. HOURS GENERATOR ON-LINE	744.0	744.0	121507.6
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	577.2
16. GROSS THERMAL ENERGY GENERATED (MWH)	1635612	1635612	256560321
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	545088	545088	81993738
18. NET ELECTRICAL ENERGY GENERATED (MWH)	520700	520700	77600286
19. UNIT SERVICE FACTOR	100.0	100.0	64.6
20. UNIT AVAILABILITY FACTOR	100.0	100.0	64.9
21. CAPACITY FACTOR (USING MDC NET)	105.1	105.1	62.9
22. CAPACITY FACTOR (USING DER NET)	101.0	101.0	59.6
23. UNIT FORCED OUTAGE RATE	0.0	0.0	10.9
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS :			

NONE

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: February 13, 1995
COMPLETE BY: J. E. Knorr
TELEPHONE: (305) 246-6757

REPORT MONTH JANUARY 1995

Unit 4 operated at essentially 100% power through the month of January 1995.