



April 2, 1984
L-84-90

Office of Nuclear Reactor Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 & 4
Docket No. 50-250, 50-251
Proposed License Amendment
Inservice Inspection and Inservice Test Program

In accordance with 10 CFR 50.90, Florida Power & Light Company submits herewith three signed originals and forty copies of a request to amend Appendix A of Facility Operating Licenses DPR 31 and DPR 41.

This amendment is submitted as required by 10 CFR 50.55a(g)(5)(ii) when our revised Inservice Inspection (ISI) and Inservice Test (IST) programs conflict with the current technical specifications. To make the technical specifications current, we propose to adopt the wording of the Standard Technical Specifications for Westinghouse Pressurized Water Reactors (NUREG 0452, Revision 4). This change will keep the Technical Specifications up to date with the periodic changes in the ASME Boiler and Pressure Vessel Code without the need for future license amendments. This submittal is being made concurrently with the submittals of the ISI Second Ten-Year Summary and a revision to the Inservice Test Program for Pumps and Valves for Turkey Point Units 3 & 4.

The proposed amendment is described below and shown on the accompanying technical specification pages.

Page 3.3-1

Specification 3.3.3 is revised to delete specifics of isolation valve testing. Testing of these valves is included in the Inservice Test Program for Pumps and Valves which is addressed in proposed Specification 4.0.3.

8404050194-840402
PDR ADQCK 05000250
PDR

Ab47
11

Page 3.4-2

Specifications 3.4.1.b.2 and b.4 are revised to delete operable safety injection and residual heat removal pump testing prior to maintenance on inoperable pumps. Testing of these components is included in the Inservice Test Program for Pumps and Valves which is addressed in proposed Specification 4.0.3.

Page 3.4-2a

Specifications 3.4.1.b.5 and b.6 are revised to delete testing of duplicate function valves and to add a requirement to verify that the remaining residual heat removal heat exchanger and duplicate function valves meet the requirements of proposed Specification 4.0.3.

Page 3.4-4

Specifications 3.4.2.b.2 and b.3 are revised to delete operable containment spray pump and valve testing prior to maintenance on inoperable items. These pumps and valves are included in the Pump and Valve Test Program.

Specification 3.4.3.b.2 is revised to delete operable containment filter valve testing prior to maintenance on inoperable valves. These valves are included in the Pump and Valve Test Program.

Page 3.4-5

Specification 3.4.4.b.2, 3.4.5.b.1 and b.2 are revised to delete operable pump and heat exchanger testing prior to maintenance on inoperable components. These items are included in the ISI and IST Programs. Requirements are added to verify that component cooling water pumps and heat exchangers and intake cooling water headers and pumps that remain operable, when other components are inoperable, meet the requirements of proposed Specification 4.0.3.

Page 3.4-6

Specification 3.4.6.b.2 is revised to delete testing of operable duplicate function valves.

Page 3.8-1

Specification 3.8.1d and 3.8.4 are revised to specify testing in accordance with Specifications 4.0.3 and 4.10.

Page 4.0-1, -2, 4.1-1

Specification 4.0.3 is provided to add the inservice inspection and testing requirements of the ASME Code. Editorial changes are made to page 4.1-1 to facilitate this change.



Table 4.1-2 (Sheet 2 of 3)

This table is revised to require testing of pressurizer and main steam safety valves in accordance with Specification 4.0.3.

Page 4.2-1, -2, and Table 4.2-1

This specification is revised to remove requirements which are addressed by proposed Specification 4.0.3. Those items formerly in Table 4.2-1 which were not addressed in proposed specification 4.0.3 are placed in the specification as items 4.2.3 and 4.2.4.

Page 4.4-2

An editorial change is made to the specification referenced in the acceptance criteria.

Page 4.4-3

Specifications 4.4.3 and 4.4.4 are revised to reference Specification 4.0.3 for containment isolation valves and delete the specific requirements for inservice testing of portions of the residual heat removal system. These items are included in the Inservice Test Program for Pumps and Valves, which is addressed in proposed Specification 4.0.3.

Page 4.5-1

Specification 4.5 is revised by deleting the surveillance specification for safety injection pumps and valves and inserting a reference to the testing required by proposed Specification 4.0.3.

Page 4.6-2

Specification 4.6.2 is revised to delete the testing requirements for containment spray pumps and motor operated isolation valves. These items are included in the Inservice Test Program for Pumps and Valves which is addressed in proposed Specification 4.0.3.

Page 4.7-3

Revisions are made to post accident containment vent system valve testing to refer to Specification 4.0.3.

Page 4.9-1 -

Specification 4.9 is revised to adopt standard Technical specification wording for testing of the Main Steam Isolation Valves. These valves are included in the Inservice Test Program for Pumps and Valves, which is addressed in proposed Specification 4.03.



Office of Nuclear Reactor Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Page 4

Page 4.10-1

Specification 4.10 is revised to reference Specification 4.0.3 for testing of auxiliary feedwater pumps and valves.

Page B4.0-1, B4.2-1

The bases for Specification 4.0 and 4.2 are revised.

Pages i through vi, 3.4-3, 3.8-2, 4.2-2 through 4.2-6, 4.7-4 and B4.2-2 are provided with appropriate changes to Table of Contents or page numberings to be consistent with the above changes.


In accordance with 10 CFR 50.91(a)(1), it has been determined that the proposed amendment does not involve any significant hazards considerations pursuant to 10 CFR 50.92. The No Significant Hazards Considerations determination is attached.

In accordance with 10 CFR 50.91(b)(1) a copy of the proposed amendment is being forwarded to the State Designee for the State of Florida.

The proposed amendment has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the Florida Power & Light Company Nuclear Review Board.

The proposed amendment has been determined to be a Class I and II amendment, and in accordance with 10 CFR 170.22, a check for \$1,600.00 will follow by separate letter.

Very truly yours,


J. W. Williams, Jr.
Vice President
Nuclear Energy

JWW/PLP/js

Attachment

cc: J. P. O'Reilly
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, GA 30303

Lyle E. Jerrett, Administrator
Radiological Health Services
Dept. of Health & Rehabilitative Services
1323 Winewood Boulevard
Tallahassee, Florida 32301

Harold F. Reis, Esquire

PNS-LI-84-116

STATE OF FLORIDA }
COUNTY OF DADE } ss.

J. W. Williams, Jr., being first duly sworn, deposes and says:

That he is Vice President of Florida Power & Light Company, the licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.



J. W. Williams, Jr.

Subscribed and sworn to before me this
2nd day of April, 1984.



Sarah P. Brock

NOTARY PUBLIC, in and for the County of
Dade, State of Florida.

My commission expires:
NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXPIRES FEB 12 1987
BONDED THRU GENERAL INSURANCE UND