

DMR Copy of Record

Permit

Permit #:
Major:

LA0042731
Yes

Permittee:
Permittee Address:

Entergy Operations, Inc.- River Bend Station
5485 US Highway 61
St. Francisville, LA 70775

Facility:
Facility Location:

ENTERGY OPERATIONS, INC.- RIVER BEND STATION
5485 US HWY 61
ST. FRANCISVILLE, LA 70775

Permitted Feature:

101
Internal Outfall

Discharge:

101-A
Low level radioactive low volume ww

Report Dates & Status

Monitoring Period:

From 06/01/17 to 06/30/17

DMR Due Date:

07/15/17

Status:

NetDMR Validated

Considerations for Form Completion

*WHEN DISCHARGING

Principal Executive Officer

First Name:
Last Name:

Title:

Telephone:

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Typ
						Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample								=	0.1	=	0.3	19 - mg/L		01/30 - Monthly	GR - GRAB
					Permit Req.								<=	30 MO AVG	<=	100 DAILY MX	19 - mg/L			
					Value NODI															
03582	Oil and grease	1 - Effluent Gross	0	--	Sample								=	1.05	=	1.71	19 - mg/L		01/30 - Monthly	GR - GRAB
					Permit Req.								<=	15 MO AVG	<=	20 DAILY MX	19 - mg/L			
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.026	=	0.058	03 - MGD									01/30 - Monthly	ES - ESTIMA
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD										
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

One TSS hold time for a sample pulled on 6/12/17 exceeded the 7 day hold time. When analyzed on 6/20/17 the results were 0.0 mg/L. These results were aligned with other results from this outfall. The station is modifying the scheduling process to an automated schedule and tracking. Increased oversight has been initiated.

Attachments

No attachments.

Report Last Saved By

Entergy Operations, Inc.- River Bend Station

User:
Name:
E-Mail:

rhillia@entergy.com
Robert Hilliard
rhillia@entergy.com

Date/Time:

2017-07-13 14:13 (Time Zone: -05:00)