

DMR Copy of Record

Permit

Permit #:
Major:

LA0042731
Yes

Permittee:
Permittee Address:

Entergy Operations, Inc.- River Bend Station
5485 US Highway 61
St. Francisville, LA 70775

Facility:
Facility Location:

ENTERGY OPERATIONS, INC.- RIVER BEND STATION
5485 US HWY 61
ST. FRANCISVILLE, LA 70775

Permitted Feature:

201
Internal Outfall

Discharge:

201-Q
Internall intermittent discharge of treated sanitary ww

Report Dates & Status

Monitoring Period:

From 04/01/17 to 06/30/17

DMR Due Date:

07/15/17

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:
Last Name:

Title:

Telephone:

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
						Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample														01/90 - Quarterly	GR - GRA
					Permit Req.								<=	30 MO AVG	<=	45 DAILY MX	19 - mg/L			
					Value NODI									E - Analysis Not Conducted/No Sample		E - Analysis Not Conducted/No Sample				
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample														01/90 - Quarterly	GR - GRA
					Permit Req.								<=	30 MO AVG	<=	45 DAILY MX	19 - mg/L			
					Value NODI									8 - Other (See Comments)		8 - Other (See Comments)				
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample														01/90 - Quarterly	ES - ESTIMA
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD										
					Value NODI		E - Analysis Not Conducted/No Sample		E - Analysis Not Conducted/No Sample											
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample														01/90 - Quarterly	GR - GRA
					Permit Req.								<=	200 MOAV GEO	<=	400 DAILY MX	13 - #/100mL			
					Value NODI									E - Analysis Not Conducted/No Sample		E - Analysis Not Conducted/No Sample				

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

A BOD and Fecal Coliform sample was not taken before the end of the calendar quarter. This was due to scheduling conflicts. Increased supervisory oversight has been initiated and an improved scheduling process has been implemented. A sample was taken in July and will be reported in the July DMR. TSS samples were obtained and reported in 201A as allowed by the permit.

Attachments

No attachments.

Report Last Saved By

Entergy Operations, Inc.- River Bend Station

User:
Name:
E-Mail:

rhillia@entergy.com
Robert Hilliard
rhillia@entergy.com

Date/Time:

2017-07-13 14:13 (Time Zone: -05:00)