

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9510060358 DOC. DATE: 95/09/29 NOTARIZED: NO DOCKET #
FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light Co 05000250 P
AUTH. NAME AUTHOR AFFILIATION
PLUNKETT, T.F. Florida Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
EBNETER, S.D. Region 2 (Post 820201) R

SUBJECT: Forwards table provided identifying tubes plugged in SG B,
per TS 4.4.5.5.a. I

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2 O
TITLE: OR Submittal: General Distribution R

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	1 1	PD2-1 PD	1 1
	CROTEAU, R	1 1		
INTERNAL:	<u>FILE CENTER 01</u>	1 1	NRR/DE/EMCB	1 1
	NRR/DRCH/HICB	1 1	NRR/DSSA/SPLB	1 1
	NRR/DSSA/SRXB	1 1	NUDOCS-ABSTRACT	1 1
	OGC/HDS3	1 0		
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

1
D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 11

MAY

512



SEP 29 1995

L-95-267
10 CFR 50.36

Stewart D. Ebnetter
Regional Administrator
U. S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323


Dear Mr. Ebnetter:

Re: Turkey Point Unit 3
Docket No. 50-250
Steam Generator Tube Plugging

The Turkey Point Unit 3 steam generators were inspected from September 14, 1995 through September 19, 1995. There were two steam generator tubes plugged in steam generator 3B as a result of the inspection. No defective tubes were identified in steam generators 3A or 3C. In accordance with Technical Specification 4.4.5.5.a, the attached table is provided identifying the tubes which were plugged in steam generator B.

Should there be any questions, please contact us.

Very truly yours,


T. F. Plunkett
Vice President
Turkey Point Plant

OIH

cc: USNRC, Document Control Desk, Washington, D.C.
T. P. Johnson, Senior Resident Inspector, USNRC, Turkey
Point Plant

100108

9510060358 950929
PDR ADOCK 05000250
PDR

an FPL Group company

Handwritten: A001
1/1

Attachment to
L-95-267

Turkey Point Unit 3 Steam Generator Tube Plugging

<u>Steam Generator</u>	<u>Row</u>	<u>Column</u>	<u>Reason for Tube Plugging</u>
B	42	37	Technical Specification Acceptance Criteria
	34	38	Technical Specification Acceptance Criteria