

L-96-015  
Attachment 3

ATTACHMENT 3

PROPOSED LICENSE AMENDMENT FOR  
IMPLEMENTATION OF EMERGENCY CORE COOLING SYSTEM ACCUMULATOR  
TECHNICAL SPECIFICATION IMPROVEMENTS

PROPOSED TECHNICAL SPECIFICATIONS PAGES

3/4 5-1

3/4 5-2

9603250317 960320  
PDR ADOCK 05000250  
P PDR

### 3/4.5 EMERGENCY CORE COOLING SYSTEMS

#### 3/4.5.1 ACCUMULATORS

##### LIMITING CONDITION FOR OPERATION

SEE ATTACHED

3.5.1 Each Reactor Coolant System (RCS) accumulator shall be OPERABLE with:

- a. The isolation valve open and its circuit breaker open,
- b. An indicated borated water volume of between 6520 and 6820 gallons,
- c. A boron concentration of between 1950 and 2350 ppm,
- d. A nitrogen cover-pressure of between 600 and 675 psig, and
- e. A water level and pressure channel OPERABLE.

APPLICABILITY: MODES 1, 2, and 3\*.

##### ACTION:

- a. - With one accumulator inoperable, except as a result of a closed isolation valve, restore the inoperable accumulator to OPERABLE status within 4 hours or be in at least HOT STANDBY within the next 6 hours and reduce pressurizer pressure to less than 1000 psig within the following 6 hours.
- b. With one accumulator inoperable due to the isolation valve being closed, either immediately open the isolation valve or be in at least HOT STANDBY within 6 hours and reduce pressurizer pressure to less than 1000 psig within the following 6 hours.

##### SURVEILLANCE REQUIREMENTS

4.5.1.1 Each accumulator shall be demonstrated OPERABLE:

- a. At least once per 12 hours by:
  - 1) Verifying the indicated borated water volume and nitrogen cover-pressure in the tanks, and
  - 2) Verifying that each accumulator isolation valve is open by control room indication (power may be restored to the valve operator to perform this surveillance if redundant indicator is inoperable).

\*Pressurizer pressure above 1000 psig.



## EMERGENCY CORE COOLING SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

SEE ATTACHED

- b. At least once per 31 days and within 6 hours after each solution volume increase of greater than or equal to 1% of tank volume by verifying the boron concentration of the solution in the water-filled accumulator;
- c. At least once per 31 days:
  - 1) When the RCS pressure is above 1000 psig, by verifying that the power to the isolation valve operator is disconnected by a locked open breaker, and
  - 2) Each accumulator water level and pressure channel shall be demonstrated OPERABLE by the performance of an ANALOG CHANNEL OPERATIONAL TEST, and
- d. At least once per 18 months:
  - 1) Each accumulator water level and pressure channel shall be demonstrated OPERABLE by the performance of a CHANNEL CALIBRATION, and
  - 2) Each accumulator check valve shall be checked for operability.

3/4.5 EMERGENCY CORE COOLING SYSTEMS

3/4.5.1 ACCUMULATORS

LIMITING CONDITION FOR OPERATION

---

3.5.1 Each Reactor Coolant System (RCS) accumulator shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3\*.

ACTION:

- a. With one accumulator inoperable, except as a result of boron concentration not being within limits, restore the inoperable accumulator to OPERABLE status within 1 hour or be in at least HOT STANDBY within the next 6 hours and reduce pressurizer pressure to less than 1000 psig within the following 6 hours.
- b. With one accumulator inoperable due to the boron concentration not being within the limits, restore boron concentration back to the required limits within 72 hours, or be in at least HOT STANDBY within 6 hours and reduce pressurizer pressure to less than 1000 psig within the following 6 hours.

SURVEILLANCE REQUIREMENTS

---

4.5.1.1 Each accumulator shall be demonstrated OPERABLE:

- a. At least once per 12 hours by:
  - 1) Verifying the borated water volume in each accumulator is between 6520 and 6820 gallons, and
  - 2) Verifying that the nitrogen cover pressure in each accumulator is between 600 and 675 psig, and
  - 3) Verifying that each accumulator isolation valve is open by control room indication (power may be restored to the valve operator to perform this surveillance if redundant indicator is inoperable).

---

\*Pressurizer pressure above 1000 psig.

L-96-015  
Attachment 3

EMERGENCY CORE COOLING SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

---

- b. At least once per 31 days and within 6 hours after each solution volume increase of greater than or equal to 1% of tank volume by verifying the boron concentration of the solution in the water-filled accumulator is between 1950 and 2350 ppm;
- c. At least once per 31 days, when the RCS pressure is above 1000 psig, by verifying that the power to the isolation valve operator is disconnected by a locked open breaker.

