

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9604030077 DOC. DATE: 96/03/27 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light Co. 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light Co. 05000251
 AUTH. NAME AUTHOR AFFILIATION
 HOVEY, R.J. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards "Turkey Point Plant Units 3 & 4 Annual Radioactive Effluent Release Rept, Jan-Dec 1995." No liquid or gaseous effluent monitoring instrumentation inoperable for time greater than that allowed by TS 3.3.3.5 or 3.3.3.6.

DISTRIBUTION CODE: IE48D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2 + 24
 TITLE: 50.36a(a)(2) Semiannual Effluent Release Reports

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	PD2-1	LA	2	2		PD2-1	PD	1	1
		CROTEAU, R	1	1					
INTERNAL:	<u>FILE CENTER</u>	<u>01</u>	1	1		NRR/DRPM/PERB/B		1	1
	RGN2	DRSS/RPB	2	2		RGN2	FILE	1	1
EXTERNAL:	LITCO	AKERS, D	1	1		NRC	PDR	1	1

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 11 ENCL 11



MAR 27 1996

L-96-083
10 CFR 50.36a(a)(2)

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Annual Radioactive Effluent Release Report

Attached is the Radioactive Effluent Release Report for the period of January 1, 1995, through December 31, 1995, for Turkey Point Units 3 and 4, as required by Technical Specification 6.9.1.4 and 10 CFR 50.36a (a)(2).

No liquid or gaseous effluent monitoring instrumentation was inoperable for a time greater than that allowed by Technical Specification 3.3.3.5 or 3.3.3.6.

No gas storage tanks exceeded the limits allowed by Technical Specification 3.11.2.6 during the reporting period.

No changes were made to the Offsite Dose Calculation Manual during 1995.

There were no continuous liquid effluent releases above the lower limit of detection for either Turkey Point Unit 3 or 4 during this period.

In accordance with Technical Specification 6.9.1.4, the meteorological data is available on site and will be provided to the NRC upon request.

Should there be any questions or comments regarding this information, please contact us.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

JEK

Attachment

cc: S. D. Ebnetter, Regional Administrator, Region II, USNRC
T. P. Johnson, Sr. Resident Inspector, USNRC, Turkey Point Plant

020039

9604030077 960327
PDR ADDCK 05000250
R PDR

JEK 8/1

2007

2007

2007

TURKEY POINT PLANT
UNITS 3 AND 4

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

Executive Summary

Liquid effluent releases at Turkey Point did not exceed the concentrations specified in 10 CFR 20, Appendix B, Table II, Column 2. The limits for dissolved and entrained noble gases were not exceeded.

The dose or dose commitment limits per reactor to a member of the public from liquid effluents were not exceeded.

Dose rate limits due to radioactive materials in the gaseous effluents were not exceeded.

The dose limits per reactor to a member of the public due to I-131, I-133, tritium and particulates with half-lives greater than 8 days were not exceeded.

All liquid and airborne discharges to the environment were analyzed in accordance with the Technical Specifications and Regulatory Guide 1.21.

There were no unplanned liquid or gaseous releases for either Unit during this period.

Visitor dose limits were calculated and included in this report for both adult and children inhalation at the Red Barn and also children inhalation at the Satellite School.

