

# CATEGORY 1

## REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9604190040      DOC. DATE: 96/04/12      NOTARIZED: NO      DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C      05000250  
          50-251 Turkey Point Plant, Unit 4, Florida Power and Light C      05000251  
 AUTH. NAME      AUTHOR AFFILIATION  
 HOVEI, R.J.      Florida Power & Light Co.  
 RECIPIENT NAME      RECIPIENT AFFILIATION  
                          Document Control Branch (Document Control Desk)

SUBJECT: Responds to GL 96-01, "Testing of SR Logic Circuits,"  
 requesting licensees to perform detailed review of design  
 of logic circuits against TS required test procedures to  
 verify adequacy of test procedures.

DISTRIBUTION CODE: A067D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 2  
 TITLE: GL 96-01 Response-Testing of Safety-Related Logic

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PM/KELLY, G	1    1		
INTERNAL: <del>FILE CENTER 04</del>		1    1	NRR/DRCH/HICB	1    1
<del>NRR/DRPW/PD3-3</del>		1    1		
EXTERNAL: NOAC		1    1	NRC PDR	1    1

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM  
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR      6      ENCL      , 6





FPL

P.O. Box 029100, Miami, FL, 33102-9100

APR 12 1996

L-96-084

10 CFR \$50.54 (f)

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Response to Generic Letter 96-01  
Testing of Safety-Related Logic Circuits

On January 10, 1996, the NRC issued Generic Letter (GL) 96-01, "Testing of Safety-Related Logic Circuits," requesting licensees to perform a detailed review of the design of logic circuits against Technical Specification required test procedures to verify the adequacy of those test procedures. Each addressee was requested to respond within 60 days of the date the letter was issued indicating whether the addressee will take the requested actions or submit an alternative plan. An extension to respond to GL 96-01 until April 18, 1996, was granted in an NRC letter dated February 14, 1996.

Florida Power and Light Co. will compare electrical schematic drawings and logic drawings for the reactor protection system, diesel generator load shedding and sequencing, and actuation logic for the engineered safety features systems against plant surveillance test procedures to ensure that all portions of the logic circuitry, including parallel logic, interlocks, bypasses and inhibit circuits, are adequately covered in the surveillance procedures. This review will be completed and procedures modified, as necessary, prior to restart from the March 1997 outage for Unit 3 and the October 1997 outage for Unit 4.

Should there be any questions on this response, please contact us.

Very truly yours,

R. J. Hovey  
Vice President  
Turkey Point Plant

190015

OIH

cc: S. D. Ebnetter, Regional Administrator, Region II, USNRC  
T. P. Johnson, Senior Resident Inspector, USNRC, Turkey  
Point

9604190040 960412  
PDR ADDCK 05000250  
PDR

an FPL Group company

Adler

01-28-1-134

11A

STATE OF FLORIDA       )  
                                  ) ss.  
COUNTY OF DADE       )

R. J. Hovey being first duly sworn, deposes and says:

That he is Vice President, Turkey Point Plant,  
of Florida Power and Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements  
made in this document are true and correct to the best of his  
knowledge, information and belief, and that he is authorized to  
execute the document on behalf of said Licensee.

*RJH*  
R. J. Hovey

Subscribed and sworn to before me this

12<sup>th</sup> day of April, 1995.

*James E. Knorr*  
James E. Knorr

Name of Notary Public (Type or Print)  
NOTARY PUBLIC, in and for the County of  
Dade, State of Florida

My Commission expires 1-22-99  
Commission No. CC 434300



R. J. Hovey is personally known to me.

