

NRR-DMPSPEm Resource

From: Green, Kimberly
Sent: Tuesday, December 19, 2017 1:49 PM
To: Lashley, Phil H. (phlashley@firstenergycorp.com)
Subject: ACCEPTANCE FOR REVIEW OF APPLICATION CONCERNING REVISIONS TO THE TECHNICAL SPECIFICATIONS FOR REACTOR PRESSURE VESSEL WATER INVENTORY CONTROL (EPID L-2017-LLA-0405) (L-17-045)

Dear Mr. Lashley:

By letter dated December 6, 2017, First Energy Nuclear Operating Company submitted an amendment request for the Perry Nuclear Power Plant. The proposed amendment would adopt Technical Specification Task Force Traveler 542, "Reactor Pressure Vessel Water Inventory Control," and replace existing technical specifications (TS) requirements related to operations which have the potential for draining the reactor vessel with new requirements on reactor pressure vessel water inventory control to protect Safety Limit 2.1.1.3.

The purpose of this email is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of the proposed license amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations*, an amendment to the license (including the TSs) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed, you will be advised by separate correspondence.

Based on the information provided in your submittal, the NRC staff has estimated that this licensing request will take approximately 300 hours to complete. The NRC staff expects to complete this review by the requested date of December 19, 2018. If there are emergent complexities or challenges in our review that would cause changes to the initial forecasted completion date or significant changes in the forecasted hours, the reasons for the changes, along with the new estimates will be communicated, during the routine interactions.

These estimates are based on the staff's initial review of the application and they could change, due to several factors including requests for additional information, unanticipated addition of scope to the review, and review by NRC advisory committees or hearing-related activities.

If you have any questions, please contact me at (301) 415-1627.

Sincerely,
Kimberly J. Green, Senior Project Manager
Plant Licensing Branch III
Division of Operating Reactor Licensing

Hearing Identifier: NRR_DMPS
Email Number: 61

Mail Envelope Properties (Kimberly.Green@nrc.gov20171219134800)

Subject: ACCEPTANCE FOR REVIEW OF APPLICATION CONCERNING REVISIONS
TO THE TECHNICAL SPECIFICATIONS FOR REACTOR PRESSURE VESSEL WATER INVENTORY
CONTROL (EPID L-2017-LLA-0405) (L-17-045)

Sent Date: 12/19/2017 1:48:36 PM

Received Date: 12/19/2017 1:48:00 PM

From: Green, Kimberly

Created By: Kimberly.Green@nrc.gov

Recipients:

"Lashley, Phil H. (phlashley@firstenergycorp.com)" <phlashley@firstenergycorp.com>

Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	3251	12/19/2017 1:48:00 PM

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received: