

ATTACHMENT 3

PROPOSED TECHNICAL SPECIFICATIONS

Marked-up Technical Specifications Page

6-3

9606040148 960528
PDR ADOCK 05000250
P PDR

ADMINISTRATIVE CONTROLS

PLANT STAFF (Continued)

1. An individual should not be permitted to work more than 16 hours straight, excluding shift turnover time.
2. An individual should not be permitted to work more than 16 hours in any 24-hour period, nor more than 24 hours in any 48-hour period, nor more than 72 hours in any 7-day period, all excluding shift turnover time.
3. A break of at least 8 hours should be allowed between work periods, including shift turnover time.
4. Except during extended shutdown periods, the use of overtime should be considered on an individual basis and not for the entire staff on a shift.

Any deviation from the above guidelines shall be authorized by the applicable department manager or higher levels of management, in accordance with established procedures and with documentation of the basis for granting the deviation. Controls shall be included in the procedures such that individual overtime shall be reviewed monthly by the Plant General Manager or his designee to assure that excessive hours have not been assigned. Routine deviation from the above guidelines is not authorized.

h. The Operations Supervisor shall hold a Senior Reactor Operator License.

i. The Operations Manager shall either:

1. hold or have held a Senior Reactor Operator License on the Turkey Point Plant; or,
2. have held a Senior Reactor Operator License on a similar plant (i.e., another pressurized water reactor); or,
3. ~~have held a Senior Reactor Operator License on a boiling water reactor and~~ completed the Turkey Point Nuclear Plant Senior Management Operations Training Course. (i.e., certified at an appropriate simulator for equivalent senior operator knowledge level.)

Delete

add

