

L-96-210
Attachment 3
Page 1

ATTACHMENT 3

PROPOSED LICENSE AMENDMENT FOR
USE OF TEMPORARY FUEL OIL STORAGE SYSTEM FOR UNIT 3 DIESELS DURING THE
PERFORMANCE OF A 10 YEAR SURVEILLANCE
TECHNICAL SPECIFICATION

PROPOSED TECHNICAL SPECIFICATIONS

3.8.1.1 AC SOURCES

OPERATING

LIMITING CONDITION FOR OPERATION: 3.8.1.1

Page 3/4 8-1

REQUIRED SURVEILLANCE: 4.8.1.1.2i.1

Page 3/4 8-9

3.8.1.2 AC SOURCES

SHUTDOWN

LIMITING CONDITION FOR OPERATION: 3.8.1.2

Page 3/4 8-11

9612060022 961122
PDR ADOCK 05000250
P PDR

3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1 A.C. SOURCES

OPERATING

LIMITING CONDITION FOR OPERATION

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. Two startup transformers and their associated circuits, and
- b. Three separate and independent diesel generators* including,
 - 1) For Unit 3, two (3A and 3B); for Unit 4, one (3A or 3B) each with:
 - a) A separate skid-mounted fuel tank and a separate day fuel tank with an OPERABLE solenoid valve to permit gravity flow from the day tank to the skid mounted tank, and with the two tanks together containing a minimum of 2000 gallons of fuel oil.
 - b) A common Fuel Storage System containing a minimum volume of 38,000 gallons of fuel,██
 - c) A separate fuel transfer pump,██
 - d) Lubricating oil storage containing a minimum volume of 120 gallons of lubricating oil,
 - e) Capability to transfer lubricating oil from storage to the diesel generator unit, and
 - f) Energized MCC bus (MCC 3A vital section for EDG 3A, MCC 3K for EDG 3B).
 - 2) For Unit 3, one (4A or 4B); for Unit 4, two (4A and 4B) each with:
 - a) A separate day fuel tank containing a minimum volume of 230 gallons of fuel,
 - b) A separate Fuel Storage System containing a minimum volume of 34,700 gallons of fuel,
 - c) A separate fuel transfer pump, and
 - d) Energized MCC bus (MCC 4J for EDG 4A, MCC 4K for EDG 4B).

*Whenever one or more of the four EDG's is out-of-service, ensure compliance with the EDG requirements specified in Specifications 3.5.2 and 3.8.2.1.

**A temporary fuel storage system may be used for up to 10 days during the performance of Surveillance Requirement 4.8.1.1.2.1 for the Unit 3 storage tank.

3.8.1.1 AC SOURCES

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- h. At least once per 10 years or after any modifications which could affect diesel generator interdependence by starting all required diesel generators simultaneously and verifying that all required diesel generators provide 60 ± 1.2 Hz frequency and 4160 ± 420 volts in less than or equal to 15 seconds; and
- i. At least once per 10 years by:
 - 1) Draining each fuel oil storage tank, removing the accumulated sediment and cleaning the tank.*
 - 2) For Unit 4 only, performing a pressure test of those portions of the diesel fuel oil system designed to Section III, subsection ND of the ASME Code in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda.

4.8.1.1.3 Reports - (Not Used)

* A temporary fuel storage system may be used for up to 10 days during the performance of Surveillance Requirement 4.8.1.1.2j.1 for the Unit 3 storage tank.

ELECTRICAL POWER SYSTEMS

A.C. SOURCES

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One startup transformer and associated circuits, or an alternate circuit, between the offsite transmission network and the 4160 volt bus, A or B, and
- b. One diesel generator with:
 - 1) For Unit 3 (3A or 3B)
A skid-mounted fuel tank and a day fuel tank, with an OPERABLE solenoid valve to permit gravity flow from the day tank to the skid mounted tank, with the two tanks together containing a minimum of 2000 gallons of fuel oil
For Unit 4 (4A or 4B)
A day fuel tank containing a minimum volume of 230 gallons of fuel
 - 2) A fuel storage system containing a minimum volume of fuel of 38,000 gallons (Unit 3), 34,700 gallons (Unit 4)
 - 3) An associated fuel transfer pump
 - 4) For Unit 3 only, lubricating oil storage containing a minimum volume of 120 gallons of lubricating oil
 - 5) For Unit 3 only capability to transfer lubricating oil from storage to the diesel generator unit and
 - 6) Energized MCC bus (as identified by Specification 3.8.1.1.b.).

APPLICABILITY: MODES 5** and 6**.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS, positive reactivity changes, movement of irradiated fuel, or crane operation with loads over the fuel storage pool, and within 8 hours, depressurize and vent the Reactor Coolant System through a greater than or equal to 2.2 square inch vent. In addition, when in MODE 5 with the reactor coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible and increase RCS inventory as soon as possible.

*A temporary fuel storage system may be used for up to 10 days during the performance of Surveillance Requirement 4.8.1.1.2.1 for the Unit 3 storage tank.

**CAUTION - If the opposite unit is in MODES 1, 2, 3 or 4 see Specification 3.8.1.1

