

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9702280053 DOC. DATE: 97/02/21 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 HOVEY, R.J. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Annual Repts for 1996 tabulating occupational exposure data for Turkey Point Units 3 & 4 as required by TS 6.9.1.2.a.

DISTRIBUTION CODE: IE56D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+2
 TITLE: 20.407 Annual Personnel Monitoring Rpt/Annual Rad Exposure Rpt by Fun

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 0	CROTEAU, R	1 1
INTERNAL:	ACNW	1 1	<u>FILE CENTER</u>	1 1
	NMSS/SSSS T 8F5	1 1	NRR/DRPM/PERB/B	1 1
	RES/RPHEB	1 1	RGN2 01	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 11 ENCL 10

M. A. E.

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



FEB 21 1997

L-97-041

10 CFR 50.36

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Annual Reports for 1996

Attached is a tabulation of the 1996 occupational exposure data for Turkey Point Units 3 and 4 as required by Technical Specification 6.9.1.2.a. Deep dose equivalent exposure by Direct Reading Dosimeter (DRD), was approximately 205 person-rem. Deep dose equivalent exposure by Thermoluminescent Dosimeter (TLD) was approximately 187 person-rem. Deep dose equivalent exposure by TLD includes conservative application of dose due to lost or damaged dosimetry and neutron exposure.

In accordance with Technical Specification 6.9.1.2.b, the reactor coolant activity limits of 100/E-bar micro curies per gram of gross radioactivity and 1.0 microcurie per gram Dose Equivalent I-131 defined by Technical Specification 3.4.8 for Units 3 and 4, were not exceeded during 1996.

Should there be any questions regarding this information, please contact us.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

JEK

Attachment

cc: L. A. Reyes, Regional Administrator, Region II, USNRC
T. P. Johnson, Senior Resident Inspector, USNRC, Turkey Point
Plant

9702280053 970221
PDR ADOCK 05000250
R PDR

IE 56%

