

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9704280191 DOC. DATE: 97/04/18 NOTARIZED: YES DOCKET #
FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
AUTH. NAME: AUTH. AFFILIATION
HOVEY, R.J. Florida Power & Light Co.
RECIP. NAME: RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Confirms completion of GL 96-01, "Testing of Safety-Related Logic Circuits."

DISTRIBUTION CODE: A067D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
TITLE: GL 96-01 Response-Testing of Safety-Related Logic

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3/KELLY, G	1 1	CROTEAU, R	1 1
INTERNAL:	FILE CENTER 01	1 1	NRR/DRCH/HICB	1 1
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 6 ENCL 6



APR 18 1997

L-97-078
10 CFR §50.54(f)

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Re: Turkey Point Unit 3
Docket No. 50-250
Generic Letter 96-01
Testing of Safety-Related Logic Circuits

On January 10, 1996, the NRC issued Generic Letter (GL) 96-01, "Testing of Safety-Related Logic Circuits," requesting licensees to perform a detailed review of the design of logic circuits against Technical Specification required test procedures to verify the adequacy of those test procedures. By letter L-96-084, dated April 12, 1996, Florida Power and Light Co. informed the NRC that it would complete GL 96-01 Requested Actions for Unit 3 prior to restart from the March 1997 Unit 3 refueling outage.

GL 96-01 Requested Action (1) requested licensees to perform a comparison of electrical schematic drawings and logic drawings for the reactor protection system, diesel generator load shedding and sequencing, and actuation logic for the engineered safety features systems against plant surveillance test procedures to ensure that all portions of the logic circuitry, including the parallel logic, interlocks, bypasses and inhibit circuits, are adequately covered in the surveillance procedures to fulfill the Technical Specification requirements. GL 96-01 Requested Action (2) requested licensees to modify surveillance procedures, as necessary, for complete testing to comply with the Technical Specifications.

As requested by GL 96-01 Required Response item (2), this letter confirms completion of the GL 96-01 Requested Actions (1) and (2) for Unit 3.

Should there be any questions on this response, please contact us.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

OIH

cc: Luis A. Reyes, Regional Administrator, Region II, USNRC
T. P. Johnson, Senior Resident Inspector, USNRC, Turkey Point

7704280191 970418
PDR ADOCK 05000250
PDR

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

L-97-078
Turkey Point Unit 3
Docket No. 50-250
Generic Letter 96-01
Testing of Safety-Related Logic Circuits

STATE OF FLORIDA)
) ss.
COUNTY OF DADE)

R. J. Hovey being first duly sworn, deposes and says:

That he is Vice President, Turkey Point Plant,
of Florida Power and Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements
made in this document are true and correct to the best of his
knowledge, information and belief, and that he is authorized to
execute the document on behalf of said Licensee.

MM

R. J. Hovey


Subscribed and sworn to before me this

18 day of April, 1997.

James E. Knorr

James E. Knorr

Name of Notary Public (Type or Print)
NOTARY PUBLIC, in and for the County of
Dade, State of Florida



R. J. Hovey is personally known to me.

11 A 3

11 A 3