

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCT. ION NBR: 9712110051 DOC. DATE: 97/12/04 NOTARIZED: YES DOCKET #  
F. L: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251  
AUTH. NAME AUTHOR AFFILIATION  
HOVEY, R. J. Florida Power & Light Co.  
RECIP. NAME RECIPIENT AFFILIATION  
Document Control Branch (Document Control Desk)

SUBJECT: Forwards revised TS section 6.9.1.7, "COLR," clarifying references 4 & 6 by adding best estimate LOCA to COLR & documenting re-analysis performed as result of revs to large break LOCA methodology.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+1  
TITLE: OR Submittal: General Distribution

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	1 1	PD2-3 PD	1 1
	CROTEAU, R	1 1		
INTERNAL:	FILE CENTER 01	1 1	NRR/DE/ECGB/A	1 1
	NRR/DE/EMCB	1 1	NRR/DRCH/HICB	1 1
	NRR/DSSA/SCSB	1 0	NRR/DSSA/SPLB	1 1
	NRR/DSSA/SRXB	1 1	NUDOCS-ABSTRACT	1 1
	OGC/HDS3	1 0		
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 12

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T



DEC 04 1997

L-97-295  
10 CFR §50.36  
10 CFR §50.90



U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington D. C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Proposed License Amendments  
Large Break Loss of Coolant Accident Re-analysis

On February 24, 1997, Florida Power and Light Company (FPL) submitted L-97-037, "Large Break Loss of Coolant Accident Re-analysis." L-97-037 requested that Appendix A of Facility Operating Licenses DPR-31 and DPR-41 be amended to modify Turkey Point Units 3 and 4 Technical Specifications Section 6.9.1.7, Core Operating Limits Report (COLR). This requested change will add Best Estimate Large Break Loss of Coolant Accident Analysis (BELOCA) to the COLR. By letter L-97-108, FPL requested an additional reference be added to the Turkey Point Units 3 and 4 Technical Specifications Section 6.9.1.7, Core Operating Limits Report, in order to document the re-analyses performed as a result of revisions to the large break LOCA methodology.

As discussed with the NRC Staff on November 17, 1997, FPL requests the attached revisions to References 4 and 6 listed in page 6-22 of the Turkey Point Units 3 and 4 Technical Specifications Section 6.9.1.7, Core Operating Limits Report. The proposed changes provide clarification to the information previously submitted to the NRC by FPL letter L-97-037. No changes have been made to the analyses or references described in L-97-037. Therefore, the conclusion of the No Significant Hazards Evaluation remains valid.

Should there be any questions on this request, please contact us.

Very truly yours,

R. J. Hovey  
Vice President  
Turkey Point Plant

OIH

Attachment

cc: L. A. Reyes, Regional Administrator, Region II, USNRC  
T. P. Johnson, Senior Resident Inspector, USNRC, Turkey Point Plant  
W. A. Passetti, Florida Department of Health and Rehabilitative Services

A001/1

9712110051 971204  
PDR ADDCK 05000250  
P PDR





17

17-295

Turkey Point Units 3 and 4

Docket Nos. 50-250 and 50-251

Proposed License Amendments

Large Break Loss of Coolant Accident Re-analysis

STATE OF FLORIDA

)

)

ss.

COUNTY OF DADE

)

R. J. Hovey being first duly sworn, deposes and says:

That he is Vice President, Turkey Point Plant, for the Nuclear Division of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.



R. J. Hovey

STATE OF FLORIDA


*Miami-*

COUNTY OF Dade


Sworn to and subscribed before me

this 4<sup>th</sup> day of December, 1997

by R. J. Hovey, who is personally known to me.



Name of Notary Public - State of Florida



(Print, type or stamp Commissioned Name of Notary Public)

1

11

11