

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9801220010 DOC. DATE: 97/12/31 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 MOWREY, C.L. Florida Power & Light Co.
 HOVEY, R.J. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Dec 1997 for Turkey Point, Unit 3
& 4. W/980112 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 1	CROTEAU, R	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER</u> 01	1 1
	OC/DBA/PAD	1 1	RGN2	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9




JAN 12 1998
L-98-002
10 CFR §50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the December 1997 Operating Status and Summary of Operating Experience Reports for Turkey Point Units 3 and 4.

Very truly yours,



R. J. Hovey
Vice President
Turkey Point Plant

CLM

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

9801220010 971231
PDR ADDCK 05000250
R PDR

IE24/1

220006



AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50 - 250
UNIT Turkey Point #3
DATE Jan 05, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246 - 6204

MONTH December, 1997

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

12/01/97	721
12/02/97	727
12/03/97	727
12/04/97	725
12/05/97	729
12/06/97	735
12/07/97	738
12/08/97	737
12/09/97	732
12/10/97	720
12/11/97	716
12/12/97	716
12/13/97	717
12/14/97	722
12/15/97	732
12/16/97	735
12/17/97	738
12/18/97	737
12/19/97	737
12/20/97	734
12/21/97	729
12/22/97	721
12/23/97	720
12/24/97	717
12/25/97	717
12/26/97	714
12/27/97	715
12/28/97	727
12/29/97	732
12/30/97	735
12/31/97	736

DOCKET NO. 50-250
UNIT NAME TURKEY POINT UNIT 3
DATE January 5, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD December, 1997
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	7666.3	153117.8
4. Number of Hours Generator Was On Line_____	744.0	7571.8	150958.9
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	540845.0	5252350.0	96412556.0

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250
 UNIT NAME: Turkey Point #3
 DATE: January 5, 1998
 COMPLETED BY: C. L. Mowrey
 TELEPHONE: (305) 246-6204

REPORT MONTH December 1997

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A						

1

F - Forced
S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error
 (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: January 5, 1998
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH December 1997

Unit 3 operated at essentially 100% power for the entire month of December.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50 - 251
UNIT Turkey Point #4
DATE Jan 05, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246 - 6204

MONTH December, 1997

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

12/01/97	719
12/02/97	725
12/03/97	727
12/04/97	725
12/05/97	728
12/06/97	735
12/07/97	737
12/08/97	737
12/09/97	734
12/10/97	725
12/11/97	715
12/12/97	713
12/13/97	714
12/14/97	720
12/15/97	730
12/16/97	736
12/17/97	735
12/18/97	735
12/19/97	735
12/20/97	731
12/21/97	727
12/22/97	724
12/23/97	718
12/24/97	716
12/25/97	715
12/26/97	712
12/27/97	713
12/28/97	725
12/29/97	730
12/30/97	730
12/31/97	733

OPERATING DATA REPORT

DOCKET NO. 50-251
UNIT NAME TURKEY POINT UNIT 4
DATE January 5, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD December, 1997
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	7854.5	149307.5
4. Number of Hours Generator Was On Line_____	744.0	7810.5	144976.5
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	539998.0	5442559.0	93491637.0

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251
 UNIT NAME: Turkey Point #4
 DATE: January 5, 1998
 COMPLETED BY: C. L. Mowrey
 TELEPHONE: (305) 246-6204

REPORT MONTH December 1997

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action to Prevent Recurrence
N/A						

1

F - Forced
S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error
 (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>January 5, 1998</u>
COMPLETE BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305)246-6204</u>

REPORT MONTH December 1997

Unit 4 operated at approximately 100% power for the entire month of December.