

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9803040158 DOC. DATE: 98/02/24 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 HOVEY, R. J. Florida Power & Light Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards "Statistical Whole Body Exposure Rpt for 1997" &
 "1997 Man-Rem Rpt." Both repts submitted per TS 6.9.1.2.a.

DISTRIBUTION CODE: IE56D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1 + 2
 TITLE: Annual Personnel Monitoring Rpt/Annual Rad Exposure Rpt by Functions

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 0	CROTEAU, R	1 1
INTERNAL:	ACNW	1 1	<u>FILE CENTER</u>	1 1
	NMSS/SSSS T 8F5	1 1	NRK/DRPM/PERB/B	2 2
	RES/DRA/RPHEB	1 1	RGN2 01	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 11



FEB 24 1998

L-98-054

10 CFR 50.36

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Annual Reports for 1997

Attached is a tabulation of the 1997 occupational exposure data for Turkey Point Units 3 and 4 as required by Technical Specification 6.9.1.2.a. Deep dose equivalent exposure by Direct Reading Dosimeter (DRD), was 452.589 person-rem. Deep dose equivalent exposure by Thermoluminescent Dosimeter (TLD) was 413.636 person-rem. Deep dose equivalent exposure by TLD includes conservative application of dose due to lost or damaged dosimetry and neutron exposure. Note that the statistical summary report formerly required by 10 CFR 20.407 is also attached. As allowed by the Statements of Consideration published in the Federal Register (56FR23386), and questions 61 and 79 of NUREG/CR-6204, Turkey Point will not hereafter submit this statistical summary report.

In accordance with Technical Specification 6.9.1.2.b, the reactor coolant activity limits of 100/E-bar micro curies per gram of gross radioactivity and 1.0 microcurie per gram Dose Equivalent I-131 defined by Technical Specification 3.4.8 for Units 3 and 4, were not exceeded during 1997.

Should there be any questions regarding this information, please contact us.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

CLM

Attachment

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

9803040158 980224
PDR ADOCK 05000250
R PDR

