

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9804150174 DOC. DATE: 98/03/31 NOTARIZED: NO DOCKET #
FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
AUTH. NAME AUTHOR AFFILIATION
MOWREY, C.L. Florida Power & Light Co.
HOVEY, R.J. Florida Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Mar 1998 for Turkey Point, Units
3 & 4. W/980409 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 1	JABBOUR, K	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	OC/DBA/PAD	1 1	RGN2	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9

C
A
T
E
G
O
R
Y
1

D
O
C
U
M
E
N
T



APR 09 1998

L-98-095
10 CFR §50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the March 1998 Operating Status and Summary of Operating Experience Reports for Turkey Point Units 3 and 4.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

CLM

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

IE241/

9804150174 980331
PDR ADDCK 05000250
R PDR

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: April 1, 1998
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH March 1998

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
3/1/98	717
3/2/98	722
3/3/98	729
3/4/98	730
3/5/98	728
3/6/98	727
3/7/98	724
3/8/98	723
3/9/98	721
3/10/98	728
3/11/98	732
3/12/98	735
3/13/98	735
3/14/98	732
3/15/98	725
3/16/98	725
3/17/98	728
3/18/98	725
3/19/98	724
3/20/98	723
3/21/98	721
3/22/98	728
3/23/98	729
3/24/98	727
3/25/98	727
3/26/98	727
3/27/98	726
3/28/98	721
3/29/98	718
3/30/98	715
3/31/98	719

DOCKET NO. 50-250
UNIT NAME TURKEY POINT UNIT 3
DATE April 1, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD March, 1998
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	2079.5	155197.3
4. Number of Hours Generator Was On Line_____	744.0	2070.8	153029.7
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	539748.0	1491690.0	97904246.0

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250
 UNIT NAME: Turkey Point #3
 DATE: April 1, 1998
 COMPLETED BY: C. L. Mowrey
 TELEPHONE: (305) 246-6204

REPORT MONTH March 1998

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-250</u>
UNIT:	<u>Turkey Point #3</u>
DATE:	<u>April 1, 1998</u>
COMPLETED BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305) 246-6204</u>

REPORT MONTH March 1998

Unit 3 operated at essentially 100% power for the entire month.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: April 1, 1998
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH March 1998

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
3/1/98	715
3/2/98	721
3/3/98	728
3/4/98	729
3/5/98	728
3/6/98	726
3/7/98	724
3/8/98	722
3/9/98	721
3/10/98	727
3/11/98	731
3/12/98	733
3/13/98	733
3/14/98	731
3/15/98	726
3/16/98	726
3/17/98	728
3/18/98	726
3/19/98	725
3/20/98	723
3/21/98	722
3/22/98	728
3/23/98	728
3/24/98	726
3/25/98	727
3/26/98	726
3/27/98	725
3/28/98	721
3/29/98	717
3/30/98	714
3/31/98	717

OPERATING DATA REPORT

DOCKET NO. 50-251
UNIT NAME TURKEY POINT UNIT 4
DATE April 1, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD March, 1998
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	2160.0	151467.5
4. Number of Hours Generator Was On Line_____	744.0	2160.0	147136.5
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	539374.0	1554693.0	95046330.0

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251
 UNIT NAME: Turkey Point #4
 DATE: April 1, 1998
 COMPLETED BY: C. L. Mowrey
 TELEPHONE: (305) 246-6204

REPORT MONTH March 1998

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action to Prevent Recurrence
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
 S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error
 (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)



SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>April 1, 1998</u>
COMPLETE BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305)246-6204</u>

REPORT MONTH March 1998

Unit 4 operated at essentially 100% power for the entire month.