

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9806150286      DOC.DATE: 98/05/31      NOTARIZED: NO      DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C      05000250  
       50-251 Turkey Point Plant, Unit 4, Florida Power and Light C      05000251  
 AUTH.NAME      AUTHOR AFFILIATION  
 MOWREY, C.L.      Florida Power & Light Co.  
 HOVEY, R.J.      Florida Power & Light Co.  
 RECIP.NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Turkey Point, Units 3 & 4.  
 W/980611 ltr.

DISTRIBUTION CODE: IE24D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1    1	JABBOUR, K	1    1
INTERNAL:	AEOD/SPD/RRAB	1    1	<b>FILE CENTER 01</b>	1    1
	OC/DBA/PAD	1    1	RGN2	1    1
EXTERNAL:	LITCO BRYCE, J H	1    1	NOAC	1    1
	NRC PDR	1    1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR    9    ENCL    9

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T





FPL

JUN 11 1998

L-98-163

10 CFR §50.36

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the May 1998 Operating Status and Summary of Operating Experience Reports for Turkey Point Units 3 and 4.

Very truly yours,

R. J. Hovey  
Vice President  
Turkey Point Plant

CLM

Attachments

cc: Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

11

Tez4

9806150286 980531  
PDR ADDCK 05000250  
R PDR



AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250  
UNIT: Turkey Point #3  
DATE: June 4, 1998  
COMPLETED BY: C. L. Mowrey  
TELEPHONE: (305) 246-6204

REPORT MONTH May 1998

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
5/1/98	705
5/2/98	709
5/3/98	703
5/5/98	702
5/5/98	705
5/6/98	701
5/7/98	699
5/8/98	699
5/9/98	701
5/10/98	700
5/11/98	702
5/12/98	706
5/13/98	357
5/15/98	442
5/15/98	699
5/16/98	711
5/17/98	711
5/18/98	708
5/19/98	705
5/20/98	703
5/21/98	703
5/22/98	702
5/23/98	702
5/25/98	703
5/25/98	704
5/26/98	703
5/27/98	703
5/28/98	707
5/29/98	700
5/30/98	705
5/31/98	702

DOCKET NO. 50-250  
UNIT NAME TURKEY POINT UNIT 3  
DATE June 4, 1998  
COMPLETED BY C. L. Mowrey  
TELEPHONE (305) 246-6204

REPORTING PERIOD May, 1998  
(Month/Year)

1. Design Electrical Rating (MWe-Net)\_\_\_\_\_ 720  
2. Maximum Dependable Capacity (MWe-Net)\_\_\_\_\_ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	3542.5	156660.3
4. Number of Hours Generator Was On Line_____	744.0	3533.8	154492.7
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	508839.0	2514381.0	98926937.0



# UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250  
 UNIT NAME: Turkey Point #3  
 DATE: June 4, 1998  
 COMPLETED BY: C. L. Mowrey  
 TELEPHONE: (305) 246-6204

REPORT MONTH May 1998

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Cause & Corrective Action Comments
1063	5/13/98	S	0.0	B	5	Turbine valve test
1064	5/13/98	S	0.0	B	4	Turbine Plant Cooling Water heat exchanger cleaning
1065	5/14/98	S	0.0	B	4	Condenser water box cleaning

1

F - Forced  
 S - Scheduled

2

Reason  
 A - Equipment Failure  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory restriction  
 E - Operator Training &  
 License Examination  
 F - Administrative  
 G - Operational Error (Explain)  
 H - Other (Explain)

3

Method 1 - Manual  
 2 - Manual Scram  
 3 - Automatic Scram  
 4 - Continued  
 5 - Load Reduction  
 9 - Other (Explain)



SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-250  
UNIT: Turkey Point #3  
DATE: June 4, 1998  
COMPLETED BY: C. L. Mowrey  
TELEPHONE: (305) 246-6204

REPORT MONTH May 1998

Unit 3 operated at essentially 100% power until May 13. Power was reduced to 40% to perform periodic turbine valve testing. Power was then maintained below 50% to perform Turbine Plant Cooling Water heat exchanger cleaning and Condenser water box cleaning. The unit was returned to essentially 100% power on May 14, and operated there for the remainder of the month.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251  
UNIT: Turkey Point #4  
DATE: June 4, 1998  
COMPLETED BY: C. L. Mowrey  
TELEPHONE: (305) 246-6204

REPORT MONTH May 1998

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
5/1/98	707
5/2/98	710
5/3/98	705
5/4/98	703
5/5/98	704
5/6/98	703
5/7/98	700
5/8/98	700
5/9/98	701
5/10/98	699
5/11/98	702
5/12/98	706
5/13/98	701
5/14/98	697
5/15/98	704
5/16/98	711
5/17/98	710
5/18/98	706
5/19/98	704
5/20/98	698
5/21/98	699
5/22/98	697
5/23/98	697
5/24/98	698
5/25/98	700
5/26/98	698
5/27/98	701
5/28/98	702
5/29/98	695
5/30/98	699
5/31/98	697



# OPERATING DATA REPORT

DOCKET NO. 50-251  
UNIT NAME TURKEY POINT UNIT 4  
DATE June 4, 1998  
COMPLETED BY C. L. Mowrey  
TELEPHONE (305) 246-6204

REPORTING PERIOD May, 1998  
(Month/Year)

1. Design Electrical Rating (MWe-Net)\_\_\_\_\_ 720
2. Maximum Dependable Capacity (MWe-Net)\_\_\_\_\_ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	3623.0	152930.5
4. Number of Hours Generator Was On Line_____	744.0	3623.0	148599.5
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	522106.0	2591089.0	96082726.0

# UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251  
 UNIT NAME: Turkey Point #4  
 DATE: June 4, 1998  
 COMPLETED BY: C. L. Mowrey  
 TELEPHONE: (305) 246-6204

REPORT MONTH May 1998

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Cause & Corrective Action to Prevent Recurrence
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced  
 S - Scheduled

2

Reason  
 A - Equipment Failure  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory restriction  
 E - Operator Training &  
 License Examination  
 F - Administrative  
 G - Operational Error  
 (Explain)  
 H - Other (Explain)

3

Method  
 1 - Manual  
 2 - Manual Scram  
 3 - Automatic Scram  
 4 - Continued  
 5 - Load Reduction  
 9 - Other (Explain)



SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>June 4, 1998</u>
COMPLETE BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305)246-6204</u>

REPORT MONTH May 1998

Unit 4 operated at essentially 100% power for the entire month.

